

PUTTALAM, Sri Lanka

WMO: 434240

Lat: 8.0271N

Lon: 79.8416E

Elev: 2

StdP: 101.30

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.3	21.2	18.2	13.1	25.3	18.9	13.7	24.6	5.2	28.4	4.4	28.1	0.7	50	0.330

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.0	33.7	26.7	33.1	26.8	32.6	26.8	28.4	31.8	28.1	31.6	27.7	31.2	2.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.4	30.9	27.1	22.8	30.6	26.7	22.3	30.2	91.8	31.9	90.0	31.7	88.5	31.4	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.4	4.8	DB	18.2	35.0	0.8	1.2	17.6	35.8	17.2	36.5	16.7	37.1	16.1	38.0	(4)
(5)			WB	17.8	29.0	0.8	0.7	17.2	29.4	16.7	29.8	16.3	30.2	15.7	30.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.0	25.8	26.9	28.4	29.0	29.5	29.1	29.0	28.8	28.7	28.0	26.9	26.2	(6)
(7)		DBStd	1.51	1.09	1.18	0.92	0.97	1.04	0.79	0.67	0.74	0.81	1.03	0.81	1.03	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6580	491	472	569	568	603	574	588	583	561	559	508	503	(10)
(11)		CDD18.3	3538	233	239	311	318	345	324	330	324	311	301	258	244	(11)
(12)		CDH23.3	39071	1853	2222	3588	3960	4479	4026	3957	3812	3644	3269	2313	1948	(12)
(13)		CDH26.7	14942	545	839	1579	1808	2080	1644	1496	1386	1327	1114	634	489	(13)
(14)	Wind	WSAvg	1.9	1.4	1.4	1.1	1.1	2.3	3.4	3.1	2.9	2.6	1.5	1.0	1.3	(14)
(15)	Precipitation	PrecAvg	1191	49	34	65	170	96	38	21	16	52	237	245	154	(15)
(16)		PrecMax	1644	207	111	182	411	287	164	131	59	197	615	551	411	(16)
(17)		PrecMin	731	0	0	0	37	0	1	1	0	0	3	91	29	(17)
(18)		PrecStd	252	49	30	59	85	79	44	31	19	51	134	119	84	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.9	33.9	35.2	34.1	33.7	32.4	32.7	32.6	32.3	32.5	31.9	31.4	(19)
(20)			MCWB	25.1	24.6	24.9	27.6	28.0	27.2	26.4	26.4	26.4	26.0	25.8	25.4	(20)
(21)		2%	DB	30.8	32.6	33.8	33.5	33.0	31.8	31.9	31.8	31.6	31.7	31.1	30.7	(21)
(22)			MCWB	24.6	24.9	25.7	27.7	27.7	27.0	26.5	26.3	26.4	26.2	26.0	25.2	(22)
(23)		5%	DB	30.2	31.7	33.0	33.0	32.4	31.3	31.3	31.3	31.2	31.2	30.5	30.1	(23)
(24)			MCWB	24.3	24.9	26.1	27.5	27.5	26.9	26.4	26.3	26.3	26.2	25.9	25.2	(24)
(25)		10%	DB	29.5	30.8	32.3	32.4	31.9	30.9	30.8	30.7	30.7	30.6	29.8	29.3	(25)
(26)			MCWB	24.2	25.0	26.2	27.4	27.4	26.7	26.2	26.2	26.2	26.2	25.8	24.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.6	27.1	28.1	29.0	29.1	28.1	27.5	27.7	27.6	27.5	27.1	26.9	(27)
(28)			MCD B	29.9	31.1	32.4	32.5	32.0	31.0	30.9	30.9	30.9	30.8	30.3	29.9	(28)
(29)		2%	WB	25.9	26.6	27.6	28.5	28.5	27.7	27.1	27.1	27.1	27.0	26.7	26.3	(29)
(30)			MCD B	29.3	30.4	31.9	32.1	31.6	30.6	30.5	30.3	30.3	30.3	29.8	29.2	(30)
(31)		5%	WB	25.4	26.1	27.2	28.1	28.1	27.3	26.7	26.7	26.7	26.7	26.3	25.9	(31)
(32)			MCD B	28.6	29.9	31.4	31.8	31.4	30.3	30.1	29.8	29.9	29.9	29.3	28.6	(32)
(33)		10%	WB	24.9	25.7	26.8	27.7	27.7	27.0	26.5	26.5	26.5	26.4	26.1	25.5	(33)
(34)			MCD B	27.9	29.2	30.9	31.4	30.9	30.0	29.8	29.6	29.6	29.5	28.9	27.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.8	8.7	8.6	7.1	5.0	3.6	4.1	4.3	4.3	5.2	6.0	6.3	(35)
(36)			MCDBR	8.8	9.8	9.4	7.6	5.7	4.1	4.7	4.8	4.8	5.9	7.1	7.4	(36)
(37)			MCWBR	3.5	3.4	3.4	3.2	2.2	1.5	1.5	1.5	1.7	2.1	2.9	3.0	(37)
(38)		5% WB	MCD BR	7.4	8.2	8.3	7.1	5.5	3.7	4.3	4.4	4.5	5.5	6.4	6.2	(38)
(39)			MCWBR	3.4	3.5	3.5	3.4	2.5	1.7	1.6	1.7	1.9	2.3	2.9	2.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.437	0.437	0.476	0.492	0.541	0.513	0.527	0.508	0.477	0.481	0.468	0.461	(40)	
(41)		taud	2.351	2.325	2.236	2.222	2.069	2.161	2.104	2.169	2.272	2.266	2.300	2.298	(41)	
(42)		Ebn at Noon	877	887	853	827	771	782	775	803	840	836	841	845	(42)	
(43)		Edh at Noon	126	133	147	147	167	150	160	153	139	139	132	131	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.08	5.89	6.38	6.14	5.73	5.64	5.74	5.84	5.92	5.37	4.50	4.43	(44)	
(45)		RadStd	0.40	0.32	0.27	0.27	0.40	0.26	0.23	0.26	0.32	0.29	0.36	0.40	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (9 neighbors)	+0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page