

BATTICALOA, Sri LankaWMO: **434360**Lat: **7.7124N**Lon: **81.7011E**Elev: **20**StdP: **14.69**Time Zone: **5.50 (IND)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	73.3	74.6	66.3	96.8	82.5	67.6	101.6	83.4	17.3	81.0	15.5	81.0	1.3	270	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	12.4	96.2	77.6	94.4	78.1	92.7	79.1	83.0	89.5	82.5	89.2	81.9	88.7	6.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.2	162.3	87.7	80.7	159.3	87.5	80.1	156.1	87.1	47.0	89.9	46.4	89.4	45.9	89.0	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.7	11.7	10.0	DB	68.6	100.0	2.4	1.2	66.9	100.9	65.5	101.6	64.1	102.3	62.3	103.2	(4)
(5)			WB	66.9	84.5	2.1	0.7	65.4	85.0	64.2	85.4	63.1	85.8	61.6	86.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	83.3	79.2	80.4	82.6	84.6	85.8	86.6	86.5	85.4	84.7	82.8	80.9	79.9
	DBStd	3.13	1.88	1.93	1.60	1.71	1.68	1.72	1.84	2.02	1.85	2.01	1.49	1.77
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12156	904	852	1009	1039	1109	1099	1131	1098	1041	1018	928	928
	CDD65	6681	439	432	544	589	644	649	666	633	591	553	478	463
	CDH74	81482	4110	4543	6620	7823	8770	8880	8962	8239	7488	6498	5036	4513
	CDH80	33062	614	1084	2426	3593	4375	4584	4544	3881	3310	2436	1338	877
Wind	WSAvg	3.2	5.1	4.7	3.8	2.8	2.5	2.3	2.5	2.5	2.4	2.7	3.0	4.4
Precipitation	PrecAvg	69.8	9.3	6.0	3.0	2.0	1.8	0.7	2.0	2.1	2.7	7.5	14.5	18.3
	PrecMax	114.1	23.1	26.0	8.9	5.6	5.4	3.5	8.8	4.6	8.3	22.2	32.9	32.2
	PrecMin	34.1	0.1	0.0	0.0	0.0	0.1	0.0	0.1	0.2	0.0	1.7	4.5	5.4
	PrecStd	19.9	7.7	6.0	2.6	1.5	1.5	1.0	2.2	1.5	2.1	5.1	7.4	7.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.3	87.0	89.5	92.6	94.8	97.9	98.1	97.3	96.5	93.0	88.7	86.4
		MCWB	78.2	79.2	80.2	81.9	80.7	78.3	77.4	77.0	76.7	77.6	77.9	78.2
	2%	DB	84.2	85.9	88.4	91.4	92.7	96.0	95.7	94.5	92.9	90.2	87.1	85.2
		MCWB	77.1	78.7	79.7	81.6	81.1	78.1	77.2	77.4	78.2	78.9	78.7	78.0
	5%	DB	83.4	85.0	87.6	90.3	91.7	93.9	93.8	92.1	90.9	88.9	86.1	84.4
		MCWB	76.7	78.1	79.3	81.3	81.3	78.6	77.6	78.4	79.2	79.3	78.7	77.7
	10%	DB	82.7	84.2	86.8	89.4	90.8	92.0	92.0	90.5	89.6	87.8	85.1	83.6
		MCWB	76.2	77.5	79.0	81.0	81.3	79.4	78.4	79.0	79.4	79.3	78.5	77.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.9	80.7	81.7	83.6	83.7	83.7	82.2	82.3	82.6	81.6	80.8	80.4
		MCDB	83.4	85.8	87.6	90.2	89.8	90.2	89.0	88.7	88.7	87.0	86.2	84.1
	2%	WB	79.0	79.8	80.8	82.7	83.2	82.5	81.5	81.5	81.5	80.9	80.0	79.7
		MCDB	82.6	84.6	86.9	89.3	89.5	89.6	88.7	88.3	88.0	86.8	85.1	83.4
	5%	WB	78.3	79.1	80.2	82.0	82.6	81.8	80.9	80.8	80.8	80.4	79.6	79.1
		MCDB	81.9	83.7	86.1	88.5	89.2	89.2	88.4	88.0	87.5	86.6	84.5	82.8
	10%	WB	77.7	78.6	79.7	81.5	82.1	81.2	80.2	80.2	80.2	79.9	79.1	78.6
		MCDB	81.3	83.0	85.5	88.0	88.9	88.8	88.1	87.6	87.1	86.0	83.8	82.3
Mean Daily Temperature Range	5% DB	MDBR	6.7	6.9	8.6	9.8	10.7	12.4	12.8	11.9	11.3	10.0	7.9	6.4
		MCDBR	7.2	7.5	9.5	10.5	11.7	14.9	15.0	14.1	13.2	11.8	9.3	7.6
		MCWBR	3.4	3.6	4.0	3.9	5.2	5.2	5.3	5.7	5.9	5.2	4.1	3.5
	5% WB	MCDBR	6.3	6.8	8.4	9.9	10.7	11.9	12.3	11.8	11.3	10.3	8.6	6.7
		MCWBR	3.6	3.6	4.1	4.3	5.3	5.8	5.8	6.0	5.8	5.2	4.1	3.4
Clear-Sky Solar Irradiance	taub	0.448	0.445	0.457	0.459	0.502	0.473	0.495	0.483	0.459	0.461	0.454	0.463	
	taud	2.333	2.326	2.300	2.338	2.205	2.313	2.220	2.266	2.339	2.330	2.356	2.302	
	Ebn at Noon	275	279	276	271	254	259	254	261	271	271	271	268	
	Edh at Noon	41	42	43	42	46	41	45	44	41	41	40	42	
All-Sky Solar Radiation	RadAvg	1427	1692	1935	1911	1874	1842	1842	1884	1874	1721	1379	1262	
	RadStd	142	128	114	85	114	84	64	68	102	90	115	158	