

BATTICALOA, Sri LankaWMO: **434360**Lat: **7.7124N**Lon: **81.7011E**Elev: **6**StdP: **101.25**Time Zone: **5.50 (IND)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.0	23.6	19.0	13.8	28.1	19.8	14.5	28.5	7.7	27.2	6.9	27.2	0.6	270	0.363

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.9	35.7	25.3	34.7	25.6	33.7	26.1	28.3	32.0	28.1	31.8	27.7	31.5	2.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.3	23.2	31.0	27.0	22.8	30.9	26.7	22.3	30.6	91.5	32.1	90.2	31.9	88.9	31.7	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.2	4.5	20.4	37.8	1.4	0.7	19.4	38.3	18.6	38.7	17.8	39.1	16.8	39.6		
(5)			19.4	29.1	1.1	0.4	18.6	29.4	17.9	29.7	17.3	29.9	16.4	30.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.5	26.2	26.9	28.1	29.2	29.9	30.4	30.3	29.7	29.3	28.2	27.2	26.6		
	DBStd	1.74	1.05	1.07	0.89	0.95	0.94	0.95	1.02	1.12	1.03	1.12	0.83	0.98		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6753	502	473	561	577	616	611	628	610	578	566	516	516		
	CDD18.3	3712	244	240	302	327	358	361	370	352	328	307	266	257		
	CDH23.3	45268	2283	2524	3678	4346	4872	4933	4979	4577	4160	3610	2798	2507		
	CDH26.7	18368	341	602	1348	1996	2431	2547	2524	2156	1839	1353	743	487		
(14) Wind	WSAvg	1.4	2.3	2.1	1.7	1.2	1.1	1.0	1.1	1.1	1.1	1.2	1.3	1.9		
(15) Precipitation	PrecAvg	1773	236	153	77	52	45	17	51	54	69	191	369	464		
	PrecMax	2897	586	661	225	143	137	90	223	117	210	564	836	817		
	PrecMin	865	2	0	0	0	3	0	3	4	1	43	115	136		
	PrecStd	506	195	153	67	38	39	25	57	38	53	130	189	200		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.6	30.6	32.0	33.7	34.9	36.6	36.7	36.3	35.8	33.9	31.5	30.2		
		MCWB	25.7	26.2	26.8	27.7	27.1	25.7	25.2	25.0	24.9	25.3	25.5	25.7		
	2%	DB	29.0	29.9	31.4	33.0	33.7	35.6	35.4	34.7	33.8	32.3	30.6	29.6		
		MCWB	25.1	25.9	26.5	27.6	27.3	25.6	25.1	25.2	25.7	26.1	25.9	25.6		
	5%	DB	28.6	29.4	30.9	32.4	33.2	34.4	34.4	33.4	32.7	31.6	30.0	29.1		
		MCWB	24.8	25.6	26.3	27.4	27.4	25.9	25.3	25.8	26.2	26.3	25.9	25.4		
	10%	DB	28.2	29.0	30.5	31.9	32.6	33.4	33.3	32.5	32.0	31.0	29.5	28.6		
		MCWB	24.6	25.3	26.1	27.2	27.4	26.3	25.8	26.1	26.3	26.3	25.8	25.3		
	0.4%	WB	26.6	27.0	27.6	28.7	28.7	28.7	27.9	28.0	28.1	27.6	27.1	26.9		
		MCDB	28.6	29.9	30.9	32.4	32.1	32.4	31.7	31.5	31.5	30.5	30.1	29.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	26.1	26.6	27.1	28.2	28.4	28.1	27.5	27.5	27.5	27.2	26.7	26.5		
		MCDB	28.1	29.2	30.5	31.8	32.0	32.0	31.5	31.3	31.1	30.5	29.5	28.6		
	5%	WB	25.7	26.2	26.8	27.8	28.1	27.7	27.1	27.1	27.1	26.9	26.4	26.2		
		MCDB	27.7	28.7	30.1	31.4	31.8	31.8	31.3	31.1	30.8	30.3	29.1	28.2		
	10%	WB	25.4	25.9	26.5	27.5	27.9	27.3	26.8	26.8	26.8	26.6	26.2	25.9		
		MCDB	27.4	28.4	29.7	31.1	31.6	31.6	31.1	30.9	30.6	30.0	28.8	27.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	3.7	3.9	4.8	5.4	5.9	6.9	7.1	6.6	6.3	5.5	4.4	3.5		
		MCDBR	4.0	4.2	5.3	5.8	6.5	8.3	8.3	7.8	7.3	6.5	5.2	4.2		
		MCWBR	1.9	2.0	2.2	2.2	2.9	2.9	3.0	3.2	3.3	2.9	2.3	2.0		
	5% WB	MCDBR	3.5	3.8	4.7	5.5	6.0	6.6	6.8	6.5	6.3	5.7	4.8	3.7		
		MCWBR	2.0	2.0	2.3	2.4	3.0	3.2	3.2	3.3	3.2	2.9	2.3	1.9		
(40) Clear-Sky Solar Irradiance	taub		0.448	0.445	0.457	0.459	0.502	0.473	0.495	0.483	0.459	0.461	0.454	0.463		
	taud		2.333	2.326	2.300	2.338	2.205	2.313	2.220	2.266	2.339	2.330	2.356	2.302		
	Ebn at Noon		867	880	870	855	801	815	800	824	855	855	855	844		
	Edh at Noon		129	133	137	131	145	128	142	139	130	130	125	131		
(44) All-Sky Solar Radiation	RadAvg		4.50	5.33	6.10	6.02	5.91	5.81	5.81	5.94	5.91	5.42	4.35	3.98		
	RadStd		0.45	0.40	0.36	0.27	0.36	0.26	0.20	0.21	0.32	0.28	0.36	0.50		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page