

KANDY, Sri Lanka

WMO: 434440

Lat: 7.3344N

Lon: 80.6266E

Elev: 1565

StdP: 13.88

Time Zone: 5.50 (IND)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	63.2	65.4	58.4	77.2	74.2	60.6	83.8	73.1	8.5	79.4	7.4	79.3	0.3	N/A	0.193

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	15.6	90.0	74.0	88.5	74.5	87.3	74.6	77.7	85.6	77.1	84.7	76.5	83.7	3.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.5	141.8	81.3	74.9	138.9	80.6	74.5	136.7	80.0	42.5	85.9	41.8	84.9	41.3	84.3	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	7.6	6.3		DB	57.9	92.8	1.3	2.1	56.9	94.3	56.2	95.6	55.4	96.8	54.5	98.3
				WB	57.5	79.8	1.5	0.9	56.4	80.5	55.5	81.0	54.7	81.5	53.6	82.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.0	74.5	76.5	78.9	79.5	78.7	77.5	77.3	76.7	76.7	76.9	76.3	74.9
	DBStd	2.31	2.46	2.22	1.92	1.72	1.74	1.51	1.34	1.51	1.44	1.55	1.76	2.13
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9871	761	743	897	886	890	824	847	829	801	832	788	773
	CDD65	4396	296	323	432	436	425	374	382	364	351	367	338	308
	CDH74	27843	1665	2173	3489	3267	3178	2379	2367	2102	2034	2081	1701	1407
CDH80	6925	356	670	1393	1135	885	338	343	334	374	488	359	250	
Wind	WSAvg	1.6	1.4	1.7	1.3	0.9	1.6	2.7	2.8	2.1	1.9	1.3	0.8	1.1
Precipitation	PrecAvg	74.6	3.0	3.2	2.6	7.6	5.9	4.8	5.0	4.4	6.1	11.6	12.7	7.8
	PrecMax	93.1	10.2	12.4	4.8	13.3	16.2	7.6	9.3	10.0	15.9	20.2	19.7	15.5
	PrecMin	56.6	0.0	0.0	1.1	2.2	0.0	1.2	1.0	1.6	0.8	5.4	3.5	2.3
	PrecStd	10.0	2.6	3.0	1.1	2.4	4.1	1.7	2.3	2.2	3.7	4.0	5.0	3.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.1	89.2	92.9	91.3	89.5	86.4	87.0	86.7	86.7	87.9	86.7	86.0
		MCWB	72.4	72.7	71.3	75.5	77.4	75.9	75.1	75.4	74.7	73.6	75.0	73.6
	2%	DB	85.0	87.6	90.6	89.4	87.7	84.9	84.5	84.8	85.0	86.1	85.2	84.3
		MCWB	72.5	72.8	72.1	76.2	76.7	75.4	74.5	74.6	74.4	74.0	74.5	73.2
	5%	DB	83.5	86.0	88.9	87.9	86.3	83.3	83.3	83.6	83.6	84.7	83.9	82.8
		MCWB	71.9	72.5	72.8	76.3	76.2	74.8	74.1	74.0	74.0	74.1	74.1	73.0
	10%	DB	82.0	84.3	87.3	86.4	84.9	82.0	82.0	81.9	82.3	82.9	82.4	81.2
		MCWB	71.4	72.3	73.1	75.9	76.0	74.4	73.7	73.6	73.7	74.0	74.1	72.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.6	76.1	77.0	79.0	78.8	77.2	76.3	76.5	76.5	76.9	76.6	76.5
		MCDB	83.1	85.3	85.9	87.6	86.9	84.3	83.5	83.8	83.6	83.6	83.3	82.0
	2%	WB	74.4	75.1	76.1	77.8	77.7	76.2	75.4	75.4	75.6	75.6	75.7	75.5
		MCDB	81.5	83.8	84.8	86.1	85.5	82.8	82.3	82.5	82.3	82.3	82.1	81.0
	5%	WB	73.5	74.3	75.4	77.1	77.1	75.5	74.7	74.6	74.9	75.1	75.2	74.5
		MCDB	80.1	82.3	84.0	85.0	84.5	81.5	81.3	81.3	81.2	81.6	81.4	79.9
	10%	WB	72.7	73.5	74.7	76.4	76.4	74.8	74.1	74.0	74.2	74.5	74.5	73.7
		MCDB	78.7	80.8	82.8	83.6	83.1	80.4	80.4	80.2	80.2	80.4	80.1	78.6
Mean Daily Temperature Range	5% DB	MDBR	15.2	16.8	18.4	15.6	13.0	9.5	9.7	10.8	11.9	13.4	12.7	12.1
		MCDBR	18.2	19.8	21.0	17.4	15.8	12.0	12.6	13.7	14.6	16.3	15.2	15.9
		MCWBR	7.3	6.9	6.4	6.0	6.1	4.7	4.9	5.3	5.7	6.0	5.9	6.4
	5% WB	MCDBR	14.1	15.6	17.7	15.5	14.1	10.4	10.9	11.9	12.9	13.6	13.3	12.4
		MCWBR	6.4	6.5	6.5	6.0	5.9	4.7	4.8	5.1	5.6	5.7	5.9	5.9
Clear-Sky Solar Irradiance	taub	0.401	0.407	0.438	0.455	0.475	0.453	0.470	0.454	0.431	0.439	0.426	0.415	
	taud	2.393	2.357	2.283	2.276	2.222	2.306	2.232	2.286	2.361	2.332	2.371	2.377	
	Ebn at Noon	290	291	281	272	261	264	260	269	279	278	280	283	
	Edh at Noon	38	41	44	44	45	41	44	43	41	41	39	38	
All-Sky Solar Radiation	RadAvg	1490	1749	1912	1828	1697	1620	1626	1653	1689	1600	1381	1313	
	RadStd	144	111	109	89	118	84	77	78	111	85	111	137	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page