

COLOMBO, Sri Lanka

WMO: 434660

Lat: 6.9047N

Lon: 79.8720E

Elev: 23

StdP: 14.68

Time Zone: 5.50 (IND)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	72.9	74.0	63.6	88.0	80.2	65.5	94.1	79.7	12.1	80.4	10.0	81.3	2.3	50	0.330

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	7.6	90.4	78.7	89.6	78.9	88.9	78.8	81.8	87.5	81.3	87.0	80.8	86.6	5.0	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	156.4	85.7	79.6	153.5	85.3	79.1	151.0	85.0	45.6	87.8	45.0	87.5	44.5	87.0	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.8	8.6	7.6	DB	66.4	93.7	4.7	1.5	63.1	94.8	60.3	95.6	57.7	96.5	54.3	97.6	
			WB	64.7	83.3	3.1	0.9	62.4	84.0	60.6	84.5	58.9	85.0	56.7	85.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	82.2	80.7	81.7	82.8	83.6	83.9	83.0	82.8	82.4	82.1	81.7	80.9	80.6	(6)
(7)		DBStd	1.94	1.82	1.70	1.36	1.81	1.83	1.53	1.59	1.51	1.71	1.48	1.40	1.79	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	11742	952	886	1017	1007	1051	989	1017	1004	962	981	928	948	(10)
(11)		CDD65	6267	487	466	552	557	586	539	552	539	512	516	478	483	(11)
(12)		CDH74	69795	4748	4906	6574	6780	7350	6435	6434	6084	5655	5558	4675	4596	(12)
(13)		CDH80	23759	1481	1654	2542	2850	3052	2246	2102	1806	1661	1689	1358	1318	(13)
(14)	Wind	WSAvg	3.1	3.6	2.9	2.4	2.4	3.6	4.0	3.7	3.7	3.3	2.5	2.2	3.1	(14)
(15)	Precipitation	PrecAvg	97.2	2.9	3.0	4.8	9.6	14.1	7.6	5.4	4.1	8.9	14.5	13.2	6.7	(15)
(16)		PrecMax	154.3	8.3	8.7	14.1	24.3	29.6	23.7	19.0	10.7	21.7	34.3	38.2	18.8	(16)
(17)		PrecMin	69.8	0.0	0.0	0.0	2.8	1.9	1.2	0.4	0.1	0.8	3.7	2.3	0.7	(17)
(18)		PrecStd	18.9	2.2	2.4	2.9	5.2	7.3	4.0	4.2	2.8	5.2	6.6	6.5	4.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.6	91.7	90.8	91.3	90.3	88.2	88.2	87.9	87.7	88.1	89.0	89.9	(19)
(20)			MCWB	74.7	76.0	78.6	80.8	81.1	80.3	79.7	79.3	79.3	78.6	77.0	75.2	(20)
(21)		2%	DB	88.9	89.8	89.6	90.2	89.4	87.4	87.2	86.9	86.8	87.2	87.9	88.1	(21)
(22)			MCWB	74.9	76.1	78.6	80.4	80.9	80.3	79.4	79.1	79.0	78.7	77.9	76.0	(22)
(23)		5%	DB	87.7	88.2	88.7	89.5	88.6	86.8	86.4	86.1	86.2	86.6	87.0	87.0	(23)
(24)			MCWB	75.0	76.6	78.5	80.3	80.7	80.0	79.1	78.8	78.8	78.6	78.0	76.5	(24)
(25)		10%	DB	86.4	87.0	87.9	88.7	87.8	86.1	85.7	85.4	85.5	85.9	86.1	85.9	(25)
(26)			MCWB	75.3	76.8	78.4	80.1	80.4	79.6	78.8	78.6	78.6	78.4	78.0	76.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.6	80.0	81.4	82.4	82.8	81.8	80.8	80.7	80.6	80.6	80.0	79.8	(27)
(28)			MCD B	86.0	85.7	87.6	89.3	87.8	86.2	86.4	85.9	85.9	85.7	86.1	84.9	(28)
(29)		2%	WB	78.3	79.2	80.2	81.6	81.9	81.0	80.0	79.9	79.9	79.8	79.2	78.9	(29)
(30)			MCD B	84.7	85.4	87.0	88.4	87.3	85.8	85.5	85.1	85.1	85.0	85.3	84.4	(30)
(31)		5%	WB	77.6	78.5	79.8	81.0	81.5	80.5	79.6	79.2	79.3	79.2	78.9	78.3	(31)
(32)			MCD B	84.1	84.9	86.6	87.7	86.9	85.5	84.9	84.4	84.4	84.5	85.0	83.8	(32)
(33)		10%	WB	77.0	78.0	79.2	80.6	80.9	80.0	79.1	78.9	78.9	78.9	78.4	77.8	(33)
(34)			MCD B	83.4	84.4	86.0	87.3	86.3	84.9	84.4	84.1	84.0	84.2	84.2	83.3	(34)
(35)	Mean Daily Temperature Range		MDBR	12.3	11.8	10.9	10.4	7.6	6.3	5.9	6.1	6.6	8.6	10.3	10.7	(35)
(36)		5% DB	MCD BR	13.8	13.1	11.5	10.7	8.4	6.9	6.2	6.7	7.2	9.3	11.8	12.3	(36)
(37)			MCWBR	5.9	5.5	4.4	4.5	3.6	3.2	2.7	2.7	2.9	3.7	4.3	4.7	(37)
(38)		5% WB	MCD BR	11.8	11.4	10.9	10.3	7.7	6.4	6.0	6.6	7.0	8.9	10.8	10.8	(38)
(39)			MCWBR	5.6	5.1	4.6	4.7	3.8	3.3	2.9	2.9	3.2	3.8	4.5	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.437	0.452	0.496	0.501	0.518	0.499	0.515	0.495	0.464	0.471	0.469	0.455	(40)	
(41)		taud	2.367	2.307	2.200	2.213	2.152	2.219	2.148	2.223	2.327	2.303	2.307	2.331	(41)	
(42)		Ebn at Noon	279	278	266	260	250	251	248	258	270	269	267	271	(42)	
(43)		Edh at Noon	40	43	48	47	49	45	48	46	42	43	42	40	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1687	1896	2000	1888	1695	1684	1727	1759	1774	1693	1497	1501	(44)	
(45)		RadStd	120	102	92	95	126	97	82	89	121	105	108	127	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (9 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page