

COLOMBO, Sri Lanka

WMO: 434660

Lat: 6.9047N

Lon: 79.8720E

Elev: 7

StdP: 101.24

Time Zone: 5.50 (IND)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.7	23.3	17.5	12.6	26.8	18.6	13.4	26.5	5.4	26.9	4.5	27.4	1.0	50	0.330

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	4.2	32.4	26.0	32.0	26.0	31.6	26.0	27.7	30.8	27.4	30.5	27.1	30.3	2.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	29.8	26.4	21.9	29.6	26.2	21.6	29.5	88.2	31.0	86.8	30.9	85.7	30.6	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.4	3.9	3.4	DB	19.1	34.3	2.6	0.8	17.3	34.9	15.7	35.4	14.3	35.8	12.4	36.4	(4)
(5)			WB	18.1	28.5	1.7	0.5	16.9	28.9	15.9	29.2	14.9	29.4	13.7	29.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.9	27.1	27.6	28.2	28.6	28.8	28.3	28.2	28.0	27.8	27.6	27.2	27.0	(6)
(7)		DBStd	1.08	1.01	0.94	0.76	1.00	1.02	0.85	0.88	0.84	0.95	0.82	0.78	1.00	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6523	529	492	565	559	584	549	565	558	534	545	516	527	(10)
(11)		CDD18.3	3482	271	259	307	309	326	299	307	299	284	287	266	268	(11)
(12)		CDH23.3	38775	2638	2726	3652	3767	4083	3575	3574	3380	3142	3088	2597	2553	(12)
(13)		CDH26.7	13199	823	919	1412	1583	1696	1248	1168	1003	923	938	754	732	(13)
(14)	Wind	WSAvg	1.4	1.6	1.3	1.1	1.1	1.6	1.8	1.6	1.7	1.5	1.1	1.0	1.4	(14)
(15)	Precipitation	PrecAvg	2469	74	76	121	243	358	192	136	104	227	369	336	171	(15)
(16)		PrecMax	3920	211	220	357	618	752	602	482	271	551	871	971	477	(16)
(17)		PrecMin	1774	0	0	1	71	48	30	11	3	20	95	59	19	(17)
(18)		PrecStd	479	56	61	74	131	185	102	107	72	132	168	165	108	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.5	33.2	32.7	33.0	32.4	31.2	31.2	31.1	31.0	31.2	31.7	32.1	(19)
(20)			MCWB	23.7	24.4	25.9	27.1	27.3	26.8	26.5	26.3	26.3	25.9	25.0	24.0	(20)
(21)		2%	DB	31.6	32.1	32.0	32.3	31.9	30.8	30.7	30.5	30.5	30.7	31.1	31.2	(21)
(22)			MCWB	23.8	24.5	25.9	26.9	27.2	26.8	26.4	26.1	26.1	25.9	25.5	24.4	(22)
(23)		5%	DB	30.9	31.2	31.5	32.0	31.5	30.5	30.2	30.1	30.1	30.3	30.6	30.6	(23)
(24)			MCWB	23.9	24.8	25.8	26.8	27.0	26.6	26.2	26.0	26.0	25.9	25.6	24.7	(24)
(25)		10%	DB	30.2	30.6	31.1	31.5	31.0	30.1	29.8	29.7	29.7	29.9	30.1	29.9	(25)
(26)			MCWB	24.1	24.9	25.8	26.7	26.9	26.5	26.0	25.9	25.9	25.8	25.6	25.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.5	26.7	27.4	28.0	28.2	27.7	27.1	27.1	27.0	27.0	26.7	26.6	(27)
(28)			MCDWB	30.0	29.8	30.9	31.8	31.0	30.1	30.2	29.9	30.0	29.8	30.1	29.4	(28)
(29)		2%	WB	25.7	26.2	26.8	27.6	27.7	27.2	26.7	26.6	26.6	26.6	26.2	26.1	(29)
(30)			MCDWB	29.3	29.6	30.6	31.3	30.7	29.9	29.7	29.5	29.5	29.5	29.6	29.1	(30)
(31)		5%	WB	25.4	25.9	26.5	27.2	27.5	26.9	26.4	26.2	26.3	26.2	26.1	25.7	(31)
(32)			MCDWB	28.9	29.4	30.3	31.0	30.5	29.7	29.4	29.1	29.1	29.2	29.5	28.8	(32)
(33)		10%	WB	25.0	25.6	26.2	27.0	27.2	26.7	26.2	26.1	26.1	26.1	25.8	25.4	(33)
(34)			MCDWB	28.5	29.1	30.0	30.7	30.2	29.4	29.1	29.0	28.9	29.0	29.0	28.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.8	6.6	6.0	5.8	4.2	3.5	3.3	3.4	3.7	4.8	5.7	6.0	(35)
(36)			MCDBR	7.6	7.3	6.4	5.9	4.6	3.8	3.4	3.7	4.0	5.2	6.5	6.8	(36)
(37)			MCWBR	3.3	3.1	2.5	2.5	2.0	1.8	1.5	1.5	1.6	2.0	2.4	2.6	(37)
(38)		5% WB	MCDWB	6.6	6.4	6.1	5.7	4.3	3.5	3.4	3.7	3.9	4.9	6.0	6.0	(38)
(39)			MCWBR	3.1	2.8	2.6	2.6	2.1	1.8	1.6	1.6	1.8	2.1	2.5	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.437	0.452	0.496	0.501	0.518	0.499	0.515	0.495	0.464	0.471	0.469	0.455	(40)	
(41)		taud	2.367	2.307	2.200	2.213	2.152	2.219	2.148	2.223	2.327	2.303	2.307	2.331	(41)	
(42)		Ebn at Noon	880	875	837	820	787	792	783	814	852	847	843	854	(42)	
(43)		Edh at Noon	125	136	152	148	153	141	152	144	132	134	131	127	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.32	5.98	6.30	5.95	5.34	5.31	5.44	5.55	5.59	5.34	4.72	4.73	(44)	
(45)		RadStd	0.38	0.32	0.29	0.30	0.40	0.30	0.26	0.28	0.38	0.33	0.34	0.40	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (9 neighbors)		+0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page