

NUWARA ELIYA, Sri Lanka

WMO: 434730

Lat: 6.9698N

Lon: 80.7789E

Elev: 1880

StdP: 80.69

Time Zone: 5.50 (IND)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.6	8.9	-2.3	3.9	12.1	0.2	4.8	13.0	8.0	13.2	6.9	13.9	0.1	50	0.366

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.9	23.1	16.0	22.3	15.9	21.7	16.0	18.5	21.3	18.1	20.7	17.7	20.2	1.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.6	15.9	20.1	17.1	15.4	19.5	16.7	15.0	19.0	61.3	21.5	59.5	20.9	58.2	20.4	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	7.9	6.6	5.3	27.7	1.2	1.3	4.4	28.6	3.7	29.4	3.0	30.1	2.1	31.0	
			DB	5.3	27.7	1.2	1.3	4.4	28.6	3.7	29.4	3.0	30.1	2.1	31.0
			WB	1.9	22.6	0.7	2.2	1.4	24.2	1.0	25.5	0.6	26.7	0.1	28.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.2	15.0	15.8	16.5	17.1	17.5	16.5	16.2	16.3	16.3	16.2	16.1	15.5
	DBStd	1.21	1.37	1.33	1.08	0.83	0.82	0.94	1.06	1.00	0.83	0.83	0.83	1.25
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	775	104	72	58	38	28	57	67	64	62	65	69	90
	CDD10.0	2275	154	162	201	212	232	193	192	196	188	193	182	169
	CDD18.3	9	1	1	1	1	2	1	1	1	0	1	1	1
	CDH23.3	21	2	4	3	2	3	1	2	2	0	1	1	1
	CDH26.7	1	0	1	0	0	0	0	0	1	0	0	0	0
Wind	WSAvg	2.0	1.2	1.6	1.2	0.9	1.5	4.1	3.8	3.2	2.7	1.4	1.2	1.4
Precipitation	PrecAvg	1931	103	87	61	159	168	148	170	149	184	227	223	207
	PrecMax	2605	191	240	145	327	423	404	355	319	427	453	558	378
	PrecMin	1298	0	0	3	17	23	41	35	36	36	74	77	19
	PrecStd	343	57	74	40	68	98	80	83	68	114	101	103	90
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.1	23.5	23.8	23.6	23.8	22.0	22.0	21.9	21.9	21.6	21.1	21.3
		MCWB	14.3	14.9	14.8	17.0	17.3	17.9	16.9	17.0	16.9	16.6	16.2	14.7
	2%	DB	20.8	21.8	22.7	22.7	22.6	20.3	20.5	20.5	20.5	20.5	20.1	20.1
		MCWB	14.1	13.5	14.1	16.5	17.4	17.1	16.4	16.6	16.7	16.8	16.4	15.6
	5%	DB	19.7	20.7	21.8	22.0	21.7	19.2	19.3	19.4	19.6	19.7	19.5	19.3
		MCWB	14.7	14.4	14.4	16.8	17.4	16.5	16.1	16.2	16.3	16.5	16.2	15.7
	10%	DB	18.8	19.7	21.0	21.2	20.9	18.2	18.3	18.5	18.7	19.0	18.8	18.4
		MCWB	14.9	14.8	14.8	16.8	17.3	16.0	15.7	15.8	15.9	16.3	16.0	15.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.4	17.7	18.2	19.1	19.1	18.5	17.8	17.9	17.9	18.2	17.7	17.7
		MCDB	19.7	20.6	21.3	21.8	22.0	21.0	20.5	20.4	20.4	20.5	19.6	19.5
	2%	WB	16.6	17.0	17.6	18.4	18.5	17.4	17.1	17.2	17.2	17.4	17.2	17.0
		MCDB	18.7	19.5	20.4	21.2	21.3	19.6	19.6	19.6	19.6	19.6	19.2	18.8
	5%	WB	16.1	16.4	17.1	17.9	18.1	16.7	16.4	16.6	16.7	17.0	16.8	16.5
		MCDB	18.1	18.8	19.8	20.7	20.8	18.5	18.5	18.8	18.9	19.0	18.7	18.1
	10%	WB	15.7	15.9	16.5	17.4	17.6	16.2	15.9	16.1	16.2	16.5	16.4	16.0
		MCDB	17.4	18.0	19.2	20.1	20.1	17.6	17.5	17.8	18.0	18.4	18.2	17.5
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.5	9.5	8.9	6.9	3.5	4.0	4.5	4.9	6.0	6.0	6.1
		MCDBR	10.7	10.9	11.2	10.5	9.1	5.6	6.6	6.7	7.2	7.6	7.6	8.4
		MCWBR	7.3	7.8	7.4	6.8	6.0	3.6	3.8	4.1	4.7	5.0	5.2	5.9
	5% WB	MCDBR	7.7	8.2	9.2	8.9	7.9	4.8	5.4	6.0	6.5	7.0	6.5	6.3
		MCWBR	5.6	6.1	6.5	6.1	5.4	3.3	3.5	3.9	4.4	4.8	4.5	4.6
Clear-Sky Solar Irradiance	taub	0.323	0.330	0.351	0.364	0.376	0.361	0.371	0.361	0.346	0.352	0.346	0.333	
	taud	2.530	2.489	2.429	2.437	2.430	2.496	2.444	2.472	2.520	2.485	2.504	2.522	
	Ebn at Noon	994	993	968	940	910	913	907	930	958	958	963	978	
	Edh at Noon	105	113	121	118	116	107	113	113	109	112	107	105	
All-Sky Solar Radiation	RadAvg	4.77	5.50	5.95	5.69	5.31	5.16	5.18	5.26	5.34	5.04	4.38	4.22	
	RadStd	0.41	0.35	0.35	0.29	0.37	0.28	0.23	0.24	0.34	0.28	0.33	0.43	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (11 neighbors)	+0.17	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page