

GALLE, Sri Lanka

WMO: 434950

Lat: 6.0296N

Lon: 80.2143E

Elev: 43

StdP: 14.67

Time Zone: 5.50 (IND)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	74.2	75.0	68.2	103.7	79.6	69.7	109.5	78.7	13.4	83.0	11.1	82.4	3.3	50	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	5.2	89.7	79.9	88.6	80.0	87.6	80.0	82.1	86.7	81.7	86.2	81.2	85.6	5.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	160.5	85.5	80.3	157.5	85.0	79.9	155.6	84.7	46.0	87.4	45.4	86.4	45.0	85.9	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	17.0	14.4	70.3	92.3	2.0	1.2	68.8	93.2	67.7	93.9	66.6	94.6	65.2	95.5
			67.3	83.1	2.5	1.0	65.5	83.8	64.0	84.4	62.6	84.9	60.8	85.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.7	80.2	80.9	82.7	83.3	83.1	82.4	81.7	81.4	81.5	81.4	80.9	80.5
	DBStd	1.80	1.54	1.39	1.47	1.74	1.59	1.50	1.59	1.52	1.49	1.56	1.35	1.53
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11556	937	865	1014	998	1027	971	982	973	945	972	927	945
	CDD65	6081	472	445	549	548	562	521	517	508	495	507	477	480
	CDH74	66645	4612	4607	6383	6680	6885	6058	5690	5520	5391	5435	4751	4633
	CDH80	19144	1041	1210	2280	2607	2518	1825	1412	1265	1295	1423	1181	1087
(14) Wind	WSAvg	5.6	3.2	3.1	3.2	4.2	6.8	8.9	8.8	7.4	7.8	5.7	4.2	3.7
(15) Precipitation	PrecAvg	95.7	3.1	3.1	4.1	8.3	11.7	6.6	7.6	7.1	10.5	13.9	12.4	7.3
	PrecMax	152.1	6.6	10.5	8.8	16.1	23.2	14.3	18.4	15.4	24.0	25.1	29.5	21.8
	PrecMin	74.1	0.0	0.2	0.9	2.9	1.9	3.4	2.0	1.5	2.0	1.8	4.8	1.1
	PrecStd	16.2	1.6	2.4	2.2	3.7	5.3	2.8	5.0	3.5	5.9	6.0	6.1	4.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.6	89.7	91.4	91.8	88.9	87.0	86.4	85.8	86.0	87.3	88.8	88.9
		MCWB	78.0	77.9	79.4	82.7	81.9	80.7	80.1	79.8	79.9	79.9	79.4	78.8
	2%	DB	86.4	87.4	89.8	89.5	87.5	86.0	85.4	85.0	85.2	86.1	87.0	86.9
		MCWB	78.0	78.5	79.2	81.3	81.3	80.7	79.8	79.6	79.6	79.5	79.3	78.7
	5%	DB	85.2	86.1	88.5	88.3	86.7	85.3	84.7	84.4	84.5	85.3	85.8	85.5
		MCWB	77.7	78.3	79.3	80.8	81.0	80.4	79.6	79.4	79.3	79.2	79.1	78.5
	10%	DB	84.2	85.0	87.3	87.3	86.0	84.6	84.1	83.7	83.9	84.5	84.8	84.5
		MCWB	77.5	78.1	79.3	80.5	80.7	80.2	79.4	79.1	79.0	78.9	78.7	78.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.3	80.8	81.9	83.4	82.8	81.9	81.0	81.0	81.0	80.9	80.8	80.6
		MCDB	85.5	86.1	88.9	89.9	86.8	85.1	84.6	84.3	84.4	85.3	86.6	86.1
	2%	WB	79.3	79.9	81.0	82.1	82.2	81.5	80.5	80.3	80.3	80.1	80.0	79.8
		MCDB	84.5	85.3	87.4	87.6	86.1	84.6	83.9	83.7	83.9	84.5	85.2	85.1
	5%	WB	78.8	79.2	80.5	81.6	81.7	80.9	80.1	80.0	79.9	79.8	79.5	79.2
		MCDB	83.9	84.5	86.7	87.1	85.7	84.2	83.5	83.4	83.5	84.2	84.6	84.3
	10%	WB	78.2	78.8	79.9	81.1	81.2	80.6	79.8	79.6	79.4	79.3	79.0	78.7
		MCDB	83.1	84.0	85.9	86.4	85.2	84.0	83.2	83.0	83.0	83.6	83.9	83.7
(35) Mean Daily Temperature Range	5% DB	MDBR	8.9	9.0	10.0	8.3	5.2	4.2	4.1	4.2	4.5	6.1	8.5	8.6
		MCDBR	9.9	10.2	11.8	9.4	6.2	4.4	4.4	4.5	4.9	7.0	9.8	10.0
	5% WB	MCWBR	4.8	5.1	5.6	4.7	3.7	2.8	2.6	2.5	2.8	3.8	4.9	5.0
		MCWBR	8.8	9.1	10.2	8.7	5.6	4.2	4.3	4.3	4.8	6.7	9.1	9.2
(40) Clear-Sky Solar Irradiance	taub	taub	0.441	0.458	0.487	0.476	0.499	0.490	0.509	0.485	0.455	0.456	0.465	0.453
		taud	2.372	2.309	2.246	2.308	2.228	2.258	2.174	2.264	2.368	2.367	2.326	2.350
	Edn at Noon	Edn at Noon	279	276	268	266	254	253	250	260	272	273	269	272
		Edh at Noon	40	43	46	43	45	43	47	44	40	40	41	40
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1704	1887	1969	1852	1684	1672	1702	1732	1753	1690	1492	1528
	RadStd	RadStd	109	112	108	103	134	109	76	91	128	107	111	134

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page