

HAMBANTOTA, Sri LankaWMO: **434970**Lat: **6.1225N**Lon: **81.1287E**Elev: **66**StdP: **14.66**Time Zone: **5.50 (IND)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	70.1	71.9	60.8	79.7	84.0	62.9	86.0	85.3	22.5	83.1	20.0	82.9	4.3	0	0.400

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	94.9	76.4	93.4	76.8	91.9	77.1	82.8	88.0	82.0	87.2	81.4	86.6	16.9	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	161.6	85.5	80.7	159.9	85.2	80.2	157.2	84.8	46.9	88.8	46.0	87.6	45.3	86.6	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 23.2	21.0	19.1	65.4	97.3	2.0	2.2	64.0	98.9	62.8	100.2	61.7	101.4	60.3	103.0		
(5)			63.6	83.5	2.9	1.6	61.6	84.6	59.9	85.5	58.3	86.4	56.2	87.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.3	80.3	81.1	82.5	83.5	83.4	83.7	84.0	83.4	82.4	82.0	80.9	80.0	
	DBStd	2.32	1.85	2.07	1.63	1.51	1.88	2.22	2.22	2.10	2.10	1.96	1.41	1.71	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD50	11780	940	872	1009	1004	1035	1010	1054	1034	972	993	927	930	
	CDD65	6305	475	452	544	554	570	560	589	569	522	528	477	465	
	CDH74	66147	4344	4464	5983	6403	6508	6350	6739	6290	5443	5265	4375	3983	
	CDH80	23659	1476	1637	2429	2590	2360	2340	2654	2297	1746	1722	1285	1123	
Wind	WSAvg	8.4	7.5	7.7	6.4	5.3	8.8	11.8	12.1	11.7	10.3	7.4	5.2	6.2	
Precipitation	PrecAvg	43.4	2.7	1.9	2.1	3.5	3.3	2.2	1.4	2.0	3.0	5.1	8.5	5.2	
	PrecMax	71.9	9.7	7.0	9.3	10.7	12.6	9.1	7.6	7.3	11.4	14.2	21.9	19.1	
	PrecMin	22.8	0.0	0.0	0.0	0.6	0.1	0.0	0.0	0.0	0.0	0.0	1.2	0.7	
	PrecStd	9.9	2.4	2.0	2.0	2.2	2.5	2.0	1.4	1.8	2.4	3.4	4.1	3.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.5	93.1	95.0	94.6	94.6	95.0	95.4	95.3	95.2	94.9	90.8	89.9	
		MCWB	75.8	77.0	76.4	77.6	79.0	78.3	76.7	76.1	74.4	72.7	77.2	76.4	
	2%	DB	89.8	91.3	93.0	91.9	91.7	93.2	94.6	93.4	93.0	91.5	89.2	88.1	
		MCWB	75.2	76.6	76.5	78.4	78.8	78.1	76.7	75.9	75.7	76.1	77.8	77.2	
	5%	DB	88.2	89.7	91.1	91.1	89.9	91.5	92.9	91.5	89.9	89.3	87.6	87.1	
		MCWB	75.7	76.7	77.1	78.8	79.2	78.1	76.9	76.4	76.6	76.9	78.2	77.4	
	10%	DB	87.4	88.0	89.3	89.4	88.0	89.6	90.7	89.5	87.6	87.2	86.1	85.9	
		MCWB	75.9	76.7	78.2	79.3	79.7	78.4	77.1	76.8	77.7	78.3	78.2	77.5	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.2	81.5	82.3	83.7	84.2	83.5	82.5	82.1	81.8	81.9	81.9	81.7
			MCDB	86.9	86.8	89.2	88.9	89.5	90.1	88.8	86.4	86.4	86.1	85.4	85.3
2%		WB	79.2	80.2	81.1	82.5	82.7	81.9	80.8	80.6	80.7	80.7	80.8	80.5	
		MCDB	85.6	86.9	87.7	88.3	87.6	87.7	87.3	85.6	85.5	85.7	85.6	84.8	
5%		WB	78.5	79.4	80.3	81.6	81.7	80.9	79.7	79.7	79.9	80.0	79.8	79.4	
		MCDB	84.7	86.1	86.8	87.4	86.4	85.8	85.9	85.0	84.7	85.0	84.8	84.1	
10%		WB	77.6	78.6	79.6	80.9	80.9	80.0	78.9	79.0	79.1	79.2	79.0	78.5	
		MCDB	83.7	85.1	86.0	86.5	85.4	84.7	84.8	84.5	83.8	84.3	84.0	83.3	
Mean Daily Temperature Range	5% DB	MDBR	14.8	15.2	15.0	12.9	10.2	11.0	12.5	11.7	10.9	11.6	11.6	12.0	
		MCDBR	16.9	17.5	18.5	16.0	13.8	14.7	16.5	16.0	16.1	15.2	13.7	14.4	
		MCWBR	7.3	7.0	7.0	7.1	6.2	4.9	4.7	4.7	5.5	5.8	6.3	7.0	
	5% WB	MCDBR	13.9	14.3	14.1	12.7	10.5	11.3	12.5	10.9	10.5	11.4	11.9	12.8	
		MCWBR	6.9	7.1	6.7	6.5	5.7	5.0	4.8	4.8	5.1	5.8	6.5	7.0	
Clear-Sky Solar Irradiance	taub		0.431	0.442	0.466	0.464	0.493	0.481	0.499	0.480	0.453	0.454	0.455	0.442	
	taud		2.397	2.350	2.294	2.334	2.241	2.283	2.201	2.277	2.367	2.363	2.350	2.382	
	Ebn at Noon		282	281	274	270	256	256	252	262	273	274	272	276	
	Edh at Noon		38	41	44	42	44	42	46	43	40	40	40	39	
All-Sky Solar Radiation	RadAvg		1616	1809	1936	1850	1750	1734	1761	1782	1790	1698	1455	1450	
	RadStd		121	127	115	101	128	96	74	83	115	104	115	148	