

MALE, Maldives

WMO: 435550

Lat: 4.1927N

Lon: 73.5281E

Elev: 2

StdP: 101.30

Time Zone: 5.00 (E05)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	24.8	25.1	20.9	15.6	27.9	21.8	16.4	28.1	11.6	27.3	10.4	27.5	5.6	270	0.525

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	3.7	32.2	27.1	32.1	27.1	31.8	27.0	28.2	30.6	27.9	30.4	27.6	30.3	4.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	30.3	27.1	22.9	30.2	26.9	22.6	30.1	90.5	31.5	89.3	30.9	88.1	30.4	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.6	9.5	8.6	DB	23.0	33.1	1.2	0.8	22.2	33.7	21.5	34.1	20.8	34.5	20.0	35.1	(4)
(5)			WB	21.7	29.0	0.9	0.3	21.1	29.2	20.6	29.4	20.1	29.6	19.4	29.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.8	28.5	28.8	29.5	29.7	29.4	29.2	28.8	28.7	28.5	28.5	28.2	28.3	(6)	
	DBStd	1.03	0.68	0.68	0.75	0.90	1.09	0.94	0.99	1.08	1.01	0.99	0.94	0.84	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6875	573	527	603	592	601	576	582	579	554	572	547	568	(10)	
	CDD18.3	3833	315	293	344	342	343	326	324	321	304	314	297	310	(11)	
	CDH23.3	47761	3696	3575	4477	4559	4508	4216	4089	3982	3716	3791	3515	3637	(12)	
	CDH26.7	19009	1251	1353	2007	2169	2051	1836	1644	1552	1370	1371	1188	1217	(13)	
(14) Wind	WSAvg	4.6	5.5	4.8	3.5	3.4	5.4	5.1	4.7	4.6	4.7	4.8	3.7	4.7	(14)	
(15) Precipitation	PrecAvg	1768	82	35	44	116	184	139	170	177	200	212	200	191	(15)	
	PrecMax	2318	276	173	170	317	492	261	362	415	402	425	559	407	(16)	
	PrecMin	1151	1	0	5	18	79	39	48	52	39	21	26	48	(17)	
	PrecStd	283	76	40	41	72	96	69	77	89	97	99	125	107	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.2	32.0	32.2	33.0	32.8	32.2	32.1	32.1	31.9	31.9	31.3	31.2	(19)	
		MCWB	26.3	26.7	26.8	27.7	27.8	27.3	26.9	26.8	27.0	26.6	26.6	26.5	(20)	
	2%	DB	31.0	31.2	32.1	32.2	32.1	31.8	31.2	31.2	31.1	31.1	31.0	31.0	(21)	
		MCWB	26.1	26.4	26.7	27.2	27.4	27.1	26.8	26.7	26.7	26.5	26.6	26.4	(22)	
	5%	DB	30.4	31.0	31.8	32.0	31.8	31.2	31.0	31.0	30.9	30.9	30.5	30.3	(23)	
		MCWB	25.8	26.3	26.6	27.1	27.3	27.0	26.8	26.7	26.6	26.4	26.3	26.0	(24)	
	10%	DB	30.1	30.7	31.1	31.6	31.1	30.9	30.6	30.5	30.2	30.2	30.1	30.1	(25)	
		MCWB	25.7	26.1	26.5	27.0	27.1	27.0	26.6	26.4	26.2	26.2	26.0	25.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.5	28.0	28.2	28.5	28.5	28.2	28.2	28.0	27.9	27.6	27.5	27.5	(27)	
		MCDB	29.8	30.3	30.9	31.3	30.9	30.4	30.3	30.1	30.2	30.0	30.0	29.7	(28)	
	2%	WB	27.0	27.2	27.7	28.1	28.1	27.7	27.5	27.4	27.2	27.1	27.0	27.0	(29)	
		MCDB	29.6	30.1	30.7	31.0	30.6	30.1	30.0	29.9	29.8	29.7	29.7	29.5	(30)	
	5%	WB	26.6	26.8	27.2	27.7	27.8	27.5	27.1	27.0	26.9	26.7	26.7	26.7	(31)	
		MCDB	29.3	29.8	30.5	30.7	30.4	30.0	29.8	29.8	29.6	29.4	29.4	29.2	(32)	
	10%	WB	26.3	26.5	26.8	27.4	27.5	27.2	26.7	26.7	26.6	26.6	26.5	26.4	(33)	
		MCDB	29.1	29.6	30.2	30.5	30.2	29.9	29.6	29.6	29.3	29.2	29.1	29.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	3.6	3.8	3.8	3.7	3.6	3.5	3.6	3.6	3.6	3.7	3.7	3.7	(35)	
		MCDBR	3.8	4.0	4.0	3.9	3.7	3.6	3.7	3.7	3.8	3.9	4.0	3.9	(36)	
	5% WB	MCWBR	2.1	2.2	2.0	2.0	2.1	2.0	2.1	2.0	2.1	2.1	2.1	2.2	(37)	
		MCWBR	3.6	3.9	3.8	3.8	3.6	3.5	3.6	3.6	3.7	3.7	3.9	3.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.448	0.444	0.459	0.445	0.447	0.463	0.472	0.442	0.429	0.421	0.417	0.444	(40)	
		taud	2.371	2.362	2.340	2.417	2.436	2.370	2.315	2.433	2.469	2.498	2.499	2.406	(41)	
	Ebn at Noon		875	886	870	866	844	818	815	856	883	897	899	872	(42)	
		Edh at Noon	126	129	133	120	115	120	128	117	115	111	110	120	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.90	6.43	6.66	6.17	5.39	5.23	5.19	5.45	5.54	5.71	5.04	5.13	(44)	
	RadStd		0.25	0.26	0.31	0.32	0.33	0.38	0.32	0.33	0.49	0.40	0.51	0.50	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.31	+0.20	N/A	+0.32	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page