

DURVULJIN, MongoliaWMO: **442190**Lat: **47.6464N**Lon: **94.9989E**Elev: **7156**StdP: **11.27**Time Zone: **7.00 (E07)**Period: **02-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-36.2	-32.0	-41.1	0.7	-35.7	-37.2	0.9	-31.6	18.8	3.2	17.5	3.7	3.0	110	0.606

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	87.7	58.9	84.6	57.8	81.8	56.8	62.4	80.8	60.5	78.5	59.0	76.3	8.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	89.5	67.1	54.1	81.6	68.5	51.9	75.0	67.7	31.9	81.2	30.4	79.1	29.1	76.6	74.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.2	18.1	15.8	-35.9	94.0	7.7	3.0	-41.5	96.2	-46.0	97.9	-50.3	99.6	-55.9	101.8		
(5)			-36.1	65.3	7.7	3.6	-41.6	67.9	-46.1	70.0	-50.4	72.1	-56.0	74.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	34.5	-11.6	-2.9	23.1	42.5	53.4	65.8	70.1	66.1	53.6	37.7	16.6	-2.6	
	DBStd	29.66	11.86	14.61	13.43	9.71	8.46	6.49	5.52	6.15	8.03	8.59	10.96	10.57	
	HDD50	7623	1911	1482	834	256	64	1	0	0	55	387	1001	1632	
	HDD65	11506	2376	1902	1299	676	366	65	17	62	348	847	1451	2097	
	CDD50	1968	0	0	0	30	171	476	623	499	164	5	0	0	
	CDD65	375	0	0	0	0	8	90	175	96	6	0	0	0	
	CDH74	3625	0	0	0	3	123	909	1588	916	86	0	0	0	
	CDH80	998	0	0	0	0	14	233	492	248	11	0	0	0	
Wind	WSAvg	5.7	3.5	4.4	6.1	6.7	7.5	6.8	6.5	6.2	5.9	5.6	5.3	4.2	
Precipitation	PrecAvg	7.3	0.2	0.2	0.2	0.4	0.6	1.1	1.8	1.2	0.6	0.4	0.4	0.3	
	PrecMax	11.6	0.4	0.3	0.6	0.9	1.0	2.2	4.8	2.6	1.4	0.9	0.9	0.6	
	PrecMin	4.2	0.0	0.1	0.0	0.1	0.2	0.4	0.4	0.3	0.2	0.1	0.2	0.1	
	PrecStd	1.8	0.1	0.0	0.1	0.2	0.2	0.4	0.9	0.6	0.3	0.2	0.2	0.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.1	36.1	58.6	72.0	82.4	89.5	93.1	90.7	81.0	64.4	47.1	28.8	
		MCWB	17.1	27.0	40.3	48.2	51.9	60.8	61.7	58.9	54.2	44.7	34.4	22.0	
	2%	DB	15.3	29.3	52.1	67.2	77.3	85.8	88.5	86.0	76.1	59.9	41.6	21.8	
		MCWB	11.6	22.0	37.1	46.2	52.5	57.5	59.8	57.9	53.0	43.2	31.6	17.1	
	5%	DB	10.8	23.7	47.5	63.1	73.7	82.6	85.3	82.6	71.9	56.1	36.9	17.5	
		MCWB	7.9	18.5	34.5	44.4	50.3	56.4	59.0	56.9	50.8	40.5	28.4	13.7	
	10%	DB	6.3	18.2	43.1	59.0	69.6	79.4	82.1	79.2	68.2	52.0	32.4	13.0	
		MCWB	4.2	14.1	31.7	41.6	48.2	55.3	57.9	56.3	49.3	38.2	25.6	10.3	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.1	27.2	40.5	50.3	56.0	63.0	65.3	63.7	58.4	46.6	35.2	22.6
			MCDB	21.9	35.8	56.7	69.3	77.6	86.3	83.3	80.9	76.6	61.8	46.1	29.1
2%		WB	11.5	22.2	37.4	47.4	53.3	60.0	63.2	61.3	55.1	43.8	32.0	17.1	
		MCDB	15.1	28.7	50.8	65.5	74.2	79.8	81.4	77.4	70.4	58.4	41.3	21.4	
5%		WB	7.9	18.5	34.8	45.0	51.0	58.3	61.4	59.3	52.7	41.2	29.2	14.0	
		MCDB	10.7	23.8	47.0	61.6	71.4	76.9	79.8	76.2	67.9	54.9	37.0	17.3	
10%		WB	4.2	14.2	32.1	42.6	49.0	57.0	59.8	57.6	50.5	38.5	26.2	10.4	
		MCDB	6.3	18.3	42.6	57.7	68.1	74.9	77.4	75.7	66.7	51.4	32.8	13.0	
Mean Daily Temperature Range		5% DB	MDBR	18.6	22.6	24.9	23.8	23.2	21.3	20.0	21.2	23.0	23.1	19.0	16.9
			MCDBR	22.5	25.9	26.9	27.9	27.8	24.9	23.8	25.1	26.5	26.8	22.5	18.5
	MCWBR		19.5	20.6	16.8	16.0	14.4	10.8	9.7	10.2	12.7	15.5	14.7	15.0	
	5% WB	MCDDBR	22.3	26.0	26.1	26.5	26.0	22.3	20.5	21.1	23.8	26.2	21.8	18.4	
		MCWBR	19.3	20.7	16.8	16.2	14.6	10.5	9.6	10.0	12.2	15.7	14.8	15.0	
Clear-Sky Solar Irradiance	taub	0.211	0.233	0.268	0.300	0.302	0.312	0.313	0.296	0.266	0.248	0.227	0.214		
	taud	2.412	2.374	2.337	2.321	2.348	2.396	2.423	2.451	2.494	2.478	2.437	2.390		
	Ebn at Noon	292	304	305	303	305	301	299	301	303	294	280	275		
	Edh at Noon	20	27	33	37	38	36	35	32	28	24	20	18		
All-Sky Solar Radiation	RadAvg	464	813	1399	1891	2240	2282	2178	1909	1577	1064	590	382		
	RadStd	64	86	92	74	117	83	100	71	48	43	76	45		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	-3.76	N/A	-2.21	-2.72	N/A	N/A	N/A	N/A

Nomenclature: See separate page