

YERUU, Mongolia

WMO: 442430

Lat: 49.7492N

Lon: 106.6611E

Elev: 7156

StdP: 11.27

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-40.2	-36.2	-45.8	0.5	-39.3	-41.8	0.6	-35.8	16.2	10.9	11.8	5.0	0.6	70	0.605

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	89.6	63.1	85.8	62.2	82.2	61.3	68.2	81.0	66.0	77.7	64.4	75.6	6.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.7	120.1	73.6	62.8	112.0	71.4	60.8	104.5	70.2	37.2	81.1	35.2	77.9	33.7	75.3	77.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
19.5	16.1	13.3	DB	-44.4	96.9	5.3	4.1	-48.2	99.9	-51.4	102.3	-54.3	104.7	-58.2	107.7	
			WB	-44.0	71.0	5.5	3.2	-47.9	73.3	-51.2	75.2	-54.3	77.0	-58.3	79.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	30.0	-18.0	-9.2	17.1	38.3	50.5	63.2	68.5	63.7	51.0	33.6	9.4	-11.1	(6)
(7)		DBStd	31.46	9.16	11.84	14.43	8.42	8.24	7.15	5.48	6.14	7.95	8.89	12.70	10.77	(7)
(8)		HDD50	8948	2108	1658	1019	359	96	2	0	1	83	510	1217	1895	(8)
(9)		HDD65	13052	2573	2078	1484	801	452	116	24	100	423	974	1667	2360	(9)
(10)		CDD50	1632	0	0	0	9	112	399	574	425	112	1	0	0	(10)
(11)		CDD65	260	0	0	0	0	4	63	133	58	2	0	0	0	(11)
(12)		CDH74	3621	0	0	0	10	234	1025	1508	741	103	0	0	0	(12)
(13)		CDH80	1249	0	0	0	1	66	369	557	238	18	0	0	0	(13)
(14)	Wind	WSAvg	3.6	1.1	1.6	3.8	5.6	6.3	5.1	4.1	3.9	4.1	3.7	2.1	1.4	(14)
(15)	Precipitation	PrecAvg	11.7	0.1	0.1	0.1	0.2	0.6	2.2	3.4	3.1	1.2	0.4	0.2	0.1	(15)
(16)		PrecMax	18.1	0.4	0.5	0.6	1.1	1.8	7.0	5.8	8.1	3.0	2.0	0.6	0.4	(16)
(17)		PrecMin	6.4	0.0	0.0	0.0	0.0	0.1	0.2	1.2	1.5	0.2	0.0	0.0	0.0	(17)
(18)		PrecStd	3.3	0.1	0.1	0.2	0.3	0.4	1.6	1.5	1.6	0.7	0.4	0.2	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	29.0	57.1	74.2	87.6	94.5	94.9	92.2	82.9	67.1	46.8	22.0	(19)
(20)		0.4%	MCWB	13.0	23.7	40.1	49.6	56.9	61.9	67.4	66.0	60.1	48.7	35.9	19.2	(20)
(21)		2%	DB	7.3	21.3	49.6	66.7	80.7	88.1	90.0	86.0	76.7	59.7	38.3	14.9	(21)
(22)		2%	MCWB	5.6	18.1	37.2	45.5	54.0	60.7	65.0	63.9	57.6	43.8	31.5	12.8	(22)
(23)		5%	DB	2.0	15.3	43.8	61.0	75.3	84.1	86.2	81.8	72.0	54.1	33.6	10.0	(23)
(24)		5%	MCWB	0.7	12.9	33.9	43.2	51.7	60.0	64.0	63.2	55.5	41.7	28.2	8.5	(24)
(25)		10%	DB	-2.6	10.1	38.0	55.9	69.8	79.9	82.3	77.5	66.9	49.1	29.1	5.3	(25)
(26)		10%	MCWB	-3.6	8.4	30.4	41.2	49.3	58.9	63.2	62.0	53.4	39.2	25.2	4.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.0	23.5	41.5	51.3	59.3	67.2	72.6	69.7	63.6	48.8	37.0	19.4	(27)
(28)		0.4%	MCDWB	15.5	28.5	55.1	67.5	81.5	84.9	89.4	83.1	77.7	65.6	44.9	21.6	(28)
(29)		2%	WB	5.5	18.3	37.7	47.0	55.5	64.6	69.4	67.1	59.8	45.0	32.1	13.1	(29)
(30)		2%	MCDWB	7.2	21.2	48.5	63.1	77.5	80.2	82.0	79.1	71.7	57.3	37.4	14.9	(30)
(31)		5%	WB	0.8	13.0	34.0	44.1	53.0	62.7	67.1	65.1	57.1	42.1	28.6	8.6	(31)
(32)		5%	MCDWB	2.0	15.3	42.9	59.9	71.7	77.4	78.6	76.3	68.4	52.5	33.4	10.2	(32)
(33)		10%	WB	-3.5	8.4	30.6	41.4	50.6	60.8	65.3	63.4	54.4	39.5	25.2	4.2	(33)
(34)		10%	MCDWB	-2.7	10.1	37.9	55.2	67.3	74.6	75.9	73.6	65.5	48.2	29.2	5.4	(34)
(35)	Mean Daily Temperature Range		MDBR	20.8	26.3	27.7	27.0	28.5	26.3	23.3	23.2	26.6	25.5	22.7	19.7	(35)
(36)		5% DB	MCDBR	25.2	30.1	31.4	38.5	41.0	34.2	31.0	32.1	36.2	36.1	26.7	23.1	(36)
(37)		5% DB	MCWBR	23.8	26.8	19.4	20.2	18.1	12.0	10.8	12.4	17.4	21.1	20.1	21.3	(37)
(38)		5% WB	MCDBR	25.4	30.1	30.2	35.4	36.3	27.1	24.6	25.6	30.9	32.7	26.4	23.1	(38)
(39)		5% WB	MCWBR	23.9	26.9	18.7	19.8	17.6	11.5	10.9	11.6	15.6	19.9	20.3	21.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.205	0.219	0.246	0.279	0.309	0.317	0.310	0.293	0.261	0.238	0.220	0.207	(40)	
(41)		taud	2.399	2.399	2.452	2.472	2.402	2.459	2.509	2.551	2.607	2.602	2.490	2.392	(41)	
(42)		Ebn at Noon	286	306	312	309	301	298	299	301	304	296	277	268	(42)	
(43)		Edh at Noon	19	24	28	31	35	34	32	29	24	20	17	16	(43)	
(44)	All-Sky Solar Radiation	RadAvg	537	916	1351	1639	1930	1996	1855	1594	1286	861	535	408	(44)	
(45)		RadStd	15	26	67	87	125	95	118	107	97	40	24	21	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page