

KHUJIRT, Mongolia

WMO: 442850

Lat: 46.8997N

Lon: 102.7789E

Elev: 5453

StdP: 12.02

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-28.7	-24.9	-33.8	1.0	-27.8	-29.9	1.3	-24.1	20.9	6.5	18.1	6.6	1.0	140	0.660

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.8	82.2	60.4	78.3	58.8	75.2	57.6	63.4	77.7	61.3	74.4	59.6	71.3	6.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.1	88.6	69.3	56.5	83.3	67.1	54.8	78.4	65.2	31.8	77.7	30.1	74.6	28.8	71.6	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	20.4	17.8	15.5	DB	-32.4	87.7	5.3	3.6	-36.2	90.3	-39.3	92.4	-42.3	94.4	-46.2	96.9
(5)				WB	-32.5	66.6	5.2	3.2	-36.3	68.8	-39.3	70.7	-42.2	72.5	-46.0	74.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	31.4	-5.2	3.1	19.7	37.0	47.6	57.6	62.1	58.5	47.9	32.9	14.2	0.0	(6)
(7)		DBStd	24.98	10.28	11.13	11.65	9.22	8.44	6.68	5.55	5.72	7.72	8.87	11.80	9.69	(7)
(8)		HDD50	7804	1710	1313	940	395	145	13	1	6	126	532	1073	1550	(8)
(9)		HDD65	12310	2175	1733	1405	839	540	234	123	214	512	997	1523	2015	(9)
(10)		CDD50	1030	0	0	0	6	71	242	377	269	64	1	0	0	(10)
(11)		CDD65	60	0	0	0	0	1	13	34	12	0	0	0	0	(11)
(12)		CDH74	960	0	0	0	0	42	261	438	200	19	0	0	0	(12)
(13)		CDH80	205	0	0	0	0	3	52	111	37	2	0	0	0	(13)
(14)	Wind	WSAvg	4.1	2.2	3.0	4.7	6.2	6.3	5.0	4.0	3.8	4.3	4.0	3.3	2.3	(14)
(15)	Precipitation	PrecAvg	10.6	0.1	0.1	0.2	0.3	0.9	2.2	3.5	2.2	0.8	0.3	0.2	0.1	(15)
(16)		PrecMax	20.0	0.3	0.2	0.7	0.9	2.5	7.1	6.5	4.6	2.2	0.9	0.7	0.3	(16)
(17)		PrecMin	6.3	0.0	0.0	0.0	0.0	0.2	0.6	1.9	0.2	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	3.0	0.1	0.0	0.2	0.2	0.6	1.3	1.3	1.2	0.6	0.2	0.1	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.2	37.9	55.7	69.4	79.4	85.2	88.7	84.5	76.5	63.7	48.6	30.5	(19)
MCWB			22.4	28.9	39.4	49.4	55.6	60.6	65.2	61.5	55.9	46.6	36.3	25.1	(20)	
2%		DB	20.7	31.4	48.7	63.2	73.8	80.5	83.0	79.3	71.8	58.4	42.3	23.7	(21)	
		MCWB	16.7	24.9	35.9	45.4	52.2	58.3	62.0	59.7	53.8	43.4	33.0	19.5	(22)	
5%		DB	15.7	26.4	43.3	58.9	70.0	76.6	78.7	75.2	67.9	53.9	37.1	19.2	(23)	
		MCWB	12.7	21.6	33.0	43.3	50.1	57.0	60.5	58.4	51.8	40.7	29.5	16.0	(24)	
10%		DB	10.8	21.3	38.4	54.5	65.7	72.9	75.1	71.7	63.6	49.4	32.1	15.2	(25)	
		MCWB	8.6	17.6	30.0	40.9	48.1	55.2	59.4	57.2	49.7	38.2	26.2	12.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	29.6	41.2	51.1	58.1	62.9	67.7	64.2	58.6	48.0	37.1	25.2	(27)
MCD B			28.4	36.5	53.5	67.4	76.0	80.6	84.7	80.0	72.8	61.9	47.2	30.2	(28)	
2%		WB	16.9	25.2	36.4	46.7	54.4	60.7	64.6	61.8	55.4	44.5	33.5	19.7	(29)	
		MCD B	20.5	30.9	47.8	61.1	70.7	76.8	78.8	75.4	68.9	57.2	42.1	23.5	(30)	
5%		WB	12.8	21.6	33.2	43.8	51.4	58.8	62.5	59.9	52.9	41.3	29.8	16.1	(31)	
		MCD B	15.7	26.5	42.7	57.2	66.6	73.4	75.7	71.4	65.2	52.8	36.8	19.1	(32)	
10%		WB	8.7	17.7	30.2	41.2	48.8	56.8	60.6	58.2	50.6	38.4	26.3	12.7	(33)	
		MCD B	10.8	21.2	38.3	54.1	63.5	69.3	72.1	68.4	61.8	48.6	31.7	15.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	22.3	26.7	25.6	23.6	24.1	22.7	20.8	21.9	24.9	25.6	23.7	20.7	(35)
MCDBR			27.3	31.4	29.7	31.3	31.9	29.9	28.3	29.5	31.4	32.9	29.1	24.2	(36)	
MCWBR			23.8	25.8	19.6	17.9	16.9	14.4	12.5	14.1	17.0	20.4	20.7	21.0	(37)	
5% WB		MCDBR	26.9	31.0	28.9	29.1	29.6	25.7	24.7	24.2	28.1	31.6	28.8	23.9	(38)	
		MCWBR	23.5	25.6	19.5	18.0	17.5	13.6	12.6	12.7	16.0	20.3	21.0	21.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.232	0.258	0.303	0.345	0.361	0.371	0.361	0.338	0.302	0.278	0.251	0.235	(40)	
(41)		taud	2.388	2.341	2.271	2.228	2.236	2.306	2.386	2.425	2.468	2.458	2.418	2.373	(41)	
(42)		Ebn at Noon	282	294	292	288	286	283	285	288	291	283	271	266	(42)	
(43)		Edh at Noon	21	28	36	41	43	40	36	34	29	25	21	19	(43)	
(44)	All-Sky Solar Radiation	RadAvg	626	971	1426	1837	2105	2094	1978	1785	1531	1058	667	502	(44)	
(45)		RadStd	36	41	58	71	104	124	104	108	66	43	43	25	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	-3.78	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	N/A	N/A	-4.54	N/A	-1.40	-1.57	N/A	N/A	N/A	N/A	

Nomenclature: See separate page