

KHUJIRT, Mongolia

WMO: 442850

Lat: 46.8997N

Lon: 102.7789E

Elev: 1662

StdP: 82.89

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-33.7	-31.6	-36.5	0.1	-33.2	-34.4	0.2	-31.1	9.4	-14.2	8.1	-14.1	0.5	140	0.660

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	27.9	15.8	25.7	14.9	24.0	14.2	17.4	25.4	16.3	23.6	15.3	21.8	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
14.5	12.7	20.7	13.6	11.9	19.5	12.7	11.2	18.4	56.1	25.4	52.2	23.7	49.1	22.0	23.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	7.9	6.9	-35.8	30.9	3.0	2.0	-37.9	32.4	-39.6	33.5	-41.3	34.6	-43.4	36.1
			-35.8	19.2	2.9	1.8	-37.9	20.5	-39.6	21.5	-41.2	22.5	-43.4	23.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.3	-20.6	-16.0	-6.8	2.8	8.7	14.2	16.7	14.7	8.9	0.5	-9.9	-17.8	(6)
(7)		DBStd	13.88	5.71	6.18	6.47	5.12	4.69	3.71	3.08	3.18	4.29	4.93	6.56	5.38	(7)
(8)		HDD10.0	4336	950	729	522	219	81	7	1	3	70	296	596	861	(8)
(9)		HDD18.3	6839	1208	963	781	466	300	130	68	119	284	554	846	1119	(9)
(10)		CDD10.0	572	0	0	0	3	39	134	209	149	36	1	0	0	(10)
(11)		CDD18.3	33	0	0	0	0	1	7	19	7	0	0	0	0	(11)
(12)		CDH23.3	533	0	0	0	0	23	145	243	111	11	0	0	0	(12)
(13)		CDH26.7	114	0	0	0	0	2	29	62	21	1	0	0	0	(13)
(14)	Wind	WSAvg	1.8	1.0	1.3	2.1	2.8	2.8	2.2	1.8	1.7	1.9	1.8	1.5	1.0	(14)
(15)	Precipitation	PrecAvg	270	2	2	5	8	22	55	88	57	20	8	4	2	(15)
(16)		PrecMax	509	7	6	18	22	64	181	166	117	56	22	17	7	(16)
(17)		PrecMin	159	0	0	1	1	5	14	48	5	2	1	0	0	(17)
(18)		PrecStd	76	2	1	4	6	14	34	34	30	15	5	3	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-2.1	3.3	13.2	20.8	26.4	29.6	31.5	29.2	24.7	17.6	9.2	-0.8	(19)
(20)			MCWB	-5.3	-1.7	4.1	9.7	13.1	15.9	18.4	16.4	13.3	8.1	2.4	-3.8	(20)
(21)		2%	DB	-6.3	-0.3	9.3	17.3	23.2	27.0	28.3	26.3	22.1	14.7	5.7	-4.6	(21)
(22)			MCWB	-8.5	-3.9	2.2	7.4	11.2	14.6	16.7	15.4	12.1	6.3	0.6	-7.0	(22)
(23)		5%	DB	-9.1	-3.1	6.3	14.9	21.1	24.8	26.0	24.0	19.9	12.2	2.8	-7.1	(23)
(24)			MCWB	-10.7	-5.8	0.6	6.3	10.1	13.9	15.9	14.7	11.0	4.8	-1.4	-8.9	(24)
(25)		10%	DB	-11.8	-6.0	3.5	12.5	18.7	22.7	23.9	22.0	17.6	9.7	0.0	-9.3	(25)
(26)			MCWB	-13.0	-8.0	-1.1	4.9	9.0	12.9	15.2	14.0	9.9	3.4	-3.2	-10.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-5.5	-1.3	5.1	10.6	14.5	17.2	19.8	17.9	14.8	8.9	2.8	-3.8	(27)
(28)			MCD B	-2.0	2.5	11.9	19.7	24.5	27.0	29.3	26.7	22.6	16.6	8.4	-1.0	(28)
(29)		2%	WB	-8.4	-3.8	2.5	8.2	12.5	15.9	18.1	16.6	13.0	6.9	0.8	-6.8	(29)
(30)			MCD B	-6.4	-0.6	8.8	16.2	21.5	24.9	26.0	24.1	20.5	14.0	5.6	-4.7	(30)
(31)		5%	WB	-10.7	-5.8	0.6	6.6	10.8	14.9	17.0	15.5	11.6	5.2	-1.2	-8.8	(31)
(32)			MCD B	-9.1	-3.0	5.9	14.0	19.2	23.0	24.3	21.9	18.5	11.6	2.7	-7.1	(32)
(33)		10%	WB	-13.0	-7.9	-1.0	5.1	9.3	13.8	15.9	14.6	10.3	3.6	-3.2	-10.7	(33)
(34)			MCD B	-11.8	-6.0	3.5	12.3	17.5	20.7	22.3	20.2	16.6	9.2	-0.2	-9.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.4	14.8	14.2	13.1	13.4	12.6	11.6	12.2	13.8	14.2	13.2	11.5	(35)
(36)			MCDBR	15.2	17.4	16.5	17.4	17.7	16.6	15.7	16.4	17.5	18.3	16.2	13.4	(36)
(37)			MCWBR	13.2	14.4	10.9	10.0	9.4	8.0	6.9	7.8	9.4	11.3	11.5	11.7	(37)
(38)		5% WB	MCD BR	15.0	17.2	16.1	16.2	16.5	14.3	13.7	13.5	15.6	17.6	16.0	13.3	(38)
(39)			MCWBR	13.1	14.2	10.9	10.0	9.7	7.5	7.0	7.1	8.9	11.3	11.7	11.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.232	0.258	0.303	0.345	0.361	0.371	0.361	0.338	0.302	0.278	0.251	0.235	(40)	
(41)		taud	2.388	2.341	2.271	2.228	2.236	2.306	2.386	2.425	2.468	2.458	2.418	2.373	(41)	
(42)		Ebn at Noon	890	926	921	908	902	892	897	907	916	891	853	839	(42)	
(43)		Edh at Noon	67	89	112	130	134	126	115	106	92	78	65	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.97	3.06	4.50	5.79	6.64	6.60	6.24	5.63	4.83	3.33	2.10	1.58	(44)	
(45)		RadStd	0.11	0.13	0.18	0.22	0.33	0.39	0.33	0.34	0.21	0.14	0.13	0.08	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (5 neighbors)		N/A	N/A	-2.10	N/A	N/A	N/A	N/A	N/A	N/A
		N/A	N/A	-2.52	N/A	-0.78	-0.87	N/A	N/A	N/A

Nomenclature: See separate page