

CHOIR, Mongolia

WMO: 442980

Lat: 46.3500N

Lon: 108.3747E

Elev: 1286

StdP: 86.80

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-29.9	-27.8	-32.7	0.2	-28.5	-30.7	0.3	-26.6	12.0	-18.4	10.2	-19.2	4.5	0	0.659

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	31.5	17.1	29.5	16.3	27.7	15.6	19.2	27.6	17.9	25.9	16.9	24.8	4.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.5	13.7	22.5	15.2	12.6	21.4	14.0	11.7	20.5	60.5	27.5	56.2	26.2	52.7	24.9	27.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	10.2	9.3	-32.3	34.2	2.7	2.2	-34.2	35.8	-35.8	37.1	-37.3	38.4	-39.3	40.0
			-32.4	21.5	2.7	2.7	-34.3	23.4	-35.9	25.0	-37.4	26.5	-39.4	28.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	2.0	-19.5	-14.8	-5.2	4.4	11.5	18.0	21.0	18.7	12.4	2.8	-9.1	-17.4	(6)
(7)		DBStd	15.01	4.68	5.79	6.23	5.35	5.13	4.13	3.42	3.74	4.83	5.23	6.53	4.78	(7)
(8)		HDD10.0	3987	916	696	471	179	43	1	0	0	31	228	573	848	(8)
(9)		HDD18.3	6173	1174	929	729	418	218	56	11	41	185	482	823	1106	(9)
(10)		CDD10.0	1057	0	0	0	11	90	240	341	269	102	4	0	0	(10)
(11)		CDD18.3	203	0	0	0	0	7	45	94	52	6	0	0	0	(11)
(12)		CDH23.3	1986	0	0	0	2	117	480	877	452	58	0	0	0	(12)
(13)		CDH26.7	623	0	0	0	0	26	149	312	129	7	0	0	0	(13)
(14)	Wind	WSAvg	3.7	3.4	3.3	3.9	4.6	4.8	4.1	3.5	3.2	3.6	3.5	3.1	3.1	(14)
(15)	Precipitation	PrecAvg	148	1	1	2	4	10	25	49	31	15	5	3	2	(15)
(16)		PrecMax	288	5	7	16	13	33	52	121	81	79	13	32	6	(16)
(17)		PrecMin	70	0	0	0	0	1	4	6	3	0	0	0	0	(17)
(18)		PrecStd	52	1	2	3	4	10	14	31	21	15	5	6	2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-4.8	2.0	14.5	22.3	29.5	33.1	34.7	32.8	27.6	19.6	8.2	-3.7	(19)
(20)			MCWB	-7.4	-2.2	5.0	10.2	13.6	17.3	19.7	17.6	14.3	9.3	2.3	-5.9	(20)
(21)		2%	DB	-8.1	-1.1	10.0	19.0	26.6	30.3	32.2	29.8	25.1	15.9	5.2	-6.5	(21)
(22)			MCWB	-9.9	-4.4	2.6	8.3	12.7	15.3	17.9	16.7	13.3	7.5	0.5	-8.2	(22)
(23)		5%	DB	-10.6	-3.9	7.1	16.4	24.0	28.2	30.1	27.6	22.6	13.3	2.5	-8.5	(23)
(24)			MCWB	-11.9	-6.2	0.7	6.6	11.3	15.2	17.2	16.2	12.1	5.8	-1.2	-9.9	(24)
(25)		10%	DB	-12.8	-6.3	4.4	13.9	21.3	26.1	28.0	25.7	20.4	10.9	0.1	-10.4	(25)
(26)			MCWB	-13.8	-8.0	-0.9	5.4	10.4	14.4	16.4	15.4	11.1	4.4	-3.0	-11.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-7.1	-1.9	5.4	11.2	15.3	19.6	22.2	20.5	16.2	10.1	2.6	-5.6	(27)
(28)			MDCB	-5.1	1.8	13.8	21.1	26.9	28.7	31.6	28.7	23.9	18.6	7.2	-3.8	(28)
(29)		2%	WB	-9.8	-4.3	2.9	8.8	13.5	17.4	19.7	18.7	14.4	7.9	0.7	-8.1	(29)
(30)			MDCB	-8.3	-1.3	9.7	18.0	24.9	26.5	28.2	26.7	22.6	15.0	4.9	-6.6	(30)
(31)		5%	WB	-11.9	-6.1	1.0	7.1	12.1	16.3	18.4	17.4	13.1	6.2	-1.2	-9.9	(31)
(32)			MDCB	-10.7	-4.0	6.9	15.8	22.5	25.3	26.5	24.8	20.8	12.7	2.2	-8.6	(32)
(33)		10%	WB	-13.8	-8.0	-0.8	5.5	10.7	15.3	17.4	16.3	11.7	4.7	-2.8	-11.5	(33)
(34)			MDCB	-12.8	-6.3	4.1	13.3	20.4	24.0	25.3	23.3	19.3	10.5	0.0	-10.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.7	11.0	12.5	12.8	13.2	11.8	10.8	11.8	11.5	10.0	8.1	(35)	
(36)			MCDBR	10.8	13.2	14.9	16.0	16.1	14.3	13.1	12.9	14.1	13.9	12.1	9.7	(36)
(37)			MCWBR	9.6	10.7	10.0	9.6	8.8	6.5	5.8	6.2	7.3	8.5	8.7	8.5	(37)
(38)		5% WB	MCDBR	10.6	12.8	14.6	15.4	15.2	12.2	11.5	11.2	12.6	13.4	11.8	9.7	(38)
(39)			MCWBR	9.5	10.5	10.0	9.7	9.0	6.5	6.0	6.1	7.1	8.6	8.7	8.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.241	0.265	0.303	0.351	0.390	0.407	0.381	0.363	0.323	0.287	0.256	0.241	(40)	
(41)		taud	2.376	2.328	2.279	2.193	2.119	2.173	2.307	2.332	2.383	2.427	2.406	2.369	(41)	
(42)		Ebn at Noon	880	919	924	902	874	859	878	881	892	882	851	837	(42)	
(43)		Edh at Noon	70	91	112	135	151	144	124	116	101	82	67	63	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.01	3.10	4.67	6.01	6.91	6.85	6.52	5.91	4.92	3.53	2.26	1.65	(44)	
(45)		RadStd	0.18	0.24	0.21	0.25	0.35	0.36	0.30	0.26	0.23	0.15	0.13	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	-1.21	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	-1.92	N/A	-1.00	-0.91	N/A	N/A	N/A	N/A

Nomenclature: See separate page