

AMARBUYANTAYN, Mongolia

WMO: 443290

Lat: 44.617N

Lon: 98.700E

Elev: 6900

StdP: 11.38

Time Zone: 8.00 (E08)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.3	-12.4	-25.7	1.7	-9.6	-22.0	2.1	-7.2	27.9	-0.4	26.6	3.2	5.9	320	0.754

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.2	78.5	56.8	75.8	55.4	73.4	54.1	60.7	72.3	58.5	70.9	56.7	69.2	10.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.7	88.7	65.6	53.9	80.1	64.6	51.1	72.3	62.8	30.4	72.8	28.7	71.3	27.3	69.3	72.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
30.5	26.5	22.7	DB	-21.0	83.4	3.8	2.7	-23.7	85.4	-25.9	87.0	-28.0	88.5	-30.8	90.5	(4)
			WB	-21.2	62.6	3.5	5.0	-23.7	66.1	-25.7	69.0	-27.7	71.8	-30.2	75.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	34.4	4.3	8.5	22.0	37.3	47.4	58.4	63.3	60.7	48.7	34.0	18.7	8.0	(6)
(7)		DBStd	22.29	8.65	9.45	10.33	9.58	8.21	6.35	5.34	5.73	7.44	8.32	8.64	8.45	(7)
(8)		HDD50	6841	1416	1163	869	388	144	9	0	3	110	497	940	1302	(8)
(9)		HDD65	11246	1881	1583	1334	831	545	213	95	155	490	962	1390	1767	(9)
(10)		CDD50	1154	0	0	0	6	65	262	414	335	71	1	0	0	(10)
(11)		CDD65	82	0	0	0	0	1	15	44	22	0	0	0	0	(11)
(12)		CDH74	455	0	0	0	0	3	98	263	91	0	0	0	0	(12)
(13)		CDH80	42	0	0	0	0	0	7	29	6	0	0	0	0	(13)
(14)	Wind	WSAvg	10.5	9.1	10.3	11.5	11.9	12.4	10.0	9.0	9.0	10.1	10.9	11.2	10.2	(14)
(15)	Precipitation	PrecAvg	3.5	0.1	0.0	0.2	0.2	0.2	0.6	1.0	0.7	0.4	0.1	0.1	0.1	(15)
(16)		PrecMax	5.5	0.7	0.2	0.9	0.5	1.1	2.5	2.8	1.8	1.4	0.5	0.3	0.3	(16)
(17)		PrecMin	1.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.0	0.1	0.0	0.2	0.1	0.3	0.6	0.7	0.5	0.3	0.1	0.1	0.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.3	34.9	48.5	64.0	72.8	80.9	83.5	80.0	70.6	57.4	43.2	30.7	(19)
MCWB			23.4	27.1	34.6	47.3	52.2	58.4	60.1	57.5	50.6	41.9	33.1	23.3	(20)	
2%		DB	24.2	30.1	45.0	59.2	68.7	76.7	79.7	76.4	66.7	53.4	38.5	26.3	(21)	
		MCWB	19.1	23.3	32.5	42.9	50.2	55.4	57.4	56.1	49.2	40.4	30.3	20.4	(22)	
5%		DB	20.1	26.0	41.4	55.7	65.1	73.8	76.8	74.1	63.7	50.2	34.6	22.9	(23)	
		MCWB	15.9	20.5	30.5	40.7	47.8	53.8	55.8	54.8	47.8	38.2	27.7	17.9	(24)	
10%		DB	16.5	22.4	37.5	52.3	61.8	70.7	74.1	71.8	61.2	46.8	31.3	19.6	(25)	
		MCWB	13.1	17.8	28.3	38.8	46.1	52.4	54.7	53.5	46.7	36.0	25.3	15.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.5	27.6	36.2	50.3	56.9	61.7	64.8	63.0	54.0	45.6	34.3	24.1	(27)
MCD B			28.7	33.8	46.7	62.0	69.3	72.8	74.3	75.4	65.1	53.0	42.2	29.8	(28)	
2%		WB	19.5	23.4	33.1	45.0	52.7	58.3	61.3	60.1	51.5	41.7	30.9	20.5	(29)	
		MCD B	23.5	29.5	43.3	56.5	65.0	71.9	72.7	72.2	62.4	50.4	37.6	25.9	(30)	
5%		WB	16.0	20.7	30.8	41.9	49.8	56.1	59.0	57.7	49.5	39.0	28.0	18.1	(31)	
		MCD B	19.8	25.6	40.6	54.1	61.8	69.4	71.4	69.4	60.9	49.2	34.1	22.6	(32)	
10%		WB	13.2	18.0	28.6	39.3	47.2	54.2	57.2	55.5	47.7	36.6	25.4	15.6	(33)	
		MCD B	16.5	22.3	37.3	51.1	59.6	67.3	69.5	68.4	59.0	45.9	30.8	19.4	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	15.9	17.0	18.6	18.9	18.8	18.1	17.2	17.1	17.0	16.9	14.9	14.9	(35)
MCD BR			18.1	19.5	20.7	21.6	21.5	20.5	19.5	18.4	18.4	18.8	17.1	17.9	(36)	
MCWBR			14.6	14.8	13.8	13.6	13.0	11.0	9.7	9.1	10.5	11.9	12.6	14.0	(37)	
5% WB		MCD BR	17.4	19.2	20.0	20.4	20.1	18.5	17.4	16.6	17.0	18.1	16.5	17.6	(38)	
		MCWBR	14.2	14.8	13.8	13.9	13.7	11.5	9.5	9.4	10.7	12.7	12.4	14.0	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.238	0.267	0.309	0.346	0.357	0.378	0.371	0.349	0.317	0.283	0.253	0.236	(40)	
taud		2.397	2.324	2.209	2.159	2.186	2.202	2.266	2.315	2.364	2.400	2.410	2.394	(41)		
Ebn at Noon		288	295	293	289	289	282	283	285	287	285	278	277	(42)		
Edh at Noon		23	30	39	45	45	45	42	38	33	27	23	21	(43)		
(44)	All-Sky Solar Radiation	RadAvg	684	1033	1543	1985	2310	2262	2151	1942	1682	1229	795	601	(44)	
(45)		RadStd	43	68	86	80	122	134	89	109	69	40	40	46	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page