

SAIKHAN-OVOO, Mongolia

WMO: 443360

Lat: 45.4611N

Lon: 103.9000E

Elev: 1316

StdP: 86.48

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-32.1	-29.6	-35.7	0.1	-30.5	-33.4	0.2	-28.3	11.9	-11.1	10.0	-10.4	1.3	310	0.636

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	32.7	16.2	30.9	15.6	29.2	14.8	18.3	28.3	17.2	27.0	16.3	25.3	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.3	12.8	20.3	14.1	11.8	19.9	12.9	10.9	20.0	57.5	28.0	53.6	27.2	50.6	25.2	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	10.3	9.1	-34.2	35.4	3.2	1.7	-36.5	36.6	-38.4	37.6	-40.2	38.6	-42.5	39.8		
(5)			-34.3	19.9	3.1	1.6	-36.5	21.0	-38.3	21.9	-40.1	22.8	-42.4	24.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	3.3	-18.5	-14.0	-3.6	6.1	13.0	19.2	22.2	20.1	13.2	3.9	-7.1	-15.9	(6)
(7)		DBStd	14.96	5.30	6.30	5.88	5.10	4.86	3.84	3.36	3.59	4.54	4.84	6.23	5.07	(7)
(8)		HDD10.0	3668	883	671	421	136	27	0	0	0	21	194	514	802	(8)
(9)		HDD18.3	5764	1142	904	678	368	176	35	6	23	161	448	764	1060	(9)
(10)		CDD10.0	1226	0	0	1	18	118	276	378	312	118	5	0	0	(10)
(11)		CDD18.3	280	0	0	0	0	9	61	126	77	7	0	0	0	(11)
(12)		CDH23.3	3108	0	0	0	4	176	735	1318	771	104	0	0	0	(12)
(13)		CDH26.7	1098	0	0	0	1	42	258	527	257	14	0	0	0	(13)
(14)	Wind	WSAvg	3.1	1.9	2.3	3.6	4.2	4.6	3.9	3.4	3.1	3.1	2.5	1.8	(14)	
(15)	Precipitation	PrecAvg	132	1	1	2	4	10	27	39	29	10	4	2	3	(15)
(16)		PrecMax	225	5	6	13	12	50	97	96	117	32	12	9	27	(16)
(17)		PrecMin	64	0	0	0	0	0	1	6	0	0	0	0	0	(17)
(18)		PrecStd	48	2	1	3	4	10	23	25	24	10	4	2	5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-1.1	5.4	16.1	23.6	30.2	34.1	36.2	33.6	28.7	20.7	11.2	0.7	(19)
(20)			MCWB	-5.1	-0.8	5.0	10.3	13.1	16.0	18.2	16.7	13.5	8.6	3.3	-3.6	(20)
(21)		2%	DB	-4.8	1.8	12.6	21.0	27.6	31.7	33.4	31.4	26.2	17.7	7.7	-2.7	(21)
(22)			MCWB	-7.7	-3.0	3.2	8.3	11.9	15.2	17.0	15.8	12.5	7.4	1.2	-6.1	(22)
(23)		5%	DB	-7.2	-0.9	9.6	18.4	25.1	29.6	31.4	29.5	24.1	15.3	5.1	-5.1	(23)
(24)			MCWB	-9.4	-4.9	1.6	7.1	10.7	14.2	16.3	15.1	11.7	6.0	-0.5	-7.7	(24)
(25)		10%	DB	-9.7	-3.5	6.9	15.9	23.0	27.6	29.6	27.6	21.9	13.0	2.5	-7.5	(25)
(26)			MCWB	-11.4	-6.5	0.1	5.8	9.8	13.4	15.6	14.3	10.8	4.8	-2.1	-9.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-4.9	-0.7	5.4	11.5	14.3	17.7	20.2	18.8	15.2	9.8	3.5	-3.6	(27)
(28)			MCDWB	-1.3	4.5	15.0	22.2	27.8	30.2	30.4	28.8	24.8	19.3	10.8	0.4	(28)
(29)		2%	WB	-7.5	-2.9	3.5	8.9	12.7	16.4	19.0	17.6	13.8	7.8	1.3	-5.9	(29)
(30)			MCDWB	-4.8	1.6	12.0	19.1	25.6	26.9	29.6	27.0	22.8	16.9	7.4	-2.9	(30)
(31)		5%	WB	-9.4	-4.7	1.8	7.4	11.4	15.6	17.9	16.6	12.6	6.3	-0.4	-7.7	(31)
(32)			MCDWB	-7.2	-1.1	9.3	17.7	23.7	25.5	27.4	25.3	21.8	14.5	4.8	-5.1	(32)
(33)		10%	WB	-11.4	-6.4	0.1	6.0	10.2	14.7	16.9	15.7	11.5	4.9	-1.9	-9.6	(33)
(34)			MCDWB	-9.6	-3.5	6.7	15.4	21.8	24.6	26.5	23.8	20.5	12.5	2.4	-7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	13.5	15.6	15.3	14.1	13.8	12.8	11.7	11.9	13.2	14.3	13.5	12.7	(35)
(36)			MCDBR	15.3	18.1	18.2	17.3	16.6	15.6	13.9	14.3	15.8	17.2	15.7	14.5	(36)
(37)			MCWBR	12.9	14.0	11.2	9.5	8.0	6.4	5.0	5.3	6.9	9.7	10.6	11.8	(37)
(38)		5% WB	MCDWR	15.3	17.4	17.7	16.3	15.4	13.1	11.7	12.0	13.9	16.3	15.3	14.2	(38)
(39)			MCWBR	13.0	13.7	11.2	9.5	8.3	6.0	5.4	4.9	6.7	9.6	10.5	11.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.250	0.277	0.319	0.362	0.380	0.398	0.385	0.364	0.327	0.298	0.265	0.249	(40)	
(41)		taud	2.356	2.294	2.213	2.147	2.150	2.190	2.285	2.323	2.372	2.384	2.386	2.353	(41)	
(42)		Ebn at Noon	876	908	907	893	886	869	876	883	892	872	847	834	(42)	
(43)		Edh at Noon	73	96	121	142	147	142	128	118	103	87	71	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.02	3.15	4.71	6.02	6.99	6.97	6.65	6.04	5.09	3.64	2.31	1.71	(44)	
(45)		RadStd	0.18	0.27	0.18	0.25	0.34	0.34	0.27	0.29	0.16	0.16	0.19	0.15	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (5 neighbors)		N/A	N/A	-2.37	N/A	-0.90	-1.05	N/A	N/A	N/A

Nomenclature: See separate page