

TA KWU LING, Hong Kong

WMO: 450320

Lat: 22.5291N

Lon: 114.1560E

Elev: 14

StdP: 101.15

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.7	7.1	-5.2	2.4	13.0	-1.7	3.3	12.0	6.5	11.1	6.0	11.5	1.9	350	0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	34.2	26.7	33.6	26.6	32.9	26.5	28.4	31.6	27.7	31.3	27.3	30.7	2.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.6	23.6	30.0	26.8	22.4	29.3	26.4	21.9	29.0	92.1	31.7	88.8	31.5	86.8	31.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.0	5.2	4.5	2.7	36.1	1.9	0.9	1.3	36.7	0.1	37.2	-1.0	37.7	-2.4	38.4		
			1.1	31.0	1.6	2.8	0.0	33.0	-0.9	34.6	-1.8	36.2	-2.9	38.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.2	15.3	17.0	19.2	23.1	26.3	28.1	28.8	28.7	27.8	25.2	21.4	16.7
	DBStd	5.58	3.65	4.21	3.36	2.84	2.10	1.50	1.21	1.29	1.90	2.05	3.25	3.55
	HDD10.0	9	4	3	0	0	0	0	0	0	0	0	0	1
	HDD18.3	291	106	66	31	3	0	0	0	0	1	0	11	73
	CDD10.0	4815	169	201	285	392	506	543	584	579	534	472	341	209
	CDD18.3	2054	12	29	57	146	247	293	326	321	284	214	102	23
	CDH23.3	19099	24	79	174	799	2167	3228	3849	3651	2962	1607	492	66
	CDH26.7	6719	1	4	15	181	679	1192	1604	1464	1068	430	78	3
Wind	WSAvg	2.1	2.2	2.4	2.4	2.4	2.2	1.9	1.9	1.7	2.0	2.0	2.2	2.2
Precipitation	PrecAvg	1837	27	42	69	155	243	291	308	350	242	53	39	25
	PrecMax	2662	96	202	370	459	551	740	556	665	528	440	129	171
	PrecMin	912	0	0	3	4	25	72	96	40	28	0	0	0
	PrecStd	376	29	50	75	111	142	147	150	157	137	83	40	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.7	27.3	28.2	31.2	33.9	34.1	35.4	35.3	34.5	32.7	30.5	27.0
		MCWB	19.1	21.1	22.1	24.3	26.1	26.6	27.0	27.0	26.5	24.9	23.0	20.8
	2%	DB	23.6	25.7	26.8	29.9	32.5	33.3	34.1	34.2	33.4	31.1	28.7	25.2
		MCWB	18.1	20.4	21.9	23.9	25.7	26.6	26.7	27.0	26.2	24.0	22.0	19.0
	5%	DB	21.9	24.1	25.3	28.8	31.4	32.5	33.3	33.4	32.5	30.1	27.4	23.6
		MCWB	16.8	19.5	20.6	23.6	25.5	26.5	26.7	27.0	25.8	23.1	21.4	17.8
	10%	DB	20.3	22.5	23.9	27.6	30.2	31.6	32.5	32.5	31.5	29.1	26.1	22.0
		MCWB	16.0	18.9	20.0	23.3	25.2	26.5	26.7	26.9	25.4	22.6	20.8	17.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	22.7	23.5	25.7	27.2	29.0	29.6	32.2	28.2	26.7	24.6	22.6
		MCDB	23.8	25.6	26.7	28.9	30.9	31.5	31.2	32.6	31.2	29.5	28.1	24.9
	2%	WB	19.2	21.6	22.7	25.0	26.8	27.7	28.1	28.6	27.2	25.7	23.8	20.8
		MCDB	22.1	24.3	25.6	28.1	30.2	31.1	31.7	31.7	31.0	28.8	26.7	23.3
	5%	WB	18.1	20.6	21.9	24.4	26.4	27.2	27.6	27.7	26.8	25.1	23.2	19.6
		MCDB	20.7	23.2	24.4	27.5	29.7	30.5	31.2	31.3	30.3	28.1	25.8	22.3
	10%	WB	17.1	19.4	21.0	23.8	26.0	26.9	27.1	27.2	26.3	24.5	22.3	18.2
		MCDB	19.5	21.7	23.0	26.8	29.0	30.0	30.8	30.6	29.5	27.4	24.9	21.2
Mean Daily Temperature Range	5% DB	MDBR	7.9	6.8	6.4	6.2	6.2	6.0	6.8	6.9	6.9	7.5	7.8	8.5
		MCDBR	9.7	9.2	8.6	8.3	8.1	7.7	8.5	8.7	8.5	8.6	8.9	10.0
		MCWBR	4.3	4.4	4.1	3.2	2.7	2.5	2.6	3.0	2.6	2.8	3.3	4.3
	5% WB	MCDBR	7.4	7.3	7.0	7.0	6.8	6.5	7.2	7.5	7.4	6.8	6.9	7.4
		MCWBR	4.1	4.0	3.8	3.3	2.7	2.5	2.9	3.5	2.7	2.9	3.2	4.2
Clear-Sky Solar Irradiance	taub	0.584	0.638	0.769	0.747	0.587	0.555	0.542	0.608	0.641	0.682	0.577	0.568	
	taud	1.792	1.718	1.508	1.587	1.959	2.058	2.089	1.893	1.798	1.664	1.871	1.851	
	Ebn at Noon	675	671	608	635	742	759	769	722	687	628	677	670	
	Edh at Noon	200	228	293	275	188	169	164	200	216	237	183	182	
All-Sky Solar Radiation	RadAvg	3.09	3.12	3.33	3.65	4.40	4.52	5.29	4.98	4.69	4.39	3.58	3.24	
	RadStd	0.50	0.49	0.45	0.58	0.61	0.68	0.56	0.46	0.33	0.44	0.41	0.48	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (13 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page