

CHEUNG CHAU, Hong Kong

WMO: 450440

Lat: 22.2011N

Lon: 114.0267E

Elev: 260

StdP: 14.56

Time Zone: 8.00 (E08)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	46.3	49.0	29.6	23.8	53.3	34.4	29.4	54.6	27.2	50.1	25.2	50.2	19.2	0	0.458

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.1	90.8	82.7	89.5	82.2	88.4	81.7	84.3	88.5	83.4	87.6	82.6	86.7	9.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.2	175.2	87.0	82.3	169.9	86.1	81.6	165.9	85.3	48.9	88.9	47.8	87.9	46.9	87.0	92.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
28.3	24.2	21.3	DB	43.7	94.7	4.8	1.6	40.3	95.9	37.5	96.8	34.8	97.8	31.4	99.0	
			WB	37.2	86.6	4.1	2.3	34.3	88.3	31.9	89.7	29.6	91.0	26.7	92.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	73.9	61.1	62.9	66.4	72.8	78.7	81.9	83.0	82.6	81.8	78.1	72.0	64.3
	DBStd	9.06	5.13	6.59	5.27	4.72	3.76	2.90	2.51	2.66	2.84	3.23	4.79	5.33
	HDD50	8	3	4	0	0	0	0	0	0	0	0	0	1
	HDD65	376	138	103	47	5	0	0	0	0	0	0	8	75
	CDD50	8713	346	365	509	684	890	957	1022	1010	954	871	660	445
	CDD65	3608	16	45	91	239	425	507	557	545	504	406	218	55
	CDH74	29674	8	40	110	880	3249	5174	6079	5777	4936	2685	685	51
	CDH80	7967	0	0	3	121	706	1470	1964	1765	1369	506	62	1
Wind	WSAvg	11.0	10.9	10.3	10.2	10.1	10.8	11.3	11.0	10.2	11.7	12.2	12.0	11.7
Precipitation	PrecAvg	79.1	0.8	1.5	2.4	5.8	11.4	14.5	11.2	13.5	9.6	5.0	1.1	0.9
	PrecMax	118.5	2.5	8.7	15.6	14.0	29.2	44.4	28.0	31.2	26.1	30.8	4.6	6.1
	PrecMin	34.8	0.0	0.0	0.0	0.1	0.2	3.0	2.5	3.6	1.3	0.0	0.0	0.0
	PrecStd	21.2	0.7	2.4	3.2	4.1	7.2	9.6	5.9	7.9	6.7	7.2	1.4	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.7	77.7	79.9	86.1	91.1	91.1	91.8	92.6	92.5	89.4	84.2	78.1
		MCWB	66.6	70.3	74.0	79.0	82.2	83.7	83.8	82.4	82.0	78.8	75.2	69.6
	2%	DB	71.5	75.0	76.9	83.2	88.0	89.4	90.0	90.3	90.0	86.4	81.8	75.3
		MCWB	64.4	68.7	71.3	77.0	82.0	82.7	83.1	82.6	81.2	76.8	73.3	66.9
	5%	DB	69.2	72.3	74.6	81.0	86.0	87.9	88.8	88.8	88.3	84.4	79.7	72.9
		MCWB	62.9	67.4	69.8	75.6	80.6	82.3	82.6	82.2	80.1	75.6	71.9	65.4
	10%	DB	67.2	70.2	72.7	78.7	83.8	86.3	87.4	87.2	86.4	82.7	77.7	70.9
		MCWB	61.7	66.4	68.8	74.4	79.4	81.5	81.9	81.6	79.2	74.7	71.0	64.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.6	72.3	75.2	80.1	84.6	85.4	85.5	84.9	84.5	80.9	77.2	72.1
		MCDB	72.3	75.4	78.6	84.3	87.4	88.9	89.6	89.3	89.6	86.6	82.3	76.1
	2%	WB	66.4	70.5	72.9	78.1	82.8	83.8	84.1	83.6	82.6	79.1	75.6	69.9
		MCDB	69.3	73.1	75.1	81.4	86.5	87.5	88.4	88.2	87.9	84.0	79.4	72.9
	5%	WB	64.6	68.8	71.3	76.6	81.5	82.8	83.2	82.7	81.6	77.9	74.1	67.9
		MCDB	67.8	71.3	73.5	79.4	84.8	86.3	87.3	87.2	86.3	82.3	77.7	71.5
	10%	WB	63.0	67.0	69.9	75.5	80.3	82.0	82.4	81.9	80.5	76.6	72.7	65.8
		MCDB	66.4	69.8	72.2	78.1	83.0	85.2	86.3	86.0	84.5	80.7	76.5	69.9
Mean Daily Temperature Range	5% DB	MDBR	9.4	8.7	8.3	8.0	8.0	7.6	8.1	8.3	8.8	9.2	9.4	10.1
		MCDBR	11.1	11.2	10.5	10.9	10.6	9.7	10.0	10.7	11.6	11.0	10.5	11.4
		MCWBR	6.5	6.4	6.1	5.8	5.7	5.2	5.4	5.6	5.9	5.6	5.6	6.8
	5% WB	MCDBR	9.2	10.1	9.3	10.1	9.5	8.8	9.4	9.9	10.6	9.2	9.2	9.8
		MCWBR	6.1	6.3	6.0	5.7	5.7	5.3	5.6	5.7	5.7	4.9	5.4	6.6
Clear-Sky Solar Irradiance	taub	0.578	0.626	0.748	0.723	0.562	0.531	0.519	0.584	0.619	0.671	0.573	0.568	
	taud	1.817	1.749	1.546	1.634	2.036	2.143	2.171	1.964	1.855	1.697	1.893	1.861	
	Ebn at Noon	217	216	197	207	241	247	250	235	224	202	217	213	
	Edh at Noon	62	70	89	83	55	49	48	59	65	73	57	57	
All-Sky Solar Radiation	RadAvg	948	985	1078	1224	1459	1499	1723	1601	1503	1386	1110	986	
	RadStd	158	159	143	179	182	217	180	141	124	135	128	145	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (13 neighbors)	N/A	N/A	N/A	+0.45	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page