

CHIANG KAI SHEK INTL, Taiwan

WMO: 466860

Lat: 25.078N

Lon: 121.233E

Elev: 33

StdP: 100.93

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	10.8	2.9	4.7	11.5	4.4	5.2	12.3	13.5	14.1	13.0	14.2	7.1	40	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	34.9	26.9	34.0	27.0	33.1	26.8	28.7	32.3	28.1	31.6	27.6	31.1	8.3	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.9	24.0	31.3	27.1	22.9	30.4	26.8	22.6	30.1	93.1	32.6	90.7	31.7	87.9	31.5	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years						
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.1	12.0	11.1	DB	7.6	37.0	1.4	1.0	6.6	37.7	5.8	38.2	5.0	38.8	4.0	39.5	
			WB	5.3	29.0	1.5	1.0	4.2	29.7	3.3	30.3	2.5	30.9	1.4	31.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	16.0	16.1	17.9	22.1	25.3	28.0	29.8	29.6	27.7	24.8	21.8	17.9
	DBStd	5.54	2.76	2.95	3.13	3.07	2.41	2.03	1.25	1.42	2.10	2.22	2.53	2.89
	HDD10.0	1	1	1	0	0	0	0	0	0	0	0	0	0
	HDD18.3	251	80	74	46	6	0	0	0	0	0	0	3	42
	CDD10.0	4793	187	171	246	363	474	541	614	606	532	458	354	246
	CDD18.3	2000	8	11	33	119	216	291	356	348	282	199	107	29
	CDH23.3	19366	9	25	101	618	1714	3253	4592	4368	3013	1262	366	46
(13)	CDH26.7	7505	1	2	12	119	473	1274	2199	1995	1095	277	54	4
(14) Wind	WSAvg	5.5	6.5	6.0	5.4	4.7	4.4	4.6	4.7	4.4	5.2	6.7	6.7	7.0
(15) Precipitation	PrecAvg	2416	127	185	183	178	221	274	149	235	353	231	157	123
	PrecMax	3635	275	434	307	517	657	693	343	553	1721	940	527	287
	PrecMin	1064	42	26	78	32	15	57	12	18	12	1	6	11
	PrecStd	661	53	113	54	118	134	160	97	173	382	206	126	89
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.8	26.1	28.1	31.1	33.0	34.2	36.1	36.1	35.2	32.9	30.1	26.9
		MCWB	19.8	20.5	22.7	25.3	26.5	27.0	26.7	26.7	26.2	26.1	23.2	21.2
	2%	DB	22.2	23.8	25.9	29.2	31.8	33.2	34.9	34.9	33.2	30.9	28.1	24.2
		MCWB	18.2	19.2	20.9	24.2	25.8	27.0	27.0	27.0	26.3	25.3	22.5	19.8
	5%	DB	21.0	21.8	24.1	28.0	30.2	32.6	34.0	33.9	32.2	29.2	26.9	23.0
		MCWB	17.7	18.3	20.2	23.6	25.3	26.8	27.1	27.1	26.1	24.3	22.2	19.3
	10%	DB	19.9	20.0	22.8	26.8	29.1	31.8	33.1	32.9	31.2	28.1	25.2	21.9
		MCWB	17.2	17.4	19.7	22.9	24.8	26.6	26.9	26.8	25.9	23.6	21.5	18.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	21.6	23.7	26.2	27.6	29.2	29.5	29.1	28.6	27.0	24.9	22.4
		MCDB	22.7	24.7	26.8	29.2	31.0	32.4	33.3	33.1	32.1	30.6	27.5	25.4
	2%	WB	19.4	20.2	22.3	25.3	26.7	28.2	28.7	28.5	27.7	26.1	23.7	21.1
		MCDB	21.4	22.5	24.7	28.1	29.8	31.4	32.3	32.3	31.0	29.2	26.3	23.1
	5%	WB	18.4	18.9	21.2	24.4	26.1	27.6	28.1	27.9	27.0	25.5	23.0	20.4
		MCDB	20.3	20.7	23.3	27.1	29.1	30.8	31.5	31.7	30.4	28.2	25.5	22.1
	10%	WB	17.6	17.7	20.0	23.5	25.6	26.9	27.5	27.3	26.4	24.6	22.3	19.4
		MCDB	19.3	19.6	22.1	26.0	28.4	30.3	31.1	30.9	29.7	27.1	24.7	21.2
(35) Mean Daily Temperature Range	5% DB	MDBR	5.0	5.1	5.8	6.0	6.0	6.0	6.8	6.6	6.0	5.2	5.1	4.9
		MCDBR	7.4	8.6	8.6	8.0	7.4	7.0	7.7	7.8	7.3	6.9	7.2	7.3
		MCWBR	4.7	5.2	5.2	4.6	3.8	3.4	3.3	3.2	3.4	3.5	3.9	4.5
	5% WB	MCDBR	6.2	7.7	7.8	7.2	6.5	6.4	6.9	6.9	6.5	6.2	6.2	6.3
		MCWBR	4.3	5.2	5.2	4.5	3.7	3.6	3.5	3.4	3.4	3.5	3.8	4.3
(40) Clear-Sky Solar Irradiance	taub		0.556	0.597	0.701	0.703	0.602	0.561	0.545	0.565	0.547	0.544	0.541	0.551
	taud		1.843	1.781	1.594	1.639	1.897	2.021	2.065	2.003	2.028	1.976	1.959	1.868
	Ebn at Noon		684	692	646	661	730	755	767	751	754	729	695	666
	Edh at Noon		185	210	266	259	200	175	168	178	170	170	163	174
(44) All-Sky Solar Radiation	RadAvg		2.23	2.52	3.15	3.58	4.17	4.86	6.04	5.46	4.65	3.69	2.61	2.20
	RadStd		0.46	0.50	0.46	0.54	0.75	0.59	0.34	0.48	0.50	0.45	0.33	0.38

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144	+121
(47) Regional (20 neighbors)	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A	N/A	+81

Nomenclature: See separate page