

KEELUNG, Taiwan

WMO: 466940

Lat: 25.133N

Lon: 121.740E

Elev: 88

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	50.9	52.7	39.7	36.0	54.4	42.1	39.6	55.9	21.2	55.1	19.7	55.5	10.9	10	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	93.0	78.6	91.3	78.4	89.9	78.4	80.9	87.7	80.2	87.2	79.7	86.8	9.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	152.2	84.5	78.4	147.7	84.3	77.6	144.0	84.3	44.8	87.4	44.0	87.4	43.4	86.9	85.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	17.0	15.1	46.6	96.3	2.5	1.5	44.8	97.4	43.3	98.2	41.9	99.1	40.1	100.1
			43.6	82.3	2.7	1.4	41.6	83.3	40.0	84.2	38.4	85.0	36.4	86.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.9	60.6	61.1	64.5	70.5	76.2	81.6	84.9	84.1	80.0	74.6	70.9	65.3
	DBStd	9.37	4.45	4.75	5.16	5.90	4.55	4.22	2.34	2.22	3.80	3.40	4.40	4.57
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	426	148	127	73	20	0	0	0	0	0	0	8	50
	CDD50	8369	329	312	449	616	811	947	1083	1058	899	763	627	475
	CDD65	3316	11	18	57	185	347	497	618	593	449	298	184	59
	CDH74	30752	10	15	105	802	2500	5464	8072	7427	4406	1365	511	75
	CDH80	10810	0	1	9	103	550	2037	3710	3091	1124	152	31	2
Wind	WSAvg	6.6	7.8	7.3	6.3	5.4	5.0	5.0	5.5	6.5	6.8	7.9	7.7	8.0
Precipitation	PrecAvg	130.5	8.5	9.6	8.2	8.0	10.6	12.1	7.0	12.9	17.8	15.0	11.7	9.0
	PrecMax	194.8	19.1	20.6	12.6	20.4	25.4	27.8	16.2	28.7	71.2	55.4	31.9	17.5
	PrecMin	68.8	3.7	1.9	3.2	2.2	1.5	3.9	1.3	3.3	3.1	2.6	3.0	1.9
	PrecStd	27.0	3.3	5.2	2.4	4.3	5.6	5.4	3.9	8.1	13.7	9.9	6.8	4.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.3	76.4	80.4	86.1	90.3	94.0	96.1	94.1	91.9	87.1	83.1	79.4
		MCWB	65.6	66.6	70.7	74.5	77.5	78.0	79.4	79.7	77.4	76.5	72.6	69.5
	2%	DB	70.4	72.9	76.7	82.8	87.1	91.5	93.6	91.8	89.3	83.9	80.3	76.0
		MCWB	63.4	65.2	68.7	73.3	76.1	78.3	79.0	78.8	77.7	75.7	72.2	68.2
	5%	DB	68.2	70.3	74.2	80.3	85.0	89.6	91.7	90.4	87.2	81.3	78.5	73.4
		MCWB	62.9	64.1	67.2	72.5	75.8	78.2	78.6	78.7	77.6	74.6	71.9	67.2
	10%	DB	66.5	67.9	71.8	78.3	83.0	88.1	90.0	89.0	85.5	79.3	76.9	71.2
		MCWB	62.2	62.7	66.4	71.5	75.2	77.8	78.5	78.6	76.9	73.4	70.8	66.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.3	68.5	71.1	75.6	78.8	81.1	81.6	82.5	80.4	78.0	75.0	71.0
		MCDB	71.2	74.5	77.8	83.3	86.5	89.3	88.1	87.9	85.2	83.2	79.8	75.5
	2%	WB	65.5	66.4	69.8	74.3	77.6	79.9	80.7	81.2	79.6	76.9	73.7	69.6
		MCDB	68.7	71.4	75.5	81.1	84.8	88.0	88.4	87.2	84.6	81.9	78.3	73.8
	5%	WB	64.0	65.0	68.5	73.3	76.7	79.1	80.1	80.4	78.8	75.8	72.8	68.3
		MCDB	67.5	69.1	73.1	79.0	83.4	86.8	88.1	86.8	84.1	80.1	77.4	72.4
	10%	WB	62.7	63.4	67.2	72.3	75.8	78.4	79.6	79.7	78.1	74.7	71.8	66.9
		MCDB	65.7	67.2	71.1	77.5	82.1	85.8	87.7	86.3	83.5	78.6	76.4	71.0
Mean Daily Temperature Range	5% DB	MDBR	6.4	6.8	7.6	7.7	8.4	9.1	10.1	8.9	7.4	5.3	6.3	6.2
		MCDBR	10.2	11.5	13.0	11.7	12.6	11.8	12.4	11.3	10.1	9.0	9.1	10.5
		MCWBR	6.3	6.2	6.4	6.2	6.1	5.3	4.3	4.3	4.0	4.7	4.6	5.8
	5% WB	MCDBR	8.7	9.3	11.5	10.4	10.6	10.3	10.5	9.3	8.2	7.0	7.8	8.6
		MCWBR	5.9	5.8	6.4	6.0	5.8	5.2	4.5	4.5	4.1	4.3	4.9	5.4
Clear-Sky Solar Irradiance	taub	0.555	0.589	0.685	0.686	0.598	0.560	0.526	0.540	0.529	0.537	0.539	0.551	
	taud	1.860	1.815	1.637	1.683	1.918	2.036	2.139	2.088	2.096	2.006	1.974	1.883	
	Ebn at Noon	217	222	208	213	232	240	248	244	244	233	221	212	
	Edh at Noon	58	64	81	79	62	55	49	52	50	52	51	55	
All-Sky Solar Radiation	RadAvg	658	753	962	1114	1322	1554	1935	1747	1476	1141	794	654	
	RadStd	138	158	154	173	238	184	105	147	153	144	105	118	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (16 neighbors)	N/A	N/A	N/A	+0.58	N/A	N/A	N/A	N/A	N/A	+146

Nomenclature: See separate page