

KEELUNG, Taiwan

WMO: 466940

Lat: 25.133N

Lon: 121.740E

Elev: 27

StdP: 101.00

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.5	11.5	4.3	5.1	12.5	5.6	5.7	13.3	9.5	12.9	8.8	13.0	4.9	10	0.326

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.6	33.9	25.9	33.0	25.8	32.2	25.8	27.2	30.9	26.8	30.7	26.5	30.5	4.0	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	29.2	25.8	21.1	29.1	25.3	20.6	29.0	86.3	30.8	84.5	30.8	83.0	30.5	29.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	7.6	6.7		8.1	35.7	1.4	0.8	7.1	36.3	6.3	36.8	5.5	37.3	4.5	37.8
				6.4	27.9	1.5	0.8	5.3	28.5	4.4	29.0	3.6	29.4	2.5	30.0
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	15.9	16.2	18.0	21.4	24.5	27.5	29.4	29.0	26.7	23.7	21.6	18.5	(6)
(7)		DBStd	5.21	2.47	2.64	2.87	3.28	2.53	2.35	1.30	1.23	2.11	1.89	2.44	2.54	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	237	82	71	41	11	0	0	0	0	0	0	4	28	(9)
(10)		CDD10.0	4649	183	173	249	342	451	526	602	588	499	424	348	264	(10)
(11)		CDD18.3	1842	6	10	32	103	193	276	343	329	249	166	102	33	(11)
(12)		CDH23.3	17084	6	8	58	446	1389	3036	4484	4126	2448	758	284	42	(12)
(13)	CDH26.7	6006	0	1	5	57	306	1132	2061	1717	624	84	17	1	(13)	
(14)	Wind	WSAvg	2.9	3.5	3.3	2.8	2.4	2.2	2.5	2.9	3.0	3.5	3.4	3.6	(14)	
(15)	Precipitation	PrecAvg	3315	217	244	209	203	269	308	179	327	452	381	298	229	(15)
(16)		PrecMax	4947	486	524	320	517	645	707	412	730	1808	1406	811	445	(16)
(17)		PrecMin	1747	95	47	81	55	39	99	34	83	78	66	77	47	(17)
(18)		PrecStd	686	85	132	60	110	141	136	98	207	348	252	173	121	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	24.7	26.9	30.1	32.4	34.4	35.6	34.5	33.3	30.6	28.4	26.3	(19)
(20)			MCWB	18.7	19.2	21.5	23.6	25.3	25.6	26.4	26.5	25.2	24.7	22.5	20.8	(20)
(21)		2%	DB	21.3	22.7	24.8	28.2	30.6	33.1	34.2	33.2	31.8	28.8	26.9	24.4	(21)
(22)			MCWB	17.5	18.4	20.4	22.9	24.5	25.7	26.1	26.0	25.4	24.3	22.3	20.1	(22)
(23)		5%	DB	20.1	21.3	23.5	26.8	29.5	32.0	33.2	32.4	30.7	27.4	25.9	23.0	(23)
(24)			MCWB	17.2	17.8	19.5	22.5	24.4	25.6	25.9	26.0	25.3	23.7	22.2	19.6	(24)
(25)		10%	DB	19.2	19.9	22.1	25.7	28.4	31.1	32.2	31.7	29.7	26.3	25.0	21.8	(25)
(26)			MCWB	16.8	17.1	19.1	21.9	24.0	25.4	25.8	25.9	25.0	23.0	21.6	19.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.3	21.7	24.2	26.0	27.3	27.5	28.1	26.9	25.6	23.9	21.7	(27)
(28)			MADB	21.8	23.6	25.4	28.5	30.3	31.8	31.1	31.1	29.6	28.4	26.6	24.2	(28)
(29)		2%	WB	18.6	19.1	21.0	23.5	25.3	26.6	27.1	27.3	26.4	25.0	23.2	20.9	(29)
(30)			MADB	20.4	21.9	24.2	27.3	29.3	31.1	31.4	30.7	29.2	27.7	25.7	23.2	(30)
(31)		5%	WB	17.8	18.3	20.3	22.9	24.8	26.2	26.7	26.9	26.0	24.3	22.7	20.1	(31)
(32)			MADB	19.7	20.6	22.8	26.1	28.6	30.4	31.2	30.4	28.9	26.7	25.2	22.4	(32)
(33)		10%	WB	17.1	17.5	19.6	22.4	24.3	25.8	26.4	26.5	25.6	23.7	22.1	19.4	(33)
(34)			MADB	18.7	19.5	21.7	25.3	27.8	29.9	30.9	30.2	28.6	25.9	24.7	21.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	3.6	3.8	4.2	4.3	4.6	5.1	5.6	5.0	4.1	3.0	3.5	3.4	(35)
(36)			MCDBR	5.6	6.4	7.2	6.5	7.0	6.5	6.9	6.3	5.6	5.0	5.1	5.8	(36)
(37)			MCWBR	3.5	3.5	3.6	3.5	3.4	2.9	2.4	2.4	2.2	2.6	2.6	3.2	(37)
(38)		5% WB	MCDBR	4.8	5.2	6.4	5.8	5.9	5.7	5.8	5.2	4.6	3.9	4.4	4.8	(38)
(39)			MCWBR	3.3	3.2	3.6	3.3	3.2	2.9	2.5	2.5	2.3	2.4	2.7	3.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.555	0.589	0.685	0.686	0.598	0.560	0.526	0.540	0.529	0.537	0.539	0.551	(40)	
(41)		taud	1.860	1.815	1.637	1.683	1.918	2.036	2.139	2.088	2.096	2.006	1.974	1.883	(41)	
(42)		Ebn at Noon	685	699	657	672	732	756	782	770	770	735	696	667	(42)	
(43)		Edh at Noon	182	203	255	248	196	173	156	163	159	165	161	172	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.07	2.37	3.03	3.51	4.17	4.90	6.10	5.51	4.65	3.60	2.50	2.06	(44)	
(45)		RadStd	0.43	0.50	0.48	0.55	0.75	0.58	0.33	0.46	0.48	0.46	0.33	0.37	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (16 neighbors)	N/A	N/A	N/A	+0.32	N/A	N/A	N/A	N/A	N/A	+81

Nomenclature: See separate page