

PENGJIA YU, Taiwan

WMO: 466950

Lat: 25.628N

Lon: 122.080E

Elev: 334

StdP: 14.52

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.4	50.4	36.7	32.4	50.4	39.5	36.0	52.5	35.3	56.7	32.8	57.6	21.8	20	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.3	88.8	81.5	87.9	81.2	86.9	80.8	82.4	87.3	81.8	86.5	81.2	85.7	13.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.9	162.6	86.0	80.3	159.5	85.3	79.9	156.8	84.7	46.6	87.7	45.9	86.9	45.3	86.2	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
36.7	31.9	28.3	45.6	90.9	3.2	2.1	43.3	92.4	41.4	93.7	39.6	94.8	37.3	96.4	DB
			41.2	83.3	3.6	0.8	38.6	83.8	36.5	84.3	34.5	84.8	31.9	85.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	72.0	60.1	61.2	63.6	69.3	74.6	79.7	83.0	82.8	80.3	75.4	70.0	63.2
	DBStd	9.17	5.39	5.60	5.55	5.02	4.07	3.19	1.72	1.83	2.62	3.04	4.14	5.16
	HDD50	4	2	1	1	0	0	0	0	0	0	0	0	0
	HDD65	508	166	127	94	18	0	0	0	0	0	0	8	95
	CDD50	8029	317	316	422	578	762	892	1022	1017	909	786	599	409
	CDD65	3058	16	21	50	147	297	442	557	552	459	321	157	39
	CDH74	24121	1	5	35	326	1429	3916	6323	6166	4281	1390	240	9
	CDH80	5945	0	0	0	15	187	868	2034	1905	847	87	2	0
Wind	WSAvg	16.2	18.2	17.8	16.6	15.1	13.7	13.4	15.5	14.9	15.3	17.9	18.1	18.4
Precipitation	PrecAvg	76.5	5.5	5.7	5.7	6.1	8.0	7.9	3.7	8.5	9.3	5.8	5.6	5.2
	PrecMax	109.2	17.9	12.7	8.5	17.2	23.1	21.0	14.8	19.7	46.9	31.4	19.7	11.1
	PrecMin	35.0	0.9	0.7	2.9	0.7	1.3	1.3	0.0	0.1	0.0	0.0	0.0	0.1
	PrecStd	19.6	3.3	3.5	1.8	3.9	4.8	4.8	3.5	5.9	10.6	6.0	4.2	3.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.8	74.5	77.2	82.0	86.3	88.5	90.0	90.0	88.7	84.6	80.1	75.2
		MCWB	67.2	69.0	71.7	75.8	79.6	81.6	81.9	81.8	81.7	79.2	74.8	70.0
	2%	DB	70.8	71.9	74.6	79.4	84.0	87.1	88.8	88.9	86.9	82.2	78.1	72.9
		MCWB	65.8	67.2	69.7	74.4	78.4	81.0	81.6	81.4	80.7	77.2	73.5	67.7
	5%	DB	69.1	70.4	72.8	77.5	82.1	86.0	87.9	87.8	85.5	80.6	76.6	71.3
		MCWB	64.7	65.7	68.4	73.2	77.1	80.5	81.4	80.9	79.8	75.8	72.6	66.5
	10%	DB	67.5	68.9	71.2	75.6	80.1	84.6	86.9	86.6	84.1	79.2	75.2	69.8
		MCWB	63.4	64.6	67.0	71.9	75.9	79.9	81.0	80.6	78.9	74.6	71.3	65.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.9	70.8	72.9	76.9	80.5	82.5	83.3	83.1	82.4	80.1	76.3	71.1
		MCDB	71.4	73.2	75.7	81.2	85.1	87.0	88.3	88.3	87.1	83.5	78.6	73.6
	2%	WB	66.9	68.2	71.2	75.2	78.8	81.6	82.5	82.2	81.4	78.3	75.1	69.0
		MCDB	69.8	70.8	73.7	78.2	83.1	85.9	87.5	87.2	85.7	81.0	77.4	72.0
	5%	WB	65.5	66.8	69.4	73.9	77.6	80.9	81.8	81.6	80.5	77.0	73.5	67.4
		MCDB	68.5	69.5	72.1	76.6	81.1	84.9	86.6	86.3	84.4	79.9	76.0	70.5
	10%	WB	63.9	65.5	67.6	72.7	76.5	80.1	81.2	80.9	79.6	75.6	72.0	65.9
		MCDB	67.0	68.3	70.5	75.2	79.6	83.8	85.8	85.5	83.3	78.5	74.6	69.2
Mean Daily Temperature Range	5% DB	MDBR	5.7	6.3	6.9	6.9	6.8	6.8	7.3	7.0	5.8	4.9	5.0	5.5
		MCDBR	7.1	8.4	8.9	9.1	9.1	8.6	8.6	8.6	7.5	6.3	6.1	7.0
		MCWBR	5.9	6.7	7.0	6.0	5.5	4.7	4.3	4.4	4.3	4.7	4.5	5.8
	5% WB	MCDBR	6.8	8.2	8.9	8.8	9.0	8.2	8.0	7.8	7.0	6.0	5.7	6.9
		MCWBR	6.1	6.8	7.5	6.2	5.7	4.8	4.4	4.4	4.2	4.5	4.8	6.3
Clear-Sky Solar Irradiance	taub	0.548	0.585	0.677	0.674	0.587	0.548	0.511	0.529	0.520	0.529	0.533	0.539	
	taud	1.864	1.806	1.642	1.702	1.944	2.081	2.196	2.135	2.126	2.026	1.982	1.893	
	Ebn at Noon	218	222	210	216	235	243	252	247	246	235	222	214	
	Edh at Noon	57	65	80	77	61	52	47	49	49	51	50	54	
All-Sky Solar Radiation	RadAvg	586	684	937	1131	1365	1599	2045	1843	1537	1146	756	603	
	RadStd	142	161	154	173	247	178	108	140	150	154	113	118	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	+0.50	N/A	N/A	+0.68	N/A	N/A	N/A	N/A	N/A	+146

Nomenclature: See separate page