

PENGJIA YU, Taiwan

WMO: 466950

Lat: 25.628N

Lon: 122.080E

Elev: 102

StdP: 100.11

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.1	10.2	2.6	4.6	10.2	4.1	5.1	11.4	15.8	13.7	14.7	14.2	9.7	20	0.648

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.0	31.6	27.5	31.0	27.3	30.5	27.1	28.0	30.7	27.7	30.3	27.3	29.8	6.1	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	23.2	30.0	26.9	22.8	29.6	26.6	22.4	29.3	90.4	30.9	89.0	30.5	87.5	30.1	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
16.4	14.3	12.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			7.6	32.7	1.8	1.2	6.3	33.6	5.2	34.3	4.2	34.9	2.9	35.8
			5.1	28.5	2.0	0.4	3.7	28.8	2.5	29.1	1.4	29.3	0.0	29.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.2	15.6	16.2	17.5	20.7	23.7	26.5	28.3	28.2	26.8	24.1	21.1	17.3	(6)	
(7)		DBStd	5.09	2.99	3.11	3.08	2.79	2.26	1.77	0.96	1.01	1.46	1.69	2.30	2.87	(7)	
(8)		HDD10.0	2	1	1	1	0	0	0	0	0	0	0	0	0	(8)	
(9)		HDD18.3	282	92	71	52	10	0	0	0	0	0	0	4	53	(9)	
(10)		CDD10.0	4461	176	176	234	321	423	496	568	565	505	437	333	227	(10)	
(11)		CDD18.3	1699	9	12	28	82	165	246	309	307	255	178	87	22	(11)	
(12)		CDH23.3	13401	1	3	19	181	794	2176	3513	3426	2378	772	133	5	(12)	
(13)		CDH26.7	3303	0	0	0	8	104	482	1130	1058	471	48	1	0	(13)	
(14)	Wind	WSAvg	7.3	8.1	8.0	7.4	6.8	6.1	6.0	6.9	6.7	6.8	8.0	8.1	8.2	(14)	
(15)	Precipitation	PrecAvg	1942	139	145	144	155	204	201	93	215	237	148	141	133	(15)	
(16)		PrecMax	2774	455	323	216	437	586	534	377	501	1190	797	500	282	(16)	
(17)		PrecMin	889	23	17	73	17	34	32	0	2	0	0	0	2	(17)	
(18)		PrecStd	498	85	88	45	99	121	121	89	150	269	153	106	86	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.7	23.6	25.1	27.8	30.2	31.4	32.2	32.2	31.5	29.2	26.7	24.0	(19)	
(20)			MCWB	19.6	20.6	22.1	24.3	26.5	27.5	27.7	27.7	27.6	26.2	23.8	21.1	(20)	
(21)		2%	DB	21.5	22.2	23.7	26.4	28.9	30.6	31.6	31.6	30.5	27.9	25.6	22.7	(21)	
(22)			MCWB	18.8	19.6	20.9	23.5	25.8	27.2	27.6	27.4	27.0	25.1	23.1	19.8	(22)	
(23)		5%	DB	20.6	21.3	22.7	25.3	27.8	30.0	31.1	31.0	29.7	27.0	24.8	21.9	(23)	
(24)			MCWB	18.2	18.7	20.2	22.9	25.1	27.0	27.4	27.2	26.5	24.3	22.6	19.2	(24)	
(25)		10%	DB	19.7	20.5	21.8	24.2	26.7	29.2	30.5	30.3	29.0	26.2	24.0	21.0	(25)	
(26)			MCWB	17.4	18.1	19.5	22.2	24.4	26.6	27.2	27.0	26.1	23.7	21.8	18.3	(26)	
(27)		Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	21.6	22.7	24.9	26.9	28.1	28.5	28.4	28.0	26.7	24.6	21.7	(27)
(28)				MADB	21.9	22.9	24.3	27.3	29.5	30.6	31.3	31.3	30.6	28.6	25.9	23.1	(28)
(29)	2%		WB	19.4	20.1	21.8	24.0	26.0	27.6	28.1	27.9	27.5	25.7	23.9	20.5	(29)	
(30)			MADB	21.0	21.5	23.2	25.7	28.4	29.9	30.8	30.6	29.8	27.2	25.2	22.2	(30)	
(31)	5%		WB	18.6	19.3	20.8	23.3	25.3	27.1	27.7	27.5	26.9	25.0	23.1	19.7	(31)	
(32)			MADB	20.3	20.8	22.3	24.8	27.3	29.4	30.4	30.2	29.1	26.6	24.4	21.4	(32)	
(33)	10%		WB	17.7	18.6	19.8	22.6	24.7	26.7	27.4	27.2	26.4	24.2	22.2	18.8	(33)	
(34)			MADB	19.4	20.2	21.4	24.0	26.4	28.8	29.9	29.7	28.5	25.8	23.7	20.7	(34)	
(35)	Mean Daily Temperature Range		MDBR	3.1	3.5	3.8	3.8	3.8	3.8	4.0	3.9	3.2	2.7	2.8	3.0	(35)	
(36)			5% DB	MCDBR	3.9	4.6	4.9	5.1	5.1	4.8	4.8	4.8	4.1	3.5	3.4	3.9	(36)
(37)			MCWBR	3.3	3.7	3.9	3.3	3.1	2.6	2.4	2.4	2.4	2.6	2.5	3.2	(37)	
(38)		5% WB	MADB	3.8	4.6	4.9	4.9	5.0	4.6	4.5	4.3	3.9	3.4	3.2	3.9	(38)	
(39)			MCWBR	3.4	3.8	4.1	3.4	3.2	2.7	2.4	2.4	2.3	2.5	2.7	3.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.548	0.585	0.677	0.674	0.587	0.548	0.511	0.529	0.520	0.529	0.533	0.539	(40)		
(41)		taud	1.864	1.806	1.642	1.702	1.944	2.081	2.196	2.135	2.126	2.026	1.982	1.893	(41)		
(42)		Ebn at Noon	687	699	661	680	740	765	793	779	776	740	699	674	(42)		
(43)		Edh at Noon	180	204	253	243	191	165	147	156	154	162	159	169	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1.85	2.15	2.95	3.56	4.30	5.04	6.45	5.81	4.85	3.61	2.38	1.90	(44)		
(45)		RadStd	0.45	0.51	0.49	0.55	0.78	0.56	0.34	0.44	0.47	0.49	0.35	0.37	(45)		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (12 neighbors)	+0.28	N/A	N/A	+0.38	N/A	N/A	N/A	N/A	N/A	+81	(47)

Nomenclature: See separate page