

TAIPEI SONGSHAN, Taiwan

WMO: 466960

Lat: 25.069N

Lon: 121.552E

Elev: 6

StdP: 101.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	11.0	2.9	4.6	12.1	4.8	5.3	13.2	9.1	18.1	8.4	17.9	2.6	100	0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	35.8	26.8	34.8	26.5	34.0	26.5	28.2	33.0	27.7	32.2	27.2	31.5	5.0	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	30.7	26.2	21.7	30.0	26.1	21.5	29.9	90.2	33.3	88.2	32.8	86.4	31.7	32.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.1	7.3	7.5	37.5	1.6	1.0	6.3	38.2	5.4	38.8	4.4	39.3	3.2	40.1
			5.5	28.9	1.5	1.1	4.4	29.7	3.5	30.4	2.6	31.0	1.5	31.8
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	16.7	17.3	19.0	22.7	26.0	28.7	30.5	30.1	28.0	24.9	22.1	18.5
	DBStd	5.56	3.13	3.45	3.53	3.32	2.70	2.23	1.32	1.40	2.18	2.35	2.80	3.11
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	208	70	57	36	5	0	0	0	0	0	0	3	37
	CDD10.0	5016	207	203	278	380	496	561	636	623	542	463	364	262
	CDD18.3	2182	19	27	56	136	238	311	377	365	292	205	117	41
	CDH23.3	21424	34	84	236	833	2038	3543	4942	4639	3131	1363	486	94
	CDH26.7	8836	2	11	38	225	686	1524	2511	2231	1178	322	96	12
Wind	WSAvg	3.5	3.7	3.5	3.5	3.2	3.2	2.7	3.1	3.2	3.7	4.0	4.1	3.9
Precipitation	PrecAvg	2218	88	151	176	163	231	305	232	286	306	135	76	73
	PrecMax	4405	239	518	506	498	553	758	525	630	715	998	263	150
	PrecMin	1463	5	16	39	1	60	29	17	38	37	18	2	8
	PrecStd	514	51	130	101	112	117	167	107	144	187	170	49	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.1	28.2	29.9	32.9	34.8	35.9	37.1	36.8	35.2	33.1	31.2	28.1
		MCWB	19.7	20.9	22.5	24.2	26.0	26.9	27.1	27.2	26.4	25.6	23.7	21.7
	2%	DB	24.1	25.9	27.8	30.8	33.1	34.8	35.9	35.1	34.0	31.2	29.1	25.9
		MCWB	18.8	19.7	21.1	23.9	25.4	26.6	26.8	26.7	26.3	24.8	22.9	20.5
	5%	DB	22.2	23.9	26.0	29.1	31.9	33.8	34.9	34.1	33.0	29.9	27.2	24.0
		MCWB	17.9	19.0	20.3	23.2	25.0	26.4	26.6	26.6	26.0	24.3	22.3	19.9
	10%	DB	21.0	22.0	24.1	27.9	30.2	32.8	33.9	33.2	31.9	28.2	26.0	22.8
		MCWB	17.7	18.3	19.8	22.7	24.4	26.2	26.5	26.5	25.5	23.4	22.2	19.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.0	21.9	23.4	25.8	27.4	28.4	28.9	28.7	28.1	26.7	25.0	22.7
		MCDB	24.4	26.4	27.4	30.7	32.1	33.6	34.3	34.1	32.8	30.7	29.1	26.1
	2%	WB	19.7	20.5	22.2	24.8	26.5	27.6	28.1	28.1	27.3	25.7	24.1	21.6
		MCDB	22.5	24.2	26.0	29.0	30.7	32.4	33.0	32.8	31.4	29.2	27.1	24.3
	5%	WB	18.7	19.5	21.3	24.1	25.8	27.1	27.6	27.6	26.7	25.0	23.3	20.7
		MCDB	21.4	22.9	24.8	27.9	29.9	31.4	32.2	31.9	30.5	28.5	26.1	23.1
	10%	WB	18.0	18.5	20.4	23.4	25.2	26.6	27.1	27.1	26.2	24.4	22.5	19.6
		MCDB	20.4	21.5	23.6	26.7	29.0	30.7	31.5	31.2	29.9	27.5	25.3	22.2
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.8	6.6	6.8	6.7	6.8	7.2	6.9	6.1	5.3	5.3	5.2
		MCDBR	8.3	9.7	9.5	9.2	8.7	8.1	8.2	7.8	7.6	7.3	7.3	7.7
		MCWBR	4.4	4.7	4.8	4.2	3.8	3.2	3.1	3.0	2.9	3.1	3.4	4.0
	5% WB	MCDBR	7.0	8.7	8.6	8.2	7.7	7.4	7.5	7.1	6.7	6.2	6.5	6.6
		MCWBR	4.0	4.7	4.9	4.3	3.8	3.3	3.4	3.2	3.0	3.0	3.5	3.9
Clear-Sky Solar Irradiance	taub	0.557	0.593	0.693	0.695	0.602	0.563	0.535	0.552	0.537	0.541	0.541	0.553	
	taud	1.853	1.802	1.618	1.663	1.904	2.024	2.104	2.047	2.064	1.992	1.967	1.876	
	Ebn at Noon	684	696	652	666	730	754	774	761	762	731	695	665	
	Edh at Noon	183	206	260	253	198	175	161	170	164	168	162	173	
All-Sky Solar Radiation	RadAvg	2.17	2.46	3.07	3.49	4.08	4.79	5.95	5.38	4.56	3.60	2.56	2.14	
	RadStd	0.44	0.50	0.47	0.54	0.74	0.59	0.32	0.47	0.49	0.44	0.32	0.37	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	Station Only	N/A	N/A	N/A	+0.38	N/A	-0.60	N/A	N/A	N/A	N/A
	Regional (17 neighbors)	N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A	N/A	+81

Nomenclature: See separate page