

TAOYUAN, Taiwan

WMO: 466970

Lat: 25.056N

Lon: 121.243E

Elev: 151

StdP: 14.62

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	47.7	49.6	41.0	38.0	49.5	43.3	41.7	51.5	26.8	60.5	25.3	59.4	11.6	60	0.445

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.8	93.2	82.8	91.7	82.2	90.9	81.8	84.5	91.0	83.4	90.1	82.3	89.3	14.2	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.7	171.3	90.0	81.2	163.1	88.8	80.5	159.1	88.0	49.0	91.0	47.5	90.6	46.5	89.4	93.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.1	24.0	21.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			40.4	87.9	4.0	3.0	37.5	90.1	35.1	91.9	32.8	93.6	29.9	95.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.3	59.8	59.6	63.0	70.3	76.3	81.2	84.7	84.5	80.3	74.9	68.7	63.3
	DBStd	10.15	4.80	5.57	6.14	6.12	4.86	4.00	2.05	2.25	4.27	3.98	5.71	4.87
	HDD50	3	1	1	1	0	0	0	0	0	0	0	0	0
	HDD65	593	171	168	111	24	1	0	0	0	0	0	27	91
	CDD50	8137	304	270	404	610	814	937	1075	1069	909	772	561	412
	CDD65	3252	10	16	49	184	350	487	610	604	459	307	138	38
	CDH74	30186	16	46	163	902	2580	5116	7513	7235	4398	1646	501	70
	CDH80	11005	0	2	23	157	707	1882	3314	3020	1465	350	81	4
(14) Wind	WSAvg	10.2	11.9	11.3	10.2	8.5	7.3	8.0	7.8	8.7	9.6	13.5	13.9	12.4
(15) Precipitation	PrecAvg	95.1	5.0	7.3	7.2	7.0	8.7	10.8	5.9	9.3	13.9	9.1	6.2	4.8
	PrecMax	143.1	10.8	17.1	12.1	20.4	25.9	27.3	13.5	21.8	67.8	37.0	20.7	11.3
	PrecMin	41.9	1.7	1.0	3.1	1.3	0.6	2.2	0.5	0.7	0.5	0.0	0.2	0.4
	PrecStd	26.0	2.1	4.4	2.1	4.6	5.3	6.3	3.8	6.8	15.0	8.1	5.0	3.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.6	79.0	82.7	86.2	90.0	91.8	95.3	95.2	93.6	89.4	85.9	79.1
		MCWB	68.3	71.8	75.8	78.0	81.2	82.8	83.6	82.7	81.3	79.0	76.0	71.1
	2%	DB	71.9	74.9	78.6	84.0	88.1	91.0	93.3	93.2	91.4	86.2	82.3	75.5
		MCWB	65.2	68.5	72.6	76.4	80.3	82.2	83.3	82.5	80.8	77.8	74.1	69.1
	5%	DB	69.4	70.8	74.9	82.0	86.2	89.6	91.7	91.6	89.6	83.9	79.1	73.2
		MCWB	63.8	65.7	70.3	75.1	79.2	81.3	82.7	81.8	80.3	76.3	72.6	67.7
	10%	DB	66.3	67.6	71.5	79.2	84.2	88.2	90.8	90.0	87.6	81.4	76.7	70.2
		MCWB	62.6	63.8	67.6	73.4	77.8	80.5	82.2	81.2	79.6	74.7	71.5	65.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.6	72.7	77.2	79.2	83.4	85.1	86.7	85.4	83.6	80.3	77.7	73.3
		MCDB	74.7	78.2	82.4	84.9	88.8	90.3	92.4	91.9	90.0	86.6	82.8	77.7
	2%	WB	66.6	69.0	73.2	77.3	81.0	83.4	85.0	83.9	81.9	78.8	75.4	70.5
		MCDB	71.0	73.4	77.5	82.5	86.8	89.3	91.6	91.2	89.1	84.7	80.8	74.4
	5%	WB	64.7	66.3	70.7	75.6	79.5	81.9	83.7	82.7	80.8	77.2	73.5	68.5
		MCDB	68.1	70.2	74.3	80.5	85.0	88.3	90.4	90.0	87.8	82.5	78.2	71.9
	10%	WB	63.0	63.8	68.4	74.3	78.4	80.8	82.4	81.7	79.7	75.8	71.9	66.5
		MCDB	65.9	67.2	71.1	78.6	83.6	87.2	89.5	88.8	85.8	80.2	76.0	69.9
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.5	10.7	11.3	11.5	11.7	12.8	12.0	11.8	10.8	10.2	11.0
		MCDBR	16.2	16.8	16.7	14.4	14.2	12.9	13.8	13.6	14.0	13.9	14.0	14.5
		MCWBR	11.1	11.7	11.9	9.4	9.6	8.0	8.7	7.7	8.0	8.6	8.8	10.1
	5% WB	MCDBR	14.4	15.9	16.0	13.4	13.3	12.7	13.3	12.8	12.7	12.5	13.0	13.5
		MCWBR	10.7	11.7	11.8	9.3	9.4	8.5	9.4	8.1	7.9	8.8	8.7	10.3
(40) Clear-Sky Solar Irradiance	taub		0.554	0.595	0.700	0.702	0.602	0.562	0.545	0.565	0.547	0.543	0.539	0.550
	taud		1.846	1.783	1.594	1.638	1.895	2.017	2.061	1.999	2.026	1.977	1.961	1.870
	Ebn at Noon		218	220	205	210	232	239	243	238	239	231	221	212
	Edh at Noon		58	67	84	82	63	56	53	57	54	54	52	55
(44) All-Sky Solar Radiation	RadAvg		711	802	1001	1136	1323	1538	1909	1727	1472	1171	830	702
(45)	RadStd		144	158	144	171	238	187	108	153	157	142	105	120

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A	+146

Nomenclature: See separate page