

SU'AO, Taiwan

WMO: 467060

Lat: 24.597N

Lon: 121.857E

Elev: 82

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	51.4	52.8	40.0	36.4	53.5	43.1	41.1	55.9	16.7	62.3	15.5	62.3	9.0	280	0.304

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	89.7	79.7	88.7	79.4	87.8	79.1	81.3	86.9	80.7	86.7	80.0	86.1	10.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.8	155.2	85.1	78.9	150.5	84.9	78.2	146.7	84.6	45.2	87.0	44.4	86.7	43.8	86.5	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.3	15.7	13.7	DB	48.5	92.0	2.0	1.0	47.0	92.7	45.8	93.3	44.7	93.9	43.2	94.6
			WB	44.0	82.5	2.6	1.0	42.2	83.3	40.7	83.9	39.2	84.5	37.4	85.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	72.7	61.4	61.9	65.9	71.2	75.7	80.5	83.2	82.7	79.2	74.0	70.4	65.0	(6)
(7)		DBStd	8.60	4.57	5.32	5.48	5.75	4.16	3.54	1.70	1.78	2.91	3.77	4.31	4.68	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	384	129	115	56	17	1	0	0	0	0	0	9	57	(9)
(10)		CDD50	8268	353	334	494	635	796	916	1029	1014	875	743	613	466	(10)
(11)		CDD65	3176	17	28	85	202	332	466	564	549	425	278	172	58	(11)
(12)		CDH74	28154	11	23	214	1005	2281	4929	7116	6710	3964	1348	497	56	(12)
(13)		CDH80	8510	0	0	8	120	422	1621	2820	2478	874	141	26	0	(13)
(14)	Wind	WSAvg	6.1	6.8	6.6	5.6	4.9	4.7	4.8	6.6	6.7	6.7	6.8	6.5	6.7	(14)
(15)	Precipitation	PrecAvg	146.6	11.3	9.7	6.3	6.8	9.4	8.7	6.3	10.4	18.3	24.3	21.1	13.9	(15)
(16)		PrecMax	243.9	30.8	26.3	13.1	22.4	24.3	15.8	16.4	27.0	46.1	77.6	50.4	34.2	(16)
(17)		PrecMin	84.3	2.3	1.7	1.5	1.3	1.6	2.5	0.1	2.3	4.3	5.0	2.3	3.2	(17)
(18)		PrecStd	36.9	7.4	5.4	2.4	5.0	6.3	3.5	4.7	6.4	9.4	17.2	13.8	9.1	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.5	76.5	81.0	85.0	87.4	90.4	90.8	90.8	88.0	85.1	82.7	77.4	(19)
(20)		0.4%	MCWB	67.1	68.8	72.9	75.7	78.0	79.8	79.8	79.5	79.2	77.0	74.2	70.3	(20)
(21)		2%	DB	72.6	74.4	78.7	83.2	85.8	89.1	89.7	89.5	86.4	83.3	80.3	75.6	(21)
(22)		2%	MCWB	65.5	67.5	71.5	75.2	77.6	79.4	79.8	79.8	78.3	75.8	73.3	69.0	(22)
(23)		5%	DB	70.4	72.5	76.5	81.3	84.2	87.9	88.8	88.3	85.5	81.6	78.7	73.6	(23)
(24)		5%	MCWB	64.5	66.3	70.4	74.6	76.9	79.1	79.5	79.4	77.8	74.9	72.6	68.0	(24)
(25)		10%	DB	68.5	70.3	74.3	79.4	82.4	86.6	87.9	87.2	84.4	79.8	76.9	71.7	(25)
(26)		10%	MCWB	63.6	65.1	69.2	73.7	75.9	78.8	79.2	79.0	77.3	74.0	71.0	66.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.9	70.5	73.8	77.4	79.5	81.8	82.0	82.5	80.8	78.7	75.9	72.1	(27)
(28)		0.4%	MCDWB	72.3	74.6	79.3	82.3	85.1	87.0	87.9	87.0	85.2	82.9	80.3	75.7	(28)
(29)		2%	WB	67.2	69.1	72.6	76.2	78.4	80.7	81.0	81.4	79.8	77.4	74.6	70.5	(29)
(30)		2%	MCDWB	71.1	73.0	77.5	81.3	83.8	86.7	87.6	86.6	84.4	81.2	78.6	73.8	(30)
(31)		5%	WB	65.6	67.3	71.4	75.1	77.4	79.9	80.4	80.7	79.0	76.3	73.5	69.2	(31)
(32)		5%	MCDWB	69.2	71.2	75.7	80.3	82.8	86.0	87.3	86.4	83.8	80.1	77.6	72.8	(32)
(33)		10%	WB	64.1	65.6	69.9	74.1	76.5	79.2	79.8	80.0	78.2	75.2	72.3	67.5	(33)
(34)		10%	MCDWB	67.9	69.8	73.7	78.9	81.6	85.3	86.7	85.8	83.0	79.2	76.2	71.4	(34)
(35)	Mean Daily Temperature Range		MDBR	7.3	7.4	8.3	8.6	8.6	8.7	9.0	8.3	7.5	6.7	7.5	6.9	(35)
(36)		5% DB	MCDBR	11.1	11.3	11.3	11.3	10.6	10.3	10.3	9.7	9.0	9.4	10.3	10.0	(36)
(37)		5% DB	MCWBR	6.8	6.9	6.6	6.4	5.6	4.9	5.2	4.9	5.2	5.5	5.6	6.2	(37)
(38)		5% WB	MCDBR	9.3	9.6	10.8	10.3	10.0	9.6	9.7	8.8	7.9	7.5	8.4	8.4	(38)
(39)		5% WB	MCWBR	6.6	6.4	6.8	6.2	5.9	5.2	5.5	5.1	4.9	4.8	5.3	5.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.534	0.562	0.657	0.663	0.585	0.541	0.507	0.524	0.516	0.521	0.522	0.536	(40)	
(41)		taud	1.921	1.892	1.701	1.741	1.959	2.088	2.193	2.131	2.137	2.063	2.030	1.939	(41)	
(42)		Ebn at Noon	225	230	215	219	235	244	253	249	248	239	227	218	(42)	
(43)		Edh at Noon	55	60	76	74	60	52	47	50	49	50	49	52	(43)	
(44)	All-Sky Solar Radiation	RadAvg	715	830	999	1126	1329	1556	1853	1678	1453	1162	836	706	(44)	
(45)		RadStd	122	150	146	172	218	179	112	152	149	139	97	116	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (19 neighbors)	N/A	N/A	N/A	+0.58	N/A	N/A	N/A	N/A	N/A	+146	(47)

Nomenclature: See separate page