

PENGHU, Taiwan

WMO: 467350

Lat: 23.5655N

Lon: 119.5630E

Elev: 35

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	54.6	56.0	43.7	42.1	57.0	46.5	46.8	58.2	25.7	59.2	24.4	58.7	17.8	30	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	90.0	82.0	89.0	81.6	88.1	81.3	83.0	88.2	82.5	87.7	81.9	86.8	7.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.5	164.1	86.9	80.9	160.8	86.2	80.5	158.4	85.7	47.0	88.6	46.4	87.9	45.9	87.4	85.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.0	22.1	20.4	51.7	94.0	1.1	3.5	50.9	96.5	50.3	98.6	49.6	100.6	48.8	103.1		
			46.9	84.4	1.9	0.7	45.5	84.9	44.3	85.3	43.3	85.7	41.8	86.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	62.9	62.8	67.4	73.5	78.6	82.1	84.2	84.0	82.5	77.9	73.1	67.4
	DBStd	8.45	3.76	4.67	4.80	5.38	3.29	2.49	1.89	1.85	2.19	2.94	3.51	3.66
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	237	88	93	30	7	0	0	0	0	0	0	1	18
	CDD50	9034	399	357	539	704	886	964	1059	1053	975	865	694	539
	CDD65	3794	22	30	103	261	421	514	594	588	525	400	244	92
	CDH74	34111	10	33	220	1343	3357	5614	7240	7095	5785	2719	641	54
	CDH80	10125	0	0	10	170	640	1690	2843	2687	1729	320	33	3
Wind	WSAvg	10.4	13.6	12.6	10.6	9.0	7.6	7.6	6.5	7.3	9.4	13.7	13.1	13.7
Precipitation	PrecAvg	37.4	0.8	1.9	2.2	3.3	4.6	6.6	5.2	6.6	3.4	1.1	0.9	0.8
	PrecMax	57.4	3.3	12.4	10.6	17.2	10.7	13.7	16.7	25.2	15.7	8.1	5.4	3.3
	PrecMin	20.9	0.1	0.0	0.1	0.2	0.1	0.4	0.2	0.1	0.0	0.0	0.0	0.0
	PrecStd	11.5	0.7	2.4	2.2	3.2	3.0	4.3	4.4	5.6	3.7	2.0	1.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.3	77.6	81.4	85.5	88.2	90.0	91.5	91.4	90.1	86.3	83.1	78.9
		MCWB	67.6	72.2	74.6	77.9	80.0	81.8	82.8	82.5	81.7	78.7	76.1	72.8
	2%	DB	71.3	74.7	78.8	83.7	86.5	88.5	90.1	89.8	88.5	84.7	80.8	74.9
		MCWB	65.8	70.0	73.3	77.2	79.4	81.7	82.1	82.2	80.8	77.5	74.9	70.5
	5%	DB	69.2	72.4	76.5	82.1	85.0	87.5	89.1	88.8	87.5	83.2	79.1	73.2
		MCWB	64.4	68.3	72.2	76.5	78.6	81.3	81.7	81.8	80.1	76.3	73.6	68.8
	10%	DB	67.8	70.0	74.1	80.4	83.4	86.4	88.1	87.8	86.2	81.7	77.5	71.6
		MCWB	63.7	66.2	70.6	75.7	77.7	80.8	81.5	81.3	79.4	75.3	72.4	67.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.4	73.7	76.0	79.3	81.1	83.2	83.7	83.7	82.8	80.1	77.1	73.6
		MCDB	72.9	76.2	79.8	83.9	85.9	87.9	89.4	88.9	88.1	84.5	81.7	77.6
	2%	WB	66.6	71.0	74.3	78.1	80.1	82.4	82.9	83.0	81.8	78.8	75.6	71.2
		MCDB	70.5	73.7	77.8	82.4	84.8	87.2	88.4	88.2	86.7	82.9	79.4	74.6
	5%	WB	65.1	68.5	72.8	77.1	79.2	81.7	82.5	82.4	81.1	77.8	74.7	69.4
		MCDB	68.9	72.0	76.1	80.9	83.7	86.3	87.8	87.6	85.7	81.9	78.2	72.6
	10%	WB	64.1	66.3	71.1	76.1	78.4	81.1	81.9	81.8	80.5	76.7	73.6	67.8
		MCDB	67.7	70.0	74.0	79.8	82.6	85.3	86.9	86.6	84.8	80.9	77.0	71.2
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.1	6.8	6.9	7.0	6.8	7.7	7.0	6.5	5.6	5.5	5.1
		MCDBR	8.2	10.6	10.4	9.0	8.5	8.3	8.9	8.6	8.2	7.3	7.4	7.6
		MCWBR	5.0	7.3	6.7	5.1	4.2	4.3	3.9	4.0	3.8	3.9	4.5	4.8
	5% WB	MCDBR	8.4	10.6	9.9	8.5	7.9	7.7	8.4	7.8	7.5	6.9	7.2	7.5
MCWBR		5.4	8.0	6.9	5.1	4.4	4.4	4.1	4.1	3.8	3.4	4.6	5.3	
Clear-Sky Solar Irradiance	taub	0.548	0.604	0.712	0.701	0.571	0.514	0.516	0.560	0.591	0.589	0.556	0.556	
	taud	1.887	1.785	1.604	1.670	2.007	2.200	2.186	2.040	1.922	1.873	1.937	1.883	
	Ebn at Noon	223	220	204	211	239	251	251	240	229	221	219	214	
	Edh at Noon	57	67	84	80	57	47	47	55	60	61	54	56	
All-Sky Solar Radiation	RadAvg	858	987	1189	1398	1624	1762	1976	1748	1647	1395	1009	866	
	RadStd	140	167	141	180	209	177	140	207	154	133	133	106	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (19 neighbors)	+0.50	N/A	N/A	+0.36	+0.45	+0.45	N/A	N/A	+229	+214	

Nomenclature: See separate page