

PENGHU, Taiwan

WMO: 467350

Lat: 23.5655N

Lon: 119.5630E

Elev: 11

StdP: 101.20

Time Zone: 8.00 (E08)

Period: 90-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	13.3	6.5	6.0	13.9	8.0	6.7	14.6	11.5	15.1	10.9	14.8	7.9	30	0.435

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.3	32.2	27.8	31.7	27.6	31.2	27.4	28.3	31.2	28.1	30.9	27.7	30.4	3.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.5	23.4	30.5	27.2	23.0	30.1	26.9	22.6	29.8	91.4	31.4	90.1	31.1	88.8	30.8	29.8

Extreme Annual Design Conditions

Extreme Annual WS							Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature											
							Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years					
							Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max				
1%	2.5%	5%																				
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)							
10.7	9.9	9.1	DB	11.0	34.5	0.6	2.0	10.5	35.9	10.1	37.0	9.8	38.1	9.3	39.5							
			WB	8.3	29.1	1.1	0.4	7.5	29.4	6.9	29.6	6.3	29.8	5.5	30.1							

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.7	17.2	17.1	19.7	23.0	25.9	27.8	29.0	28.9	28.1	25.5	22.8	19.7
	DBStd	4.69	2.09	2.59	2.67	2.99	1.83	1.38	1.05	1.03	1.22	1.63	1.95	2.03
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	132	49	52	17	4	0	0	0	0	0	0	1	10
	CDD10.0	5019	222	198	299	391	492	536	588	585	542	481	386	299
	CDD18.3	2108	12	17	57	145	234	286	330	327	292	222	136	51
	CDH23.3	18951	6	18	122	746	1865	3119	4022	3942	3214	1511	356	30
CDH26.7	5625	0	0	6	94	356	939	1579	1493	961	178	18	2	
Wind	WSAvg	4.6	6.1	5.6	4.7	4.0	3.4	3.4	2.9	3.3	4.2	6.1	5.9	6.1
Precipitation	PrecAvg	950	21	47	57	85	116	168	131	167	87	29	22	21
	PrecMax	1458	83	315	268	436	272	349	423	640	400	205	138	84
	PrecMin	531	3	0	2	6	2	10	6	3	1	0	0	0
	PrecStd	291	17	61	57	81	76	109	111	141	93	51	27	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	25.3	27.4	29.7	31.2	32.2	33.1	33.0	32.3	30.2	28.4	26.1
		MCWB	19.8	22.3	23.7	25.5	26.6	27.6	28.2	28.1	27.6	25.9	24.5	22.7
	2%	DB	21.8	23.7	26.0	28.7	30.3	31.4	32.3	32.1	31.4	29.3	27.1	23.9
		MCWB	18.8	21.1	23.0	25.1	26.3	27.6	27.8	27.9	27.1	25.3	23.8	21.4
	5%	DB	20.7	22.4	24.7	27.8	29.4	30.8	31.7	31.6	30.8	28.4	26.2	22.9
		MCWB	18.0	20.2	22.4	24.7	25.9	27.4	27.6	27.7	26.7	24.6	23.1	20.5
	10%	DB	19.9	21.1	23.4	26.9	28.6	30.2	31.2	31.0	30.1	27.6	25.3	22.0
		MCWB	17.6	19.0	21.4	24.3	25.4	27.1	27.5	27.4	26.3	24.1	22.5	19.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.2	23.2	24.4	26.3	27.3	28.4	28.7	28.7	28.2	26.7	25.0	23.1
		MCDB	22.7	24.6	26.6	28.8	29.9	31.0	31.9	31.6	31.2	29.2	27.6	25.3
	2%	WB	19.2	21.7	23.5	25.6	26.7	28.0	28.3	28.3	27.7	26.0	24.2	21.8
		MCDB	21.4	23.2	25.4	28.0	29.3	30.7	31.3	31.2	30.4	28.3	26.3	23.7
	5%	WB	18.4	20.3	22.7	25.0	26.2	27.6	28.0	28.0	27.3	25.5	23.7	20.8
		MCDB	20.5	22.2	24.5	27.2	28.7	30.1	31.0	30.9	29.8	27.7	25.7	22.6
	10%	WB	17.8	19.0	21.7	24.5	25.8	27.3	27.7	27.7	26.9	24.9	23.1	19.9
		MCDB	19.8	21.1	23.3	26.5	28.1	29.6	30.5	30.3	29.3	27.2	25.0	21.8
Mean Daily Temperature Range	5% DB	MDBR	2.9	3.4	3.8	3.9	3.9	3.8	4.3	3.9	3.6	3.1	3.1	2.8
		MCDBR	4.5	5.9	5.8	5.0	4.7	4.6	4.9	4.8	4.5	4.0	4.1	4.2
		MCWBR	2.8	4.0	3.7	2.8	2.3	2.4	2.2	2.2	2.1	2.2	2.5	2.7
	5% WB	MCDBR	4.6	5.9	5.5	4.7	4.4	4.3	4.6	4.4	4.2	3.8	4.0	4.1
MCWBR		3.0	4.5	3.8	2.9	2.4	2.4	2.3	2.3	2.1	1.9	2.6	2.9	
Clear-Sky Solar Irradiance	taub		0.548	0.604	0.712	0.701	0.571	0.514	0.516	0.560	0.591	0.589	0.556	0.556
	taud		1.887	1.785	1.604	1.670	2.007	2.200	2.186	2.040	1.922	1.873	1.937	1.883
	Ebn at Noon		702	694	643	664	754	792	790	757	723	696	691	674
	Edh at Noon		180	212	265	252	179	147	149	172	190	191	170	175
All-Sky Solar Radiation	RadAvg		2.71	3.11	3.75	4.41	5.12	5.56	6.23	5.51	5.19	4.40	3.18	2.73
	RadStd		0.44	0.53	0.44	0.57	0.66	0.56	0.44	0.65	0.49	0.42	0.42	0.34

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (19 neighbors)	+0.28	N/A	N/A	+0.20	+0.25	+0.25	N/A	N/A	+127	+119

Nomenclature: See separate page