

KAOHSIUNG INTL, Taiwan

WMO: 467400

Lat: 22.577N

Lon: 120.350E

Elev: 8

StdP: 101.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	13.8	6.2	5.9	15.1	8.1	6.7	15.8	7.5	17.1	6.8	18.5	3.0	0	0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.9	33.5	26.8	33.1	26.8	32.4	26.5	28.1	31.1	27.7	30.8	27.4	30.7	5.4	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.2	22.9	30.0	27.0	22.7	29.9	26.2	21.7	29.5	89.8	31.8	88.1	31.4	87.0	30.8	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.3	7.1	6.2		10.0	35.1	1.9	0.8	8.7	35.6	7.6	36.1	6.5	36.6	5.1	37.2
				7.7	29.1	2.2	0.7	6.1	29.6	4.9	30.0	3.6	30.4	2.1	30.9
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	20.2	21.1	23.2	25.9	27.9	28.8	29.3	28.8	28.5	27.0	24.8	21.5
	DBStd	3.75	2.49	2.84	2.64	2.08	1.48	1.47	1.22	1.24	1.13	1.43	1.87	2.52
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	28	12	8	3	0	0	0	0	0	0	0	0	6
	CDD10.0	5687	315	309	408	477	553	564	597	582	554	527	444	356
	CDD18.3	2674	68	84	152	227	295	314	339	324	304	269	195	103
	CDH23.3	27172	268	437	990	2052	3298	3886	4298	3916	3523	2683	1368	452
	CDH26.7	9869	27	69	209	588	1195	1669	1934	1616	1372	821	308	61
Wind	WSAvg	3.0	2.8	2.9	2.9	2.9	2.9	3.3	3.5	3.5	3.1	2.7	2.5	2.7
Precipitation	PrecAvg	1798	15	21	22	68	154	396	372	413	229	62	28	19
	PrecMax	2753	56	93	99	241	631	984	803	1200	785	278	202	154
	PrecMin	951	0	0	0	0	2	33	4	106	53	0	0	0
	PrecStd	492	16	25	30	72	126	273	214	298	176	75	45	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.0	30.1	31.2	32.2	33.2	34.2	34.2	34.0	33.7	32.6	31.2	29.9
		MCWB	21.7	22.8	24.0	25.0	26.2	26.9	26.9	27.1	27.0	26.2	24.4	22.5
	2%	DB	27.2	28.8	30.0	31.2	32.2	33.2	33.7	33.1	32.9	31.8	30.1	28.1
		MCWB	20.9	22.2	23.7	24.8	25.9	26.8	26.9	27.0	26.8	25.9	24.0	21.6
	5%	DB	26.1	27.2	29.0	30.4	31.9	32.8	33.0	32.2	32.1	31.0	29.2	27.1
		MCWB	19.9	21.4	22.9	24.5	25.8	26.7	26.9	26.8	26.4	25.6	23.4	21.1
	10%	DB	24.9	26.0	27.9	29.9	31.0	32.0	32.2	31.9	31.2	30.1	28.4	26.0
		MCWB	19.5	20.8	22.2	24.2	25.7	26.5	26.7	26.7	26.3	25.0	22.9	20.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.3	24.3	25.3	26.7	27.7	28.3	28.6	28.5	28.2	27.4	26.0	23.7
		MCDB	27.1	27.8	29.1	30.0	30.4	31.3	32.0	31.6	31.5	30.6	29.8	27.6
	2%	WB	21.9	23.4	24.4	25.9	27.2	27.7	28.0	27.9	27.5	26.7	25.1	22.7
		MCDB	26.1	27.0	28.4	29.4	30.4	30.8	31.1	30.9	30.9	29.8	28.6	26.5
	5%	WB	20.9	22.4	23.7	25.2	26.6	27.4	27.6	27.5	27.1	26.3	24.5	22.1
		MCDB	24.8	26.3	27.6	29.1	30.0	30.7	30.9	30.6	30.5	29.4	27.8	25.8
	10%	WB	19.9	21.2	22.9	24.7	26.2	27.0	27.2	27.2	26.7	25.8	23.8	21.2
		MCDB	23.8	25.3	26.7	28.7	29.6	30.6	30.7	30.4	30.0	28.9	27.2	24.7
Mean Daily Temperature Range	5% DB	MDBR	8.6	8.4	7.9	6.8	6.0	5.6	5.9	5.8	6.2	6.3	7.3	8.1
		MCDBR	9.6	9.3	8.8	7.4	6.7	6.5	6.7	6.5	6.9	6.7	7.8	8.9
		MCWBR	4.7	4.7	4.4	3.4	2.9	2.8	2.9	3.0	3.0	3.0	3.5	4.2
	5% WB	MCDBR	8.6	8.6	7.9	6.8	6.0	5.7	5.9	6.0	6.3	5.9	6.9	7.9
		MCWBR	4.6	4.8	4.3	3.4	3.0	2.9	3.0	3.1	3.0	2.9	3.4	4.1
Clear-Sky Solar Irradiance	taub	0.509	0.544	0.662	0.645	0.530	0.494	0.496	0.549	0.583	0.591	0.519	0.529	
	taud	2.018	1.947	1.701	1.782	2.122	2.252	2.239	2.061	1.936	1.871	2.057	1.978	
	Ebn at Noon	746	749	682	705	785	808	806	767	731	699	732	707	
	Edh at Noon	159	181	241	226	160	139	141	169	188	193	152	161	
All-Sky Solar Radiation	RadAvg	3.45	4.05	4.44	4.87	5.15	5.40	5.69	5.06	4.94	4.55	3.70	3.27	
	RadStd	0.34	0.41	0.38	0.47	0.56	0.60	0.48	0.55	0.43	0.27	0.27	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.37	N/A	N/A	N/A	+0.42	+0.55	N/A	N/A	+130	+124
(47)	Regional (19 neighbors)	+0.24	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+116	+110

Nomenclature: See separate page