

TAINAN AP, Taiwan

WMO: 467430

Lat: 22.950N

Lon: 120.206E

Elev: 63

StdP: 14.66

Time Zone: 8.00 (E08)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	51.4	53.5	41.0	38.0	55.0	44.8	44.0	56.4	24.7	59.4	22.1	59.7	10.6	10	0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.9	91.8	81.6	91.3	81.4	89.9	80.5	83.4	89.8	82.6	88.9	81.9	88.1	11.6	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.4	163.6	87.9	80.8	160.2	87.3	80.3	157.6	86.8	47.4	90.6	46.7	89.1	45.9	88.4	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	17.9	16.0	DB	43.9	95.0	6.0	3.4	39.5	97.5	36.0	99.5	32.6	101.4	28.2	103.8	(4)
(5)			WB	40.4	85.0	5.9	1.8	36.2	86.3	32.7	87.4	29.4	88.4	25.1	89.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.2	65.8	66.5	70.6	76.5	80.5	83.0	83.6	82.8	82.2	79.0	74.1	68.8
	DBStd	7.49	4.60	5.63	5.21	4.52	2.97	2.46	2.17	2.69	2.23	3.02	3.78	4.32
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD65	127	45	46	16	2	0	0	0	0	0	1	17	
	CDD50	9550	490	461	638	796	947	990	1040	1018	967	900	722	581
	CDD65	4201	69	87	189	348	482	540	575	553	517	435	273	133
	CDH74	39690	248	410	1060	2730	4769	6243	6746	6202	5570	3672	1523	517
	CDH80	14004	15	55	200	789	1644	2485	2797	2384	2075	1182	320	58
Wind	WSAvg	7.3	9.5	9.0	7.9	6.7	5.9	6.5	6.5	6.7	6.4	6.8	7.6	8.9
Precipitation	PrecAvg	62.4	0.7	1.1	1.5	2.9	6.4	13.9	12.8	15.7	5.7	1.1	0.6	0.4
	PrecMax	122.5	4.1	4.3	6.8	11.8	16.4	56.7	40.9	59.4	19.2	6.4	3.4	1.5
	PrecMin	20.9	0.0	0.0	0.0	0.0	0.0	1.9	1.7	1.1	0.3	0.0	0.0	0.0
	PrecStd	20.6	0.8	1.3	1.7	2.9	4.7	10.4	8.3	11.1	5.2	1.8	0.8	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.2	84.3	86.2	90.0	91.7	93.4	93.5	92.9	92.0	90.1	87.5	84.4
		MCWB	70.8	72.7	75.5	79.0	81.0	82.1	82.5	83.0	81.5	79.0	76.3	73.3
	2%	DB	79.1	82.0	84.3	88.0	89.9	91.6	91.7	91.4	90.6	89.2	85.2	81.9
		MCWB	68.9	71.4	74.6	78.1	79.6	81.5	81.7	82.1	80.6	78.8	75.5	71.5
	5%	DB	77.0	79.1	82.5	86.2	88.3	90.0	91.1	89.9	89.6	87.7	83.9	79.0
		MCWB	67.6	69.6	72.9	76.9	78.9	80.7	81.4	81.1	80.1	78.2	74.0	69.7
	10%	DB	73.8	76.3	80.4	84.5	87.5	89.4	89.7	89.1	88.1	86.0	82.1	77.0
		MCWB	65.6	67.9	71.2	75.9	78.6	80.4	80.6	80.8	79.6	76.7	72.5	68.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.6	75.2	77.8	80.5	82.8	84.1	84.1	84.5	83.6	81.0	78.2	75.4
		MCDB	80.0	81.6	84.2	87.9	88.9	90.7	91.4	90.4	89.4	88.4	85.1	82.6
	2%	WB	70.0	72.6	76.0	79.2	81.4	82.8	83.0	83.3	82.3	79.8	76.4	72.7
		MCDB	77.2	79.2	82.6	86.1	87.8	89.1	89.9	89.3	88.5	86.8	83.7	79.3
	5%	WB	68.4	70.6	74.4	78.1	80.1	81.9	82.2	82.4	81.4	78.8	74.8	70.9
		MCDB	75.3	77.3	80.6	84.7	86.5	88.2	88.9	88.3	87.6	85.5	81.7	77.2
	10%	WB	66.7	68.8	72.5	76.8	79.2	81.1	81.4	81.5	80.4	77.8	73.5	69.2
		MCDB	73.3	75.4	78.2	83.1	85.1	87.3	87.9	87.0	86.5	84.1	79.5	75.4
Mean Daily Temperature Range	5% DB	MDBR	16.3	16.6	15.9	14.3	12.6	11.5	11.9	11.0	12.5	14.5	15.5	16.3
		MCDBR	18.7	18.9	17.4	15.2	13.8	12.9	13.6	12.6	13.6	14.9	16.1	17.7
		MCWBR	10.6	10.9	9.5	8.4	7.1	6.4	6.8	6.7	7.1	7.5	8.1	9.9
	5% WB	MCDBR	17.8	18.5	16.1	14.5	12.9	12.0	12.4	11.7	12.5	13.8	15.0	16.8
		MCWBR	11.0	11.6	9.9	8.9	7.7	6.8	6.9	7.0	7.4	7.4	8.3	10.3
Clear-Sky Solar Irradiance	taub	0.507	0.551	0.665	0.656	0.542	0.497	0.502	0.555	0.595	0.600	0.525	0.524	
	taud	2.005	1.918	1.687	1.754	2.079	2.235	2.213	2.036	1.900	1.839	2.022	1.972	
	Ebn at Noon	237	235	215	221	246	255	254	241	229	219	230	225	
	Edh at Noon	51	59	77	74	53	45	46	55	62	63	50	51	
All-Sky Solar Radiation	RadAvg	1057	1219	1348	1489	1609	1693	1815	1620	1575	1440	1143	1018	
	RadStd	117	144	129	161	184	180	144	179	136	92	95	105	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)	+0.43	N/A	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+209

Nomenclature: See separate page