

KAOHSIUNG, Taiwan

WMO: **467440**Lat: **22.5659N**Lon: **120.3157E**Elev: **8**StdP: **14.69**Time Zone: **8.00 (E08)**Period: **90-98**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.2	57.3	44.0	42.4	58.7	47.3	48.3	60.2	14.2	68.6	12.9	69.4	5.7	10	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.7	90.9	80.9	90.0	80.7	89.1	80.5	82.6	88.8	81.9	88.1	81.3	87.5	9.2	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	160.4	86.8	80.1	156.3	86.3	79.6	153.4	85.9	46.5	89.1	45.7	88.3	45.1	87.7	
(p)															

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.4	12.3	11.1	50.7	95.9	2.2	4.8	49.1	99.3	47.9	102.1	46.6	104.8	45.1	108.3
			46.7	83.8	3.5	0.7	44.1	84.4	42.1	84.8	40.1	85.2	37.6	85.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.4	67.0	68.4	73.1	77.7	81.4	83.5	84.6	83.9	82.6	79.5	75.6	70.8
	DBStd	6.86	4.07	4.32	4.65	4.54	2.63	2.72	2.09	2.10	1.88	2.58	3.08	3.92
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	55	28	15	3	2	0	0	0	0	0	0	0	7
	CDD50	9996	528	515	716	830	973	1004	1072	1051	978	914	769	646
	CDD65	4575	91	109	254	382	508	554	607	586	528	449	319	188
	CDH74	45365	186	365	1435	3202	5543	6792	7838	7243	6150	4135	1883	593
	CDH80	15055	3	20	187	704	1724	2747	3478	2941	2096	909	212	34
(14) Wind	WSAvg	5.0	5.4	5.1	5.1	5.0	5.0	5.2	5.7	5.7	4.9	4.3	4.2	4.6
(15) Precipitation	PrecAvg	70.8	0.6	0.8	0.9	2.7	6.1	15.6	14.6	16.3	9.0	2.4	1.1	0.7
	PrecMax	108.4	2.2	3.7	3.9	9.5	24.8	38.7	31.6	47.2	30.9	10.9	8.0	6.1
	PrecMin	37.4	0.0	0.0	0.0	0.0	0.1	1.3	0.2	4.2	2.1	0.0	0.0	0.0
	PrecStd	19.4	0.6	1.0	1.2	2.8	5.0	10.7	8.4	11.7	6.9	3.0	1.8	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.2	82.3	85.3	88.2	89.9	92.1	93.2	91.9	90.2	87.5	85.3	82.8
		MCWB	69.2	71.9	75.4	77.4	80.2	81.1	81.0	82.0	79.7	78.9	75.9	73.0
	2%	DB	77.8	80.3	83.7	86.5	88.7	90.6	91.0	90.3	88.9	86.3	83.7	80.7
		MCWB	67.6	71.3	74.8	77.0	79.7	80.9	80.8	81.2	79.9	78.1	74.9	71.8
	5%	DB	76.1	78.3	82.2	85.3	87.5	89.4	90.0	89.2	87.9	85.2	82.3	78.9
		MCWB	66.7	70.2	73.7	76.6	79.0	80.7	80.8	80.8	79.4	77.3	73.7	69.8
	10%	DB	74.5	76.4	80.5	83.9	86.3	88.3	89.1	88.2	86.8	84.1	81.1	77.2
		MCWB	65.7	68.7	72.6	76.1	78.3	80.3	80.6	80.3	78.9	76.5	72.9	69.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.7	75.0	76.9	79.7	81.6	83.4	83.5	83.3	82.4	80.5	77.5	75.1
		MCDB	78.0	79.2	83.4	85.8	88.1	89.0	88.9	89.8	86.7	86.0	82.9	81.1
	2%	WB	68.7	73.1	75.6	78.3	80.5	82.1	82.6	82.4	81.3	79.3	76.2	73.4
		MCDB	76.4	79.0	81.9	84.1	87.2	88.5	88.9	88.6	86.5	84.8	82.2	78.8
	5%	WB	67.4	71.1	74.6	77.4	79.7	81.5	81.8	81.6	80.6	78.4	75.1	71.8
		MCDB	74.9	77.3	80.9	83.5	86.2	87.8	88.3	87.6	86.4	83.8	80.9	77.3
	10%	WB	66.2	68.9	73.4	76.6	78.9	80.8	81.2	81.0	79.8	77.5	74.0	70.2
		MCDB	73.4	75.9	80.0	82.9	85.3	87.1	87.6	86.6	85.5	82.8	79.9	76.0
(35) Mean Daily Temperature Range	5% DB	MDBR	12.6	12.0	11.4	10.0	8.7	8.1	8.7	8.4	8.4	8.8	10.2	11.9
		MCDBR	13.5	13.6	12.0	10.4	9.7	9.5	9.9	9.7	9.2	9.1	10.6	12.7
		MCWBR	7.8	8.6	7.5	5.6	5.5	5.3	5.5	5.0	4.6	5.1	6.1	7.4
		MCDBR	13.1	12.7	11.2	9.6	9.3	8.9	9.2	9.0	8.7	8.2	9.4	11.1
	5% WB	MCWBR	8.0	9.0	8.0	5.7	5.7	5.5	5.7	5.0	4.9	4.8	5.7	7.1
(40) Clear-Sky Solar Irradiance	taub		0.509	0.545	0.661	0.643	0.529	0.492	0.494	0.546	0.581	0.591	0.520	0.530
	taud		2.019	1.947	1.705	1.787	2.130	2.259	2.246	2.070	1.944	1.874	2.057	1.977
	Ebn at Noon		237	238	216	224	249	257	256	244	233	222	232	224
	Edh at Noon		50	57	76	71	50	44	44	53	59	61	48	51
(44) All-Sky Solar Radiation	RadAvg		1092	1280	1406	1548	1639	1717	1811	1610	1572	1445	1172	1035
	RadStd		110	131	121	149	176	190	154	177	138	85	86	105

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (19 neighbors)	+0.43	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+209	+198