

KAOHSIUNG, Taiwan

WMO: **467440**Lat: **22.5659N**Lon: **120.3157E**Elev: **2**StdP: **101.30**Time Zone: **8.00 (E08)**Period: **90-98**WBAN: **99999**

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	14.1	6.6	6.1	14.8	8.5	6.9	15.6	6.4	20.3	5.8	20.8	2.5	10	0.295

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.8	32.7	27.2	32.2	27.1	31.7	26.9	28.1	31.5	27.7	31.2	27.4	30.8	4.1	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	22.9	30.4	26.7	22.3	30.2	26.4	21.9	30.0	90.3	31.7	88.5	31.3	87.1	30.9	29.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.4	5.5	5.0	10.4	35.5	1.2	2.7	9.5	37.4	8.8	39.0	8.1	40.4	7.3	42.4
			8.1	28.8	1.9	0.4	6.7	29.1	5.6	29.3	4.5	29.6	3.1	29.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.2	19.5	20.2	22.8	25.4	27.4	28.6	29.2	28.8	28.1	26.4	24.2	21.6
	DBStd	3.81	2.26	2.40	2.58	2.52	1.46	1.51	1.16	1.17	1.05	1.44	1.71	2.18
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	31	16	8	2	1	0	0	0	0	0	0	0	4
	CDD10.0	5553	293	286	398	461	541	558	596	584	543	508	427	359
	CDD18.3	2542	51	61	141	212	282	308	337	326	293	249	177	104
	CDH23.3	25203	103	203	797	1779	3079	3773	4354	4024	3417	2297	1046	329
	CDH26.7	8364	2	11	104	391	958	1526	1932	1634	1164	505	118	19
(14) Wind	WSAvg	2.2	2.4	2.3	2.3	2.2	2.2	2.3	2.5	2.5	2.2	1.9	1.9	2.1
(15) Precipitation	PrecAvg	1798	15	21	22	68	154	396	372	413	229	62	28	19
	PrecMax	2753	56	93	99	241	631	984	803	1200	785	278	202	154
	PrecMin	951	0	0	0	0	2	33	4	106	53	0	0	0
	PrecStd	492	16	25	30	72	126	273	214	298	176	75	45	33
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.8	27.9	29.6	31.2	32.2	33.4	34.0	33.3	32.4	30.8	29.6	28.2
		MCWB	20.7	22.2	24.1	25.2	26.8	27.3	27.2	27.8	26.5	26.0	24.4	22.8
	2%	DB	25.5	26.8	28.7	30.3	31.5	32.6	32.8	32.4	31.6	30.2	28.7	27.1
		MCWB	19.8	21.8	23.8	25.0	26.5	27.2	27.1	27.3	26.6	25.6	23.8	22.1
	5%	DB	24.5	25.7	27.9	29.6	30.8	31.9	32.2	31.8	31.0	29.6	28.0	26.0
		MCWB	19.3	21.2	23.2	24.8	26.1	27.0	27.1	27.1	26.3	25.2	23.2	21.0
	10%	DB	23.6	24.7	26.9	28.8	30.2	31.3	31.7	31.2	30.5	29.0	27.3	25.1
		MCWB	18.7	20.4	22.6	24.5	25.7	26.8	27.0	26.8	26.1	24.7	22.7	20.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.5	23.9	24.9	26.5	27.6	28.5	28.6	28.5	28.0	26.9	25.3	23.9
		MCDB	25.5	26.2	28.5	29.9	31.2	31.7	31.6	32.1	30.4	30.0	28.3	27.3
	2%	WB	20.4	22.8	24.2	25.7	27.0	27.9	28.1	28.0	27.4	26.3	24.6	23.0
		MCDB	24.7	26.1	27.7	28.9	30.7	31.4	31.6	31.5	30.3	29.3	27.9	26.0
	5%	WB	19.7	21.7	23.7	25.2	26.5	27.5	27.7	27.6	27.0	25.8	24.0	22.1
		MCDB	23.8	25.2	27.2	28.6	30.1	31.0	31.3	30.9	30.2	28.8	27.1	25.2
	10%	WB	19.0	20.5	23.0	24.8	26.1	27.1	27.3	27.2	26.5	25.3	23.3	21.2
		MCDB	23.0	24.4	26.7	28.3	29.6	30.6	30.9	30.3	29.7	28.2	26.6	24.5
(35) Mean Daily Temperature Range	5% DB	MDBR	7.0	6.7	6.3	5.5	4.8	4.5	4.8	4.7	4.7	4.9	5.7	6.6
		MCDBR	7.5	7.5	6.7	5.8	5.4	5.3	5.5	5.4	5.1	5.1	5.9	7.1
	5% WB	MCWBR	4.3	4.8	4.2	3.1	3.0	2.9	3.1	2.8	2.6	2.8	3.4	4.1
		MCWBR	7.3	7.1	6.2	5.3	5.2	5.0	5.1	5.0	4.8	4.6	5.2	6.2
(40) Clear-Sky Solar Irradiance	taub		0.509	0.545	0.661	0.643	0.529	0.492	0.494	0.546	0.581	0.591	0.520	0.530
		taud	2.019	1.947	1.705	1.787	2.130	2.259	2.246	2.070	1.944	1.874	2.057	1.977
	Ebn at Noon		746	749	682	706	786	809	807	768	733	699	731	707
		Edh at Noon	159	181	240	225	159	138	140	167	187	192	152	161
(44) All-Sky Solar Radiation	RadAvg		3.44	4.04	4.43	4.88	5.17	5.41	5.71	5.08	4.96	4.55	3.69	3.26
	RadStd		0.35	0.41	0.38	0.47	0.56	0.60	0.48	0.56	0.43	0.27	0.27	0.33

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (19 neighbors)		+0.24	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+116

Nomenclature: See separate page