

TAICHUNG, Taiwan

WMO: 467490

Lat: 24.1457N

Lon: 120.6840E

Elev: 84

StdP: 100.32

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	11.3	3.6	4.9	12.7	5.4	5.6	13.3	5.6	16.9	4.9	17.3	2.0	10	0.280

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.4	33.6	26.5	33.0	26.3	32.5	26.1	27.5	32.1	27.0	31.7	26.7	31.2	2.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.8	30.1	25.7	21.2	29.8	25.4	20.7	29.6	87.9	32.2	85.9	31.8	84.2	31.4	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.8	4.2	3.7	8.0	35.2	1.7	1.2	6.8	36.1	5.8	36.8	4.8	37.5	3.6	38.4		
(5)			5.9	28.2	1.6	0.4	4.8	28.6	3.9	28.8	3.0	29.1	1.9	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	24.1	17.6	18.2	20.5	23.9	26.5	28.3	29.1	28.7	28.1	26.1	23.1	19.2	(6)
(7)		DBStd	4.72	2.75	3.26	3.16	2.76	1.95	1.65	1.30	1.31	1.43	1.79	2.29	2.73	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	127	46	39	16	2	0	0	0	0	0	0	1	23	(9)
(10)		CDD10.0	5163	235	231	324	418	513	548	592	578	544	500	393	286	(10)
(11)		CDD18.3	2248	23	36	82	170	254	298	334	320	294	242	144	51	(11)
(12)		CDH23.3	21373	58	122	369	1129	2364	3391	4102	3748	3248	1989	715	137	(12)
(13)	CDH26.7	7661	3	12	57	254	740	1346	1824	1518	1209	563	124	11	(13)	
(14)	Wind	WSAvg	1.8	1.9	1.9	1.8	1.7	1.7	1.8	1.9	1.7	1.8	1.9	1.8	1.9	(14)
(15)	Precipitation	PrecAvg	1603	33	77	95	116	214	347	233	315	108	15	17	21	(15)
(16)		PrecMax	2338	123	384	352	473	541	890	643	785	576	129	74	84	(16)
(17)		PrecMin	979	4	3	3	0	6	46	21	74	5	0	0	0	(17)
(18)		PrecStd	353	27	94	72	99	120	218	151	170	108	23	21	22	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.8	28.3	29.9	31.5	33.1	34.1	34.5	34.0	33.6	32.4	30.5	28.1	(19)
MCWB			19.6	21.3	22.8	24.5	25.9	26.7	26.7	26.9	26.3	25.6	23.6	20.8	(20)	
2%		DB	24.9	26.4	28.2	30.3	32.1	33.2	33.6	33.2	32.7	31.3	29.2	26.2	(21)	
		MCWB	18.6	20.2	21.9	23.8	25.4	26.4	26.6	26.5	26.1	25.0	22.9	20.0	(22)	
5%		DB	23.4	24.9	26.9	29.2	31.3	32.6	33.0	32.5	32.0	30.5	28.2	24.9	(23)	
		MCWB	18.0	19.1	21.1	23.3	25.1	26.2	26.4	26.3	25.8	24.4	22.3	19.2	(24)	
10%		DB	21.8	23.3	25.5	28.2	30.3	31.8	32.4	31.9	31.3	29.6	27.0	23.6	(25)	
		MCWB	17.1	18.5	20.3	22.8	24.5	25.9	26.2	26.1	25.5	23.8	21.4	18.5	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.9	22.2	23.7	25.4	27.2	27.7	28.1	27.4	26.6	24.7	22.2	(27)	
MCDWB			24.7	26.7	28.5	30.2	31.9	32.9	32.5	32.2	32.1	31.5	28.8	26.5	(28)	
2%		WB	19.6	21.0	22.7	24.5	26.2	27.1	27.3	27.4	26.8	25.8	23.8	21.1	(29)	
		MCDWB	23.5	24.9	26.8	28.9	30.8	32.1	32.0	31.7	31.3	30.0	27.7	24.6	(30)	
5%		WB	18.7	20.0	21.9	23.9	25.6	26.6	26.9	26.9	26.4	25.2	23.1	20.1	(31)	
		MCDWB	22.2	23.7	25.7	28.1	30.0	31.4	31.7	31.2	30.7	29.3	26.9	23.7	(32)	
10%		WB	17.8	18.8	21.0	23.3	25.1	26.1	26.5	26.5	26.0	24.6	22.4	19.3	(33)	
		MCDWB	21.1	22.8	24.8	27.3	29.2	30.7	31.1	30.6	30.2	28.6	26.0	22.7	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.4	7.1	7.3	6.7	6.2	6.0	6.4	6.0	6.3	6.8	7.2	7.4	(35)
MCDBR			9.5	9.6	8.9	7.7	7.3	7.2	7.1	7.0	7.0	7.3	8.2	9.0	(36)	
MCWBR			4.5	4.6	4.2	3.4	3.2	3.2	2.9	2.9	2.7	3.2	3.6	4.3	(37)	
5% WB		MCDWB	8.3	8.8	7.9	7.0	6.4	6.6	6.7	6.4	6.4	6.3	7.1	7.5	(38)	
		MCWBR	4.3	4.7	4.1	3.4	3.1	3.2	3.0	2.9	2.7	2.9	3.4	3.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.492	0.547	0.669	0.681	0.584	0.536	0.549	0.585	0.579	0.541	0.503	0.494	(40)	
taud		2.010	1.895	1.649	1.678	1.936	2.084	2.037	1.929	1.923	1.971	2.061	2.023	(41)		
Ebn at Noon		752	739	672	677	744	774	764	737	731	735	738	731	(42)		
Edh at Noon		158	189	253	250	192	165	173	192	189	172	149	151	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2.91	3.22	3.69	4.05	4.63	5.11	5.81	5.26	4.84	4.29	3.23	2.87	(44)	
(45)		RadStd	0.39	0.46	0.41	0.55	0.69	0.56	0.37	0.51	0.46	0.36	0.30	0.35	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (28 neighbors)	+0.25	N/A	N/A	+0.22	N/A	N/A	N/A	N/A	+127	+112

Nomenclature: See separate page