

PINGTUNG SOUTH, Taiwan

WMO: 467500

Lat: 22.672N

Lon: 120.462E

Elev: 78

StdP: 14.65

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	53.3	55.3	48.1	49.9	56.9	50.4	54.3	58.8	15.7	75.3	13.8	74.5	1.2	330	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	94.9	81.2	93.5	80.8	92.7	80.5	83.0	91.4	82.2	90.5	81.5	89.5	10.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	160.7	87.6	80.2	157.3	86.9	79.2	151.7	85.9	47.1	91.3	46.1	90.9	45.4	89.8	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.5	13.9	11.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB												
			WB	41.1	85.2	6.8	0.9	36.2	85.8	32.3	86.4	28.4	86.9	23.5	87.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	77.8	67.5	69.2	73.5	78.6	82.3	84.1	84.7	84.2	83.1	80.5	75.4	69.6	(6)
(7)		DBStd	7.13	4.34	4.76	5.18	4.14	2.73	2.93	2.62	2.56	2.22	2.69	3.44	4.05	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	57	25	15	7	1	0	0	0	0	0	0	0	9	(9)
(10)		CDD50	10140	543	539	728	859	1002	1023	1075	1061	994	945	763	608	(10)
(11)		CDD65	4721	103	134	270	410	537	573	610	596	544	480	313	151	(11)
(12)		CDH74	46648	519	810	1950	3588	5732	6734	7284	6846	5812	4454	2144	775	(12)
(13)		CDH80	17932	61	172	625	1317	2318	2940	3237	2868	2226	1528	539	101	(13)
(14)	Wind	WSAvg	3.4	2.9	3.1	3.3	3.4	3.6	4.4	4.6	4.5	3.6	2.8	2.5	2.5	(14)
(15)	Precipitation	PrecAvg	70.8	0.6	0.8	0.9	2.7	6.1	15.6	14.6	16.3	9.0	2.4	1.1	0.7	(15)
(16)		PrecMax	108.4	2.2	3.7	3.9	9.5	24.8	38.7	31.6	47.2	30.9	10.9	8.0	6.1	(16)
(17)		PrecMin	37.4	0.0	0.0	0.0	0.0	0.1	1.3	0.2	4.2	2.1	0.0	0.0	0.0	(17)
(18)		PrecStd	19.4	0.6	1.0	1.2	2.8	5.0	10.7	8.4	11.7	6.9	3.0	1.8	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.5	87.4	91.0	93.2	95.1	96.5	96.8	95.2	93.5	92.3	88.2	85.5	(19)
(20)			MCWB	71.8	74.3	75.7	77.1	80.6	82.2	82.1	81.6	81.3	79.6	77.2	74.1	(20)
(21)		2%	DB	81.3	84.3	88.1	91.3	93.1	94.7	94.8	93.5	92.1	89.9	86.4	82.6	(21)
(22)			MCWB	69.5	72.3	75.6	77.5	79.5	81.3	81.3	81.2	80.8	78.6	76.0	72.0	(22)
(23)		5%	DB	79.2	82.2	86.2	89.4	91.5	93.1	93.3	92.4	91.3	89.1	84.8	80.6	(23)
(24)			MCWB	68.1	70.6	74.8	76.9	79.0	80.7	81.1	80.9	80.4	78.3	75.0	70.5	(24)
(25)		10%	DB	77.0	79.2	84.0	87.5	89.8	91.4	91.6	91.1	89.6	87.5	83.6	78.6	(25)
(26)			MCWB	67.3	68.9	73.2	76.4	78.5	80.3	80.5	80.6	79.7	77.8	74.3	69.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.8	75.7	78.3	80.4	82.5	84.6	83.8	83.6	83.3	81.0	79.2	75.6	(27)
(28)			MCDWB	81.9	85.3	87.9	89.2	91.4	93.4	93.0	92.0	90.7	88.8	86.3	83.4	(28)
(29)		2%	WB	71.2	73.3	76.4	78.9	81.0	82.8	82.7	82.5	82.0	79.9	77.5	73.4	(29)
(30)			MCDWB	79.3	81.9	86.5	87.9	89.9	91.1	91.8	90.4	89.7	87.5	84.6	80.6	(30)
(31)		5%	WB	69.7	71.6	75.1	77.7	80.0	81.7	81.8	81.6	81.1	79.1	76.1	71.8	(31)
(32)			MCDWB	76.8	80.0	84.6	86.4	88.4	89.8	90.6	89.3	88.4	86.4	83.0	78.8	(32)
(33)		10%	WB	68.1	69.9	73.8	76.7	79.2	80.8	81.0	80.9	80.2	78.3	74.9	70.0	(33)
(34)			MCDWB	75.0	77.9	82.2	85.0	87.0	88.7	89.1	88.3	87.0	85.2	81.5	76.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	18.6	18.6	18.1	16.0	15.1	14.0	14.2	13.6	13.9	14.9	16.4	18.2	(35)
(36)			MCDBR	20.9	21.4	20.6	18.2	17.3	16.4	16.3	15.5	15.5	16.0	17.0	19.6	(36)
(37)			MCWBR	10.9	11.1	10.4	8.2	7.3	7.0	6.8	6.6	6.7	6.7	8.5	10.2	(37)
(38)		5% WB	MCDBR	19.2	20.2	19.6	17.0	15.6	14.9	15.1	14.4	14.4	15.1	16.4	17.9	(38)
(39)			MCWBR	11.0	11.1	10.5	8.4	7.4	7.3	7.1	6.8	7.0	7.0	8.8	10.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.505	0.542	0.666	0.651	0.539	0.499	0.501	0.558	0.593	0.596	0.517	0.525	(40)	
(41)		taud	2.014	1.941	1.683	1.759	2.085	2.221	2.209	2.021	1.899	1.850	2.049	1.977	(41)	
(42)		Ebn at Noon	237	238	215	222	247	255	254	241	229	220	233	225	(42)	
(43)		Edh at Noon	50	58	78	73	53	46	46	56	62	62	49	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1107	1292	1406	1528	1609	1689	1786	1590	1554	1436	1175	1047	(44)	
(45)		RadStd	106	127	121	151	177	190	151	170	133	82	83	103	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.43	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+209	+198

Nomenclature: See separate page