

PINGTUNG SOUTH, Taiwan

WMO: 467500

Lat: 22.672N

Lon: 120.462E

Elev: 24

StdP: 101.04

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.8	13.0	9.0	7.1	13.9	10.2	7.8	14.9	7.0	24.0	6.2	23.6	0.5	330	0.297

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.9	35.0	27.3	34.2	27.1	33.7	26.9	28.3	33.0	27.9	32.5	27.5	32.0	4.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.1	23.0	30.9	26.8	22.5	30.5	26.2	21.7	29.9	91.6	33.0	89.4	32.7	87.6	32.1	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.2	5.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			5.1	29.5	3.8	0.5	2.3	29.9	0.1	30.2	-2.0	30.5	-4.7	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	19.7	20.7	23.1	25.9	28.0	28.9	29.3	29.0	28.4	26.9	24.1	20.9		
	DBStd	3.96	2.41	2.64	2.88	2.30	1.52	1.63	1.45	1.42	1.24	1.49	1.91	2.25		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	32	14	8	4	1	0	0	0	0	0	0	0	5		
	CDD10.0	5633	302	299	404	477	557	568	597	589	552	525	424	338		
	CDD18.3	2623	57	74	150	228	298	318	339	331	302	267	174	84		
	CDH23.3	25916	288	450	1083	1993	3184	3741	4047	3803	3229	2474	1191	431		
	CDH26.7	9962	34	96	347	732	1288	1633	1798	1593	1237	849	299	56		
(14) Wind	WSAvg	1.5	1.3	1.4	1.5	1.5	1.6	2.0	2.1	2.0	1.6	1.3	1.1	1.1		
(15) Precipitation	PrecAvg	1798	15	21	22	68	154	396	372	413	229	62	28	19		
	PrecMax	2753	56	93	99	241	631	984	803	1200	785	278	202	154		
	PrecMin	951	0	0	0	0	2	33	4	106	53	0	0	0		
	PrecStd	492	16	25	30	72	126	273	214	298	176	75	45	33		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.2	30.8	32.8	34.0	35.1	35.9	36.0	35.1	34.2	33.5	31.2	29.7		
		MCWB	22.1	23.5	24.3	25.1	27.0	27.9	27.9	27.6	27.4	26.5	25.1	23.4		
	2%	DB	27.4	29.1	31.2	32.9	34.0	34.8	34.9	34.2	33.4	32.2	30.2	28.1		
		MCWB	20.9	22.4	24.2	25.3	26.4	27.4	27.4	27.3	27.1	25.9	24.4	22.2		
	5%	DB	26.2	27.9	30.1	31.9	33.0	34.0	34.0	33.5	32.9	31.7	29.3	27.0		
		MCWB	20.1	21.4	23.8	25.0	26.1	27.1	27.3	27.2	26.9	25.7	23.9	21.4		
	10%	DB	25.0	26.2	28.9	30.8	32.1	33.0	33.1	32.8	32.0	30.8	28.7	25.9		
		MCWB	19.6	20.5	22.9	24.7	25.8	26.8	27.0	27.0	26.5	25.5	23.5	20.6		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	24.3	25.7	26.9	28.0	29.2	28.8	28.7	28.5	27.2	26.2	24.2		
		MCDB	27.7	29.6	31.1	31.8	33.0	34.1	33.9	33.4	32.6	31.6	30.2	28.5		
	2%	WB	21.8	22.9	24.7	26.1	27.2	28.2	28.2	28.0	27.8	26.6	25.3	23.0		
		MCDB	26.3	27.7	30.3	31.0	32.1	32.8	33.2	32.5	32.0	30.8	29.2	27.0		
	5%	WB	20.9	22.0	23.9	25.4	26.7	27.6	27.7	27.6	27.3	26.2	24.5	22.1		
		MCDB	24.9	26.7	29.2	30.2	31.3	32.1	32.5	31.8	31.4	30.2	28.3	26.0		
	10%	WB	20.0	21.0	23.2	24.9	26.2	27.1	27.2	27.1	26.8	25.7	23.8	21.1		
		MCDB	23.9	25.5	27.9	29.4	30.5	31.5	31.7	31.3	30.6	29.6	27.5	24.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.3	10.4	10.0	8.9	8.4	7.8	7.9	7.6	7.7	8.3	9.1	10.1		
		MCDBR	11.6	11.9	11.4	10.1	9.6	9.1	9.1	8.6	8.6	8.9	9.4	10.9		
	5% WB	MCWBR	6.1	6.2	5.8	4.5	4.0	3.9	3.8	3.6	3.7	3.7	4.7	5.7		
		MCWBR	10.7	11.2	10.9	9.4	8.7	8.3	8.4	8.0	8.0	8.4	9.1	10.0		
(40) Clear-Sky Solar Irradiance	taub		0.505	0.542	0.666	0.651	0.539	0.499	0.501	0.558	0.593	0.596	0.517	0.525		
	taud		2.014	1.941	1.683	1.759	2.085	2.221	2.209	2.021	1.899	1.850	2.049	1.977		
	Ebn at Noon		748	750	678	700	778	803	802	760	723	695	733	710		
	Edh at Noon		159	182	245	231	166	144	145	175	195	197	153	161		
(44) All-Sky Solar Radiation	RadAvg		3.49	4.07	4.43	4.82	5.07	5.33	5.63	5.01	4.90	4.53	3.70	3.30		
	RadStd		0.34	0.40	0.38	0.48	0.56	0.60	0.48	0.54	0.42	0.26	0.26	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (21 neighbors)	+0.24	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+116	+110

Nomenclature: See separate page