

HENGCHUN AP, Taiwan

WMO: 467520

Lat: 22.041N

Lon: 120.730E

Elev: 46

StdP: 14.67

Time Zone: 8.00 (E08)

Period: 86-98

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	59.5	61.1	49.7	52.8	62.9	51.6	56.7	63.5	28.5	68.4	25.6	69.0	9.0	40	0.403

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	91.7	81.6	91.0	81.4	89.8	80.7	83.4	89.2	82.7	88.5	82.1	87.8	9.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.9	166.5	87.6	80.9	160.8	86.9	80.5	158.8	86.6	47.5	89.9	46.7	89.2	46.1	87.9	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.3	21.7	19.3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB	51.6	85.7	2.0	1.6	50.1	86.9	48.9	87.9	47.8	88.8	46.3	89.9
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.2	70.2	70.9	74.9	78.6	81.6	83.0	83.8	83.3	82.7	80.1	77.1	72.1
	DBStd	5.82	3.65	4.03	4.26	3.88	2.82	2.63	2.30	2.01	2.39	2.75	3.36	3.75
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	13	5	4	2	0	0	0	0	0	0	0	0	2
	CDD50	10300	626	584	771	859	978	990	1048	1032	981	933	812	686
	CDD65	4838	166	168	308	409	513	540	583	567	531	468	362	223
	CDH74	45077	432	597	1867	3483	5460	6256	7083	6642	5839	4281	2364	773
	CDH80	14934	25	59	407	1019	1906	2393	2864	2491	2048	1174	471	77
(14) Wind	WSAvg	8.7	9.7	9.6	8.9	8.1	7.0	7.6	7.2	7.2	6.3	10.0	11.5	10.8
(15) Precipitation	PrecAvg	78.0	0.9	0.9	0.7	1.7	6.3	14.1	15.2	18.8	12.3	5.4	1.3	0.6
	PrecMax	135.4	2.8	3.3	3.7	7.8	15.7	42.0	36.0	38.6	32.3	21.6	7.8	2.4
	PrecMin	35.0	0.1	0.0	0.0	0.0	1.0	1.1	4.9	3.1	0.9	0.1	0.0	0.0
	PrecStd	21.6	0.7	0.9	0.8	1.7	4.3	8.5	8.7	9.9	8.7	6.4	1.7	0.6
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.6	84.1	88.6	91.3	91.8	93.0	93.2	92.7	92.7	91.1	89.5	84.7
		MCWB	72.7	75.0	77.3	79.2	80.3	82.1	81.8	82.6	82.9	80.5	79.7	75.0
	2%	DB	80.4	82.1	86.1	89.2	90.2	91.2	91.5	91.1	90.7	89.3	86.4	82.3
		MCWB	71.3	73.2	75.9	78.1	79.5	81.7	82.0	81.8	81.8	79.4	77.4	73.2
	5%	DB	78.5	80.2	84.2	87.5	89.3	89.7	90.0	89.7	89.5	87.6	84.4	80.4
		MCWB	70.2	71.7	74.7	77.7	79.3	81.3	81.4	81.2	80.8	78.6	75.9	71.7
	10%	DB	76.5	77.7	82.4	85.6	87.7	88.1	89.3	88.2	88.0	85.9	82.6	78.5
		MCWB	69.2	70.3	74.0	76.9	79.3	81.0	81.1	81.0	80.3	77.7	74.6	70.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.6	76.5	78.6	80.8	83.2	84.5	84.0	84.3	83.9	81.8	79.9	77.1
		MCDB	79.7	82.1	86.6	87.9	88.6	89.4	90.0	90.1	90.5	88.5	87.3	83.2
	2%	WB	72.5	74.4	77.0	79.4	81.5	82.9	82.9	82.9	82.7	80.3	78.5	74.3
		MCDB	78.2	80.1	84.7	86.2	87.7	88.3	89.0	88.5	89.0	87.1	85.3	80.3
	5%	WB	71.0	72.6	75.6	78.5	80.5	82.2	82.4	82.2	81.8	79.2	77.1	72.7
		MCDB	76.7	78.2	82.7	85.1	86.9	87.7	88.4	87.7	87.7	85.6	83.1	78.7
	10%	WB	69.7	71.0	74.5	77.6	79.6	81.4	81.6	81.5	80.8	78.2	75.6	71.4
		MCDB	75.4	76.7	81.1	84.1	85.7	86.6	87.4	86.7	86.4	84.3	81.2	77.1
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	12.2	12.4	12.3	11.7	10.2	10.0	10.2	11.0	11.6	11.4	11.4
		MCDBR	13.6	14.5	14.5	14.1	13.3	11.8	11.5	12.0	12.5	13.2	12.9	12.5
	5% WB	MCWBR	8.2	9.0	8.5	7.6	7.0	6.5	6.1	6.7	7.1	7.9	7.7	7.8
		MCWBR	12.5	13.2	14.0	13.1	12.3	10.4	10.7	10.8	11.6	12.3	11.9	11.7
(40) Clear-Sky Solar Irradiance	taub		0.500	0.522	0.642	0.623	0.513	0.490	0.493	0.536	0.556	0.546	0.506	0.524
		taud	2.059	2.024	1.753	1.841	2.192	2.278	2.261	2.112	2.026	2.009	2.111	2.006
	Ebn at Noon		241	245	221	229	253	257	256	246	239	235	237	227
		Edn at Noon	49	53	73	68	47	43	44	51	55	53	46	50
(44) All-Sky Solar Radiation	RadAvg		1033	1249	1413	1613	1701	1802	1844	1650	1577	1438	1140	959
	RadStd		105	138	129	154	172	188	165	167	153	91	88	117

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (14 neighbors)		+0.47	N/A	N/A	N/A	+0.45	+0.58	N/A	N/A	+209	+198	

Nomenclature: See separate page