

HSINCHU, Taiwan

WMO: 467560

Lat: 24.818N

Lon: 120.939E

Elev: 26

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	48.4	50.3	41.0	37.8	50.5	44.2	42.9	53.4	30.0	58.8	27.1	57.1	14.5	40	0.450

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.2	91.7	82.3	90.7	81.9	89.7	81.4	84.0	89.6	82.9	88.8	82.3	88.3	14.5	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.5	169.3	88.7	81.0	161.3	87.7	80.6	159.0	87.4	48.2	89.7	47.0	89.7	46.3	88.3	90.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
30.2	26.8	24.2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB	41.8	86.1	2.9	1.7	39.7	87.3	38.0	88.2	36.3	89.2	34.2	90.4
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	72.7	60.4	60.3	63.4	70.8	76.6	81.3	84.2	84.2	81.1	75.8	70.1	63.9	(6)
(7)		DBStd	9.66	4.29	4.94	5.63	5.67	4.34	3.60	1.86	1.99	3.33	3.56	4.71	4.30	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	496	151	146	97	18	1	0	0	0	0	0	11	72	(9)
(10)		CDD50	8303	322	289	416	624	826	940	1060	1060	933	800	602	431	(10)
(11)		CDD65	3323	8	14	48	192	362	490	595	595	483	335	163	38	(11)
(12)		CDH74	31286	9	38	147	931	2771	5295	7344	7321	4886	1952	540	52	(12)
(13)		CDH80	11059	0	2	15	112	659	1910	3138	3074	1674	404	70	1	(13)
(14)	Wind	WSAvg	10.8	12.5	12.0	10.5	8.9	7.4	9.4	8.8	8.8	9.4	14.5	14.9	13.1	(14)
(15)	Precipitation	PrecAvg	63.9	2.6	5.2	5.9	6.5	8.1	9.8	4.9	6.7	7.8	2.4	2.0	1.9	(15)
(16)		PrecMax	92.3	6.1	14.3	10.8	19.8	26.7	22.8	13.5	17.5	46.9	9.9	8.7	5.4	(16)
(17)		PrecMin	30.7	0.5	0.6	3.0	0.7	0.6	0.1	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	18.1	1.3	3.9	1.8	4.7	5.3	6.1	3.9	5.7	11.0	2.8	2.4	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.4	78.5	82.3	84.5	89.4	91.4	92.9	93.6	93.5	88.2	85.4	78.5	(19)
(20)			MCWB	67.5	71.5	74.7	77.5	81.2	82.0	82.6	82.7	81.8	78.8	75.8	70.0	(20)
(21)		2%	DB	71.9	74.1	77.8	82.7	87.4	89.7	91.5	91.7	90.0	85.8	82.1	75.3	(21)
(22)			MCWB	65.7	68.2	72.7	76.5	79.6	81.4	82.3	82.6	81.0	78.0	74.1	68.3	(22)
(23)		5%	DB	69.6	71.2	74.9	80.9	85.6	88.4	90.0	91.0	89.2	84.1	79.2	73.2	(23)
(24)			MCWB	64.0	65.7	70.7	75.1	78.4	81.0	81.6	82.3	80.7	76.1	72.5	66.8	(24)
(25)		10%	DB	66.5	67.8	71.7	79.1	84.0	87.7	89.6	89.6	87.7	82.4	77.0	71.1	(25)
(26)			MCWB	62.4	63.3	67.9	74.0	77.7	80.7	81.4	81.6	80.0	75.1	71.3	65.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	72.2	75.7	79.1	82.6	84.2	84.6	86.0	84.1	80.5	77.2	72.4	(27)
(28)			MCDB	73.5	77.1	80.6	82.9	88.2	89.0	89.9	90.7	89.7	86.3	82.0	76.3	(28)
(29)		2%	WB	66.6	69.0	73.0	77.5	80.1	82.7	83.7	84.2	82.4	78.9	75.1	69.7	(29)
(30)			MCDB	71.0	73.2	77.2	81.6	85.2	88.0	89.3	90.0	88.7	84.1	80.8	73.3	(30)
(31)		5%	WB	64.9	66.2	70.9	76.0	79.1	81.8	82.7	83.0	81.3	77.4	73.4	68.0	(31)
(32)			MCDB	68.5	70.2	74.3	80.1	84.0	87.3	88.7	89.0	87.5	82.5	77.7	71.8	(32)
(33)		10%	WB	63.2	63.7	68.6	74.7	78.1	80.8	82.0	82.2	80.3	76.1	72.0	66.3	(33)
(34)			MCDB	66.2	67.2	71.4	78.5	82.8	86.4	88.1	88.2	86.2	80.8	76.1	70.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.7	10.9	10.5	10.8	10.8	11.1	11.3	11.2	11.7	11.6	11.3	12.1	(35)
(36)			MCDBR	15.4	16.6	15.2	12.6	12.5	11.9	11.9	12.9	13.4	13.8	14.5	15.5	(36)
(37)			MCWBR	11.0	11.8	10.7	8.7	8.1	7.5	7.2	7.7	8.0	8.6	9.1	10.5	(37)
(38)		5% WB	MCDBR	13.2	16.0	14.3	11.5	11.5	11.6	11.6	11.8	12.3	12.4	12.8	13.7	(38)
(39)			MCWBR	10.0	12.0	10.8	8.5	8.1	7.7	7.6	7.9	8.0	8.5	9.1	10.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.540	0.587	0.699	0.703	0.599	0.555	0.551	0.572	0.554	0.539	0.530	0.536	(40)	
(41)		taud	1.888	1.806	1.604	1.645	1.912	2.049	2.055	1.988	2.016	1.999	1.996	1.914	(41)	
(42)		Ebn at Noon	222	222	206	210	232	241	242	237	238	233	224	217	(42)	
(43)		Edh at Noon	56	65	84	82	62	54	54	57	55	53	50	53	(43)	
(44)	All-Sky Solar Radiation	RadAvg	776	869	1059	1187	1381	1577	1902	1725	1506	1243	893	771	(44)	
(45)		RadStd	141	154	134	171	235	184	114	159	157	137	104	119	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)	+0.45	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	+221	+175

Nomenclature: See separate page