

TAITUNG, Taiwan

WMO: 467660

Lat: 22.7522N

Lon: 121.1546E

Elev: 30

StdP: 14.68

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	56.5	58.2	44.5	43.3	59.4	46.8	47.3	60.3	14.9	69.5	12.5	69.0	4.6	330	0.265

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.3	91.6	81.0	90.6	80.8	89.6	80.5	82.5	89.6	81.8	88.9	81.2	88.3	6.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.4	158.1	88.2	79.7	154.3	87.6	79.0	150.8	87.1	46.4	89.9	45.7	89.2	45.0	88.6	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.3	11.5	9.9	54.4	96.4	2.0	2.8	52.9	98.4	51.7	100.0	50.6	101.6	49.1	103.6		
(5)			49.0	83.5	1.8	0.9	47.6	84.2	46.6	84.7	45.5	85.2	44.2	85.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	76.8	67.6	68.9	71.6	75.8	79.6	82.8	84.3	84.0	82.3	79.1	75.1	69.8		
	DBStd	6.89	4.19	4.80	4.73	4.35	3.60	3.08	2.24	2.31	2.47	2.81	3.27	4.29		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	63	24	19	7	1	0	0	0	0	0	0	0	12		
	CDD50	9770	545	530	670	773	917	984	1063	1053	968	902	752	613		
	CDD65	4359	104	129	212	324	452	534	598	588	518	437	303	160		
	CDH74	40125	155	340	890	2214	4229	6284	7635	7246	5701	3590	1476	365		
	CDH80	13521	3	18	100	460	1203	2461	3348	3000	1933	813	171	11		
(14) Wind	WSAvg	4.5	4.7	4.6	4.5	4.3	4.0	4.1	4.2	4.2	4.4	5.1	4.9	4.9		
(15) Precipitation	PrecAvg	76.0	1.7	2.0	1.7	3.1	6.0	9.1	11.5	12.9	13.1	8.6	4.2	2.0		
	PrecMax	123.8	6.9	4.5	3.5	8.6	14.8	26.1	24.6	30.6	39.4	42.6	21.7	10.1		
	PrecMin	49.1	0.4	0.2	0.3	0.4	0.6	0.1	0.7	2.1	1.3	0.8	0.0	0.0		
	PrecStd	17.3	1.3	1.2	0.9	2.0	3.7	6.1	6.7	7.7	9.7	10.2	4.6	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.1	82.3	85.1	88.8	91.1	92.6	93.1	92.7	91.3	88.9	85.3	81.6		
		MCWB	71.4	73.6	75.6	77.5	79.1	80.7	81.3	81.2	80.7	79.6	76.7	73.1		
	2%	DB	77.7	79.8	82.6	86.1	88.7	90.9	91.6	90.9	89.7	87.1	83.6	79.5		
		MCWB	69.7	72.1	74.6	77.3	79.4	80.9	81.4	81.2	80.3	78.2	75.2	71.3		
	5%	DB	75.7	77.9	80.5	84.5	87.3	89.7	90.5	89.9	88.5	85.8	82.1	77.7		
		MCWB	68.2	70.4	72.9	76.4	78.9	80.6	81.0	80.7	79.7	77.0	74.0	70.0		
	10%	DB	74.0	76.0	78.6	82.7	85.8	88.5	89.4	88.9	87.3	84.4	80.4	76.1		
		MCWB	66.9	69.0	71.6	75.2	78.0	80.0	80.5	80.2	79.0	75.8	72.8	68.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.2	74.8	76.9	79.4	81.5	83.3	83.4	83.1	82.4	81.2	78.5	74.9		
		MCDB	78.2	80.9	82.8	85.9	88.2	90.2	90.3	90.2	88.9	86.4	83.4	79.4		
	2%	WB	70.7	72.9	75.3	78.0	80.4	82.1	82.4	82.1	81.3	79.7	76.5	73.0		
		MCDB	76.2	78.6	81.7	84.8	87.2	89.1	89.9	89.4	88.0	85.7	82.0	77.9		
	5%	WB	69.2	71.4	73.7	76.9	79.5	81.3	81.7	81.5	80.4	78.3	75.1	71.1		
		MCDB	74.7	77.0	79.7	83.7	86.0	88.3	89.1	88.7	87.3	84.3	80.8	76.6		
	10%	WB	67.6	69.7	72.2	75.6	78.6	80.5	81.0	80.8	79.6	77.0	73.8	69.6		
		MCDB	73.1	75.2	78.1	82.1	84.8	87.6	88.3	87.9	86.3	83.0	79.3	75.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.3	9.4	9.7	9.8	9.5	9.1	9.3	8.9	9.2	9.4	9.1	9.0		
		MCDBR	11.1	11.2	11.7	11.7	11.3	10.8	10.6	10.2	10.5	10.5	10.6	10.5		
	5% WB	MCWBR	8.0	7.8	8.2	8.0	6.9	6.5	6.6	6.6	6.5	6.5	7.6	7.5		
		MCWBR	10.2	10.6	11.4	11.4	10.5	9.9	9.8	9.6	9.8	9.6	9.6	9.4		
(40) Clear-Sky Solar Irradiance	taub		0.488	0.508	0.618	0.608	0.513	0.472	0.465	0.509	0.531	0.519	0.487	0.504		
	taud		2.081	2.066	1.799	1.877	2.182	2.317	2.331	2.185	2.096	2.088	2.161	2.058		
	Ebn at Noon		243	248	226	232	253	262	264	253	245	242	242	232		
	Edh at Noon		47	51	69	65	48	41	41	47	51	49	43	47		
(44) All-Sky Solar Radiation	RadAvg		898	1083	1203	1372	1541	1724	1854	1664	1528	1345	1019	861		
	RadStd		94	136	149	166	196	183	142	169	146	95	89	113		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.52	+0.61	N/A	N/A	N/A	N/A
(47) Regional (21 neighbors)		+0.43	N/A	N/A	N/A	+0.36	+0.43	N/A	N/A	+209	+198

Nomenclature: See separate page