

TAITUNG, Taiwan

WMO: 467660

Lat: 22.7522N

Lon: 121.1546E

Elev: 9

StdP: 101.22

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.6	14.6	6.9	6.2	15.2	8.2	6.8	15.7	6.7	20.8	5.6	20.6	2.1	330	0.265

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	33.1	27.2	32.5	27.1	32.0	26.9	28.1	32.0	27.7	31.6	27.3	31.3	2.9	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.9	22.6	31.2	26.5	22.0	30.9	26.1	21.5	30.6	90.1	32.2	88.4	31.8	86.8	31.4	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.9	5.2	4.4	DB	12.4	35.8	1.1	1.6	11.6	36.9	11.0	37.8	10.3	38.7	9.5	39.8	
			WB	9.4	28.6	1.0	0.5	8.7	29.0	8.1	29.3	7.5	29.6	6.8	29.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.9	19.8	20.5	22.0	24.3	26.4	28.2	29.1	28.9	27.9	26.2	23.9	21.0
	DBStd	3.83	2.33	2.67	2.63	2.42	2.00	1.71	1.24	1.28	1.37	1.56	1.81	2.38
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	35	13	11	4	1	0	0	0	0	0	0	0	7
	CDD10.0	5428	303	294	372	429	509	547	591	585	538	501	418	341
	CDD18.3	2422	58	72	118	180	251	297	332	327	288	243	168	89
	CDH23.3	22292	86	189	494	1230	2349	3491	4242	4026	3167	1994	820	203
(14) Wind	WSAvg	2.0	2.1	2.1	2.0	1.9	1.8	1.8	1.9	1.9	2.0	2.3	2.2	2.2
	PrecAvg	1931	44	52	43	78	152	231	293	327	333	219	107	51
	PrecMax	3144	175	114	88	219	376	663	626	776	1000	1081	550	256
	PrecMin	1248	9	6	7	10	15	2	17	53	34	21	0	1
	PrecStd	439	33	30	22	51	93	156	171	195	247	260	117	52
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.7	28.0	29.5	31.6	32.8	33.7	34.0	33.7	33.0	31.6	29.6	27.6
		MCWB	21.9	23.1	24.2	25.3	26.1	27.0	27.4	27.3	27.0	26.4	24.8	22.8
	2%	DB	25.4	26.6	28.1	30.1	31.5	32.7	33.1	32.7	32.0	30.6	28.6	26.4
		MCWB	21.0	22.3	23.6	25.2	26.4	27.1	27.4	27.3	26.8	25.7	24.0	21.8
	5%	DB	24.3	25.5	27.0	29.2	30.7	32.1	32.5	32.2	31.4	29.9	27.8	25.4
		MCWB	20.1	21.4	22.7	24.7	26.0	27.0	27.2	27.1	26.5	25.0	23.3	21.1
	10%	DB	23.3	24.4	25.9	28.2	29.9	31.4	31.9	31.6	30.7	29.1	26.9	24.5
		MCWB	19.4	20.5	22.0	24.0	25.6	26.7	27.0	26.8	26.1	24.3	22.7	20.5
	0.4%	WB	22.9	23.8	24.9	26.3	27.5	28.5	28.6	28.4	28.0	27.4	25.8	23.8
		MCDB	25.7	27.1	28.2	29.9	31.2	32.3	32.4	32.3	31.6	30.2	28.5	26.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	21.5	22.7	24.1	25.6	26.9	27.8	28.0	27.8	27.4	26.5	24.7	22.8
		MCDB	24.5	25.9	27.6	29.3	30.7	31.7	32.1	31.9	31.1	29.8	27.8	25.5
	5%	WB	20.7	21.9	23.2	24.9	26.4	27.4	27.6	27.5	26.9	25.7	24.0	21.7
		MCDB	23.7	25.0	26.5	28.7	30.0	31.3	31.7	31.5	30.7	29.1	27.1	24.8
	10%	WB	19.8	21.0	22.3	24.2	25.9	27.0	27.2	27.1	26.4	25.0	23.2	20.9
		MCDB	22.8	24.0	25.6	27.9	29.3	30.9	31.3	31.1	30.2	28.3	26.3	23.9
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	5.2	5.4	5.4	5.3	5.1	5.2	5.0	5.1	5.2	5.1	5.0
		MCDBR	6.1	6.2	6.5	6.5	6.3	6.0	5.9	5.7	5.8	5.8	5.9	5.8
		MCWBR	4.4	4.3	4.6	4.4	3.8	3.6	3.7	3.7	3.6	3.6	4.2	4.2
	5% WB	MCDBR	5.7	5.9	6.3	6.3	5.8	5.5	5.4	5.3	5.5	5.4	5.3	5.2
		MCWBR	4.3	4.4	4.7	4.5	3.8	3.6	3.7	3.7	3.7	3.6	4.0	4.1
(40) Clear-Sky Solar Irradiance	taub		0.488	0.508	0.618	0.608	0.513	0.472	0.465	0.509	0.531	0.519	0.487	0.504
	taud		2.081	2.066	1.799	1.877	2.182	2.317	2.331	2.185	2.096	2.088	2.161	2.058
	Ebn at Noon		766	782	714	731	798	825	831	798	773	762	763	732
	Edh at Noon		149	161	219	205	151	130	129	149	160	155	137	148
(44) All-Sky Solar Radiation	RadAvg		2.83	3.41	3.79	4.33	4.86	5.43	5.85	5.25	4.82	4.24	3.21	2.71
	RadStd		0.30	0.43	0.47	0.52	0.62	0.58	0.45	0.53	0.46	0.30	0.28	0.35

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	+0.29	+0.34	N/A	N/A	N/A	N/A
Regional (21 neighbors)	+0.24	N/A	N/A	N/A	+0.20	+0.24	N/A	N/A	+116	+110

Nomenclature: See separate page