

TAIPING ISLAND, Taiwan

WMO: 469020

Lat: 10.377N

Lon: 114.365E

Elev: 16

StdP: 14.69

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	75.4	76.2	69.6	109.1	79.4	71.0	114.4	79.9	26.9	80.6	24.5	80.7	8.7	50	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.8	96.2	84.6	94.4	84.2	93.0	83.6	86.3	93.4	85.3	92.3	84.4	91.5	6.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
84.5	181.3	92.0	83.4	174.6	90.8	82.5	169.6	89.9	51.0	93.3	49.6	92.5	48.7	91.8	97.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	22.5	19.8	68.6	99.1	5.0	3.3	65.0	101.5	62.1	103.5	59.2	105.4	55.6	107.8
			66.2	88.3	4.6	3.0	62.9	90.4	60.2	92.2	57.6	93.8	54.3	96.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	84.1	82.0	83.0	84.8	86.4	86.3	85.0	83.8	84.3	83.8	83.7	83.5	82.4	(6)
	DBStd	2.69	2.24	2.19	2.35	2.20	2.90	2.67	2.40	2.20	2.37	2.10	2.28	2.17	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	12445	992	924	1080	1092	1126	1049	1049	1064	1013	1045	1006	1005	(10)
	CDD65	6970	527	504	615	642	661	599	584	599	563	580	556	540	(11)
	CDH74	81037	5316	5304	7096	8023	8456	7353	6962	7140	6574	6662	6359	5792	(12)
	CDH80	30919	1349	1608	2828	3795	4073	3141	2640	2798	2420	2401	2227	1639	(13)
(14) Wind	WSAvg	9.0	10.7	9.6	7.7	5.6	6.8	9.0	11.6	10.9	10.0	6.9	8.3	10.3	(14)
(15) Precipitation	PrecAvg	83.4	5.5	1.3	2.9	2.8	5.1	9.1	8.7	7.6	10.0	8.2	8.1	13.6	(15)
	PrecMax	167.7	23.4	4.9	20.5	16.3	17.0	33.6	26.5	21.0	21.0	25.1	21.7	41.7	(16)
	PrecMin	26.7	0.0	0.0	0.0	0.0	0.1	1.0	2.0	0.7	0.6	1.7	0.6	0.1	(17)
	PrecStd	44.1	6.5	1.4	5.6	4.1	4.7	8.4	6.7	5.2	5.9	6.1	5.9	12.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.5	93.6	97.5	98.5	98.7	96.7	94.2	94.0	94.3	93.1	92.2	91.0	(19)
		MCWB	82.2	81.7	83.7	84.2	86.5	85.7	84.4	84.7	84.7	84.2	83.8	82.7	(20)
	2%	DB	88.9	91.1	94.0	95.9	95.6	93.6	91.8	91.5	91.7	91.0	90.6	88.6	(21)
		MCWB	81.2	81.5	83.1	84.0	85.1	84.8	83.6	83.7	83.7	83.3	83.1	81.5	(22)
	5%	DB	87.3	89.1	91.8	93.7	93.7	91.5	89.9	89.7	89.7	89.5	89.0	87.2	(23)
		MCWB	80.4	80.7	82.1	83.4	84.4	83.7	82.6	82.5	82.6	82.4	82.2	80.7	(24)
	10%	DB	85.9	87.3	89.8	91.9	91.9	89.4	87.9	88.1	87.9	88.0	87.5	85.9	(25)
		MCWB	79.6	80.1	81.4	82.6	83.6	82.5	81.7	81.7	81.7	81.5	81.5	80.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	83.9	84.7	87.1	86.6	87.8	87.0	85.8	86.3	85.6	85.5	84.8	83.5	(27)
		MCDB	88.8	89.5	92.8	94.3	95.9	94.6	92.3	92.2	92.3	91.6	90.5	89.3	(28)
	2%	WB	82.1	82.5	84.3	85.0	86.0	85.3	84.3	84.2	84.1	83.7	83.6	82.3	(29)
		MCDB	87.6	88.8	92.0	93.1	94.1	92.4	90.5	90.5	90.6	89.8	89.3	87.5	(30)
	5%	WB	80.9	81.4	82.7	84.1	84.9	84.1	83.2	83.1	82.9	82.7	82.7	81.4	(31)
		MCDB	86.2	87.6	90.6	92.4	92.7	90.8	88.8	88.8	88.7	88.6	88.1	86.1	(32)
	10%	WB	80.0	80.4	81.6	83.1	83.9	82.8	82.1	82.0	81.9	81.8	81.8	80.6	(33)
		MCDB	84.7	86.3	89.0	91.2	91.2	88.5	87.2	87.1	87.0	87.2	86.6	84.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.0	9.2	11.2	12.2	10.8	8.8	7.7	7.8	8.0	8.7	7.9	6.8	(35)
		MCDBR	10.2	12.4	14.6	15.0	14.0	12.6	11.1	10.5	11.1	11.1	10.0	9.0	(36)
	5% WB	MCWBR	5.9	6.1	6.9	6.8	6.7	6.5	6.1	5.7	5.7	5.8	5.4	5.1	(37)
		MCWBR	9.7	11.2	13.6	13.4	13.1	11.7	10.1	10.0	10.1	10.7	9.6	8.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.469	0.438	0.443	0.435	0.422	0.434	0.453	0.462	0.449	0.442	0.463	0.500	(40)
		taud	2.308	2.414	2.415	2.441	2.510	2.491	2.420	2.378	2.413	2.435	2.353	2.197	(41)
	Ebn at Noon		266	280	279	278	277	270	266	267	273	275	266	254	(42)
		Edh at Noon	41	38	39	37	34	34	37	39	38	37	39	45	(43)
(44) All-Sky Solar Radiation	RadAvg		1461	1822	2003	2092	1866	1535	1531	1637	1540	1596	1494	1259	(44)
	RadStd		194	153	170	148	195	181	158	135	212	170	158	197	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)
(47)	Regional (1 neighbor)	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(47)

Nomenclature: See separate page