

TAIPING ISLAND, Taiwan

WMO: 469020

Lat: 10.377N

Lon: 114.365E

Elev: 5

StdP: 101.26

Time Zone: 8.00 (E08)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	24.1	24.6	20.9	15.6	26.3	21.7	16.3	26.6	12.0	27.0	11.0	27.1	3.9	50	0.469

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	6.0	35.7	29.2	34.7	29.0	33.9	28.7	30.2	34.1	29.6	33.5	29.1	33.1	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
29.2	25.9	33.3	28.5	24.9	32.7	28.1	24.2	32.2	100.7	34.1	97.6	33.6	95.3	33.2	36.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	10.1	8.8	20.4	37.3	2.8	1.9	18.3	38.6	16.7	39.7	15.1	40.8	13.1	42.1
			19.0	31.3	2.5	1.7	17.2	32.5	15.7	33.4	14.2	34.4	12.4	35.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	27.8	28.3	29.4	30.2	30.2	29.4	28.8	29.1	28.8	28.7	28.6	28.0	(6)
(7)		DBStd	1.50	1.24	1.22	1.30	1.22	1.61	1.48	1.33	1.22	1.32	1.16	1.27	1.20	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6914	551	513	600	607	626	583	583	591	563	581	559	558	(10)
(11)		CDD18.3	3872	293	280	342	357	367	333	324	333	313	322	309	300	(11)
(12)		CDH23.3	45021	2953	2947	3942	4457	4698	4085	3868	3967	3652	3701	3533	3218	(12)
(13)	CDH26.7	17177	749	893	1571	2108	2263	1745	1467	1554	1344	1334	1237	911	(13)	
(14)	Wind	WSAvg	4.0	4.8	4.3	3.5	2.5	3.0	4.0	5.2	4.9	4.5	3.1	3.7	4.6	(14)
(15)	Precipitation	PrecAvg	2118	139	33	74	70	130	230	220	194	253	209	206	346	(15)
(16)		PrecMax	4259	594	125	521	413	431	853	673	533	533	638	552	1058	(16)
(17)		PrecMin	679	0	0	0	0	2	26	51	17	16	44	14	2	(17)
(18)		PrecStd	1121	164	36	142	103	119	214	169	133	149	154	151	311	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.1	34.2	36.4	37.0	37.1	36.0	34.5	34.5	34.6	33.9	33.4	32.8	(19)
(20)		0.4%	MCWB	27.9	27.6	28.7	29.0	30.3	29.9	29.1	29.3	29.3	29.0	28.8	28.1	(20)
(21)		2%	DB	31.6	32.8	34.5	35.5	35.3	34.2	33.2	33.1	33.2	32.8	32.5	31.5	(21)
(22)		2%	MCWB	27.3	27.5	28.4	28.9	29.5	29.3	28.6	28.7	28.7	28.5	28.4	27.5	(22)
(23)		5%	DB	30.7	31.7	33.2	34.3	34.3	33.1	32.2	32.0	32.0	31.9	31.7	30.7	(23)
(24)		5%	MCWB	26.9	27.1	27.8	28.5	29.1	28.7	28.1	28.1	28.1	28.0	27.9	27.1	(24)
(25)		10%	DB	29.9	30.7	32.1	33.3	33.3	31.9	31.1	31.2	31.1	31.1	30.8	29.9	(25)
(26)		10%	MCWB	26.4	26.7	27.4	28.1	28.7	28.0	27.6	27.6	27.6	27.5	27.5	26.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	28.8	29.3	30.6	30.3	31.0	30.5	29.9	30.2	29.8	29.7	29.3	28.6	(27)
(28)		0.4%	MCDWB	31.5	31.9	33.8	34.6	35.5	34.8	33.5	33.5	33.5	33.1	32.5	31.8	(28)
(29)		2%	WB	27.8	28.1	29.1	29.5	30.0	29.6	29.1	29.0	28.9	28.7	28.7	28.0	(29)
(30)		2%	MCDWB	30.9	31.5	33.3	33.9	34.5	33.5	32.5	32.5	32.6	32.1	31.8	30.8	(30)
(31)		5%	WB	27.2	27.5	28.2	28.9	29.4	28.9	28.4	28.4	28.3	28.2	28.1	27.4	(31)
(32)		5%	MCDWB	30.1	30.9	32.6	33.6	33.7	32.7	31.6	31.6	31.5	31.4	31.1	30.0	(32)
(33)		10%	WB	26.7	26.9	27.6	28.4	28.8	28.2	27.8	27.8	27.7	27.7	27.7	27.0	(33)
(34)		10%	MCDWB	29.3	30.1	31.7	32.9	32.9	31.4	30.7	30.6	30.6	30.6	30.4	29.4	(34)
(35)	Mean Daily Temperature Range		MDBR	4.4	5.1	6.2	6.8	6.0	4.9	4.3	4.4	4.9	4.4	3.8	(35)	
(36)		5% DB	MCDDBR	5.7	6.9	8.1	8.4	7.8	7.0	6.2	5.8	6.2	6.2	5.6	5.0	(36)
(37)			MCWBR	3.3	3.4	3.8	3.8	3.7	3.6	3.4	3.2	3.2	3.2	3.0	2.8	(37)
(38)			5% WB	MCDDBR	5.4	6.2	7.5	7.5	7.3	6.5	5.6	5.5	5.6	5.9	5.3	4.8
(39)		MCWBR		3.3	3.5	3.9	3.9	3.9	3.6	3.3	3.1	3.2	3.3	3.1	2.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.469	0.438	0.443	0.435	0.422	0.434	0.453	0.462	0.449	0.442	0.463	0.500	(40)	
(41)		taud	2.308	2.414	2.415	2.441	2.510	2.491	2.420	2.378	2.413	2.435	2.353	2.197	(41)	
(42)		Ebn at Noon	840	883	880	877	872	851	837	842	862	867	840	800	(42)	
(43)		Edh at Noon	130	121	122	118	108	108	117	124	121	117	124	143	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.61	5.74	6.31	6.60	5.88	4.84	4.83	5.16	4.85	5.03	4.71	3.97	(44)	
(45)		RadStd	0.61	0.48	0.54	0.47	0.62	0.57	0.50	0.43	0.67	0.54	0.50	0.62	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page