

HAIKOU MEILAN INTL, China

WMO: 470311

Lat: 19.935N

Lon: 110.459E

Elev: 23

StdP: 101.05

Time Zone: 8.00 (E08)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.8	11.1	5.8	5.7	13.6	7.1	6.3	13.8	8.4	18.4	8.0	18.5	2.3	350	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	8.0	35.8	26.9	34.9	26.9	34.0	26.9	28.4	32.2	28.0	31.5	27.6	31.2	3.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.1	29.6	27.1	22.9	29.5	26.9	22.7	29.4	91.7	32.1	89.7	32.5	87.8	32.0	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.5	6.5	7.3	37.2	1.8	1.5	6.0	38.3	4.9	39.1	3.9	39.9	2.6	41.0		
			6.5	29.4	1.6	0.9	5.4	30.0	4.4	30.5	3.5	31.0	2.4	31.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.8	17.8	19.8	22.8	25.9	28.3	29.2	29.1	28.5	27.7	25.6	23.1	19.5
	DBStd	4.73	3.32	4.45	3.89	3.00	2.00	1.61	1.53	1.35	1.45	1.63	2.58	3.03
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	122	51	34	11	0	0	0	0	0	0	0	3	23
	CDD10.0	5399	242	276	396	477	567	577	592	573	529	483	393	294
	CDD18.3	2479	34	77	147	228	308	327	334	314	279	225	146	59
	CDH23.3	22604	79	373	904	1858	3128	3719	3763	3328	2764	1774	753	159
	CDH26.7	8611	11	104	281	684	1273	1647	1631	1328	994	484	157	16
Wind	WSAvg	3.1	3.5	3.3	3.3	3.2	2.7	2.4	2.6	2.4	2.8	3.5	3.6	3.8
Precipitation	PrecAvg	1972	28	41	53	95	205	204	216	281	330	351	101	67
	PrecMax	2702	147	177	236	317	437	444	431	537	801	1429	215	195
	PrecMin	1204	0	4	6	14	101	84	101	68	102	19	4	5
	PrecStd	365	27	37	46	67	74	87	82	101	166	291	60	48
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	32.8	33.2	35.8	36.1	36.9	36.9	35.9	34.2	32.1	31.8	28.2
		MCWB	22.7	23.2	25.0	26.4	27.1	26.8	26.0	26.3	26.6	25.6	25.3	22.9
	2%	DB	25.1	29.2	31.8	34.0	34.9	35.2	35.2	34.2	33.1	31.0	30.0	26.8
		MCWB	21.1	23.0	24.8	26.3	26.9	27.2	26.9	27.0	26.6	25.1	24.4	22.3
	5%	DB	23.9	27.8	29.8	32.1	33.9	34.2	34.1	33.2	32.2	30.1	28.8	25.0
		MCWB	20.5	22.6	24.0	25.7	26.8	27.2	27.0	26.9	26.4	24.4	23.9	21.4
	10%	DB	22.1	25.1	28.0	30.8	32.8	33.2	33.0	32.1	31.2	29.2	27.0	23.9
		MCWB	19.9	21.7	23.3	25.4	26.4	26.9	26.6	26.7	26.2	24.2	23.1	20.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	24.3	26.1	27.7	28.6	29.1	28.7	28.8	28.3	27.1	26.2	24.5
		MCDB	26.5	29.3	31.0	32.8	32.7	33.5	33.0	32.5	31.5	29.5	29.2	26.6
	2%	WB	21.9	23.6	25.3	26.8	27.9	28.3	28.1	28.1	27.6	26.4	25.4	23.3
		MCDB	24.1	27.6	29.9	31.3	31.8	32.2	31.8	31.3	30.7	28.9	28.3	25.4
	5%	WB	21.2	22.9	24.5	26.2	27.4	27.9	27.7	27.6	27.2	25.9	24.7	22.2
		MCDB	22.9	26.2	28.3	30.3	31.2	31.6	31.2	30.8	30.3	28.5	27.3	24.1
	10%	WB	20.5	22.3	23.8	25.7	26.9	27.5	27.2	27.2	26.7	25.4	24.0	21.5
		MCDB	22.0	25.1	26.8	29.5	30.7	31.1	30.8	30.5	29.7	28.0	26.1	23.1
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.6	7.0	7.3	8.1	8.0	7.8	7.6	7.1	7.1	6.5	6.0
		MCDBR	8.1	9.3	9.3	9.4	9.5	9.3	9.3	9.2	8.6	8.6	8.9	8.5
		MCWBR	4.3	3.7	3.7	3.4	3.6	3.5	3.4	3.7	3.5	3.7	4.0	4.4
	5% WB	MCDBR	6.7	8.4	8.7	8.7	8.8	8.3	7.9	7.8	7.6	6.8	7.4	6.7
		MCWBR	3.8	3.8	3.9	3.7	3.8	3.5	3.3	3.6	3.5	3.4	3.7	4.0
Clear-Sky Solar Irradiance	taub	0.574	0.591	0.706	0.672	0.514	0.486	0.469	0.517	0.570	0.642	0.579	0.594	
	taud	1.820	1.822	1.622	1.740	2.189	2.288	2.326	2.166	1.981	1.760	1.870	1.798	
	Ebn at Noon	699	720	657	688	798	813	828	794	748	670	690	663	
	Edh at Noon	198	208	264	237	150	134	129	152	181	219	187	197	
All-Sky Solar Radiation	RadAvg	2.72	3.33	3.90	4.69	5.36	5.40	5.43	5.07	4.53	3.94	3.25	2.68	
	RadStd	0.55	0.61	0.43	0.53	0.46	0.51	0.47	0.38	0.40	0.33	0.37	0.41	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	-1.03	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page