

HUICHON, Korea, Democratic People's Republic of

WMO: 470390

Lat: 40.167N

Lon: 126.250E

Elev: 155

StdP: 99.48

Time Zone: 9.00 (E09)

Period: 90-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-19.5	-17.2	-22.7	0.5	-17.6	-20.5	0.6	-15.9	5.5	-7.1	4.5	-7.6	0.2	320	0.392

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	31.7	25.1	30.4	24.3	29.1	23.5	26.7	30.5	25.6	29.0	24.6	27.7	1.4	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	21.2	29.6	24.5	19.9	28.1	23.7	18.8	26.9	85.0	30.4	79.9	29.0	75.9	27.7	31.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.3	4.3	3.4	-22.5	34.5	3.0	1.2	-24.7	35.3	-26.4	36.0	-28.1	36.7	-30.2	37.5		
(5)			-22.6	28.3	2.9	1.5	-24.7	29.3	-26.3	30.2	-27.9	31.0	-30.0	32.1		

Monthly Climatic Design Conditions

		Annual													
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.4	-8.1	-4.2	2.5	9.5	16.0	21.0	24.2	18.8	11.3	2.5	-5.6	(6)
(7)		DBStd	11.83	4.34	4.18	3.80	3.83	2.98	2.40	2.12	2.36	3.06	3.71	4.87	4.52
(8)		HDD10.0	1988	561	398	235	54	1	0	0	0	29	227	482	(8)
(9)		HDD18.3	3760	819	631	492	265	83	6	0	1	31	217	474	741
(10)		CDD10.0	1779	0	0	1	39	188	331	441	441	264	71	3	0
(11)		CDD18.3	510	0	0	0	1	12	87	182	183	46	1	0	0
(12)		CDH23.3	3729	0	0	0	14	180	622	1270	1351	283	9	0	0
(13)		CDH26.7	1061	0	0	0	1	32	158	388	439	41	1	0	0
(14)	Wind	WSAvg	0.7	0.5	0.8	0.9	1.1	1.1	0.8	0.7	0.6	0.5	0.6	0.6	0.5
(15)	Precipitation	PrecAvg	1141	9	20	27	55	84	122	338	254	109	54	49	22
(16)		PrecMax	1963	32	96	89	97	156	268	1016	1065	464	129	123	59
(17)		PrecMin	662	0	2	1	5	17	43	95	52	13	3	9	3
(18)		PrecStd	336	8	24	19	25	38	57	190	193	92	30	30	14
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	4.1	9.5	17.2	25.4	29.8	32.2	34.1	33.8	29.5	24.5	16.6	5.9	(19)
(20)		0.4% MCWB	1.3	5.2	10.2	16.1	19.9	22.0	27.3	26.9	22.6	17.2	11.9	3.3	(20)
(21)		2% DB	1.7	6.4	14.0	22.4	27.2	30.1	31.7	31.9	27.9	21.9	13.6	4.0	(21)
(22)		2% MCWB	-0.3	2.9	8.3	14.4	18.6	21.7	25.6	25.9	21.3	15.8	10.1	2.4	(22)
(23)		5% DB	0.3	4.4	11.4	20.0	25.3	28.5	30.3	30.5	26.4	20.0	11.6	2.3	(23)
(24)		5% MCWB	-1.5	1.6	6.8	12.7	17.5	21.3	25.1	24.7	20.3	14.5	8.9	0.7	(24)
(25)		10% DB	-1.3	2.6	9.2	17.6	23.3	26.9	28.8	29.2	25.0	18.0	9.6	0.9	(25)
(26)		10% MCWB	-2.9	0.2	5.4	11.4	16.4	20.7	24.4	24.0	19.5	13.2	7.4	-0.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	1.9	5.9	11.4	17.1	21.5	24.5	29.0	29.2	24.5	18.4	12.5	4.6	(27)
(28)		0.4% MCDB	3.9	9.2	16.1	23.5	27.3	28.7	32.7	32.4	27.8	22.9	15.3	5.2	(28)
(29)		2% WB	0.0	3.3	8.9	15.0	19.4	23.2	26.9	26.9	22.7	16.5	10.7	2.4	(29)
(30)		2% MCDB	1.4	5.7	12.9	21.3	25.4	28.1	30.6	30.8	26.0	20.5	13.0	3.7	(30)
(31)		5% WB	-1.3	1.8	7.2	13.4	18.2	22.4	25.7	25.8	21.5	15.3	9.1	1.0	(31)
(32)		5% MCDB	0.1	4.1	11.1	19.1	24.1	27.0	29.1	29.3	25.1	18.8	11.4	2.1	(32)
(33)		10% WB	-2.8	0.4	5.7	11.7	17.1	21.4	24.8	24.8	20.3	13.9	7.5	-0.2	(33)
(34)		10% MCDB	-1.3	2.3	8.9	16.5	22.3	25.6	27.8	27.9	23.8	17.2	9.3	0.9	(34)
(35)	Mean Daily Temperature Range	MDBR	11.5	11.1	10.5	12.2	12.1	10.4	7.7	9.0	11.3	12.5	9.4	9.6	(35)
(36)		5% DB MCDBR	11.5	12.1	14.4	16.7	16.2	13.7	10.6	11.0	12.9	15.0	11.9	9.2	(36)
(37)		5% WB MCWBR	9.4	8.8	9.5	9.4	8.6	7.0	6.2	6.1	7.4	9.0	8.5	7.4	(37)
(38)		5% WB MCDBR	10.5	10.9	13.4	15.2	14.3	11.0	8.7	8.9	10.8	13.0	10.8	8.3	(38)
(39)	Clear-Sky Solar Irradiance	taub	0.379	0.456	0.527	0.602	0.627	0.688	0.645	0.556	0.486	0.510	0.452	0.391	(40)
(41)		taud	1.982	1.840	1.740	1.656	1.649	1.599	1.742	1.945	2.051	1.876	1.933	1.993	(41)
(42)		Ebn at Noon	731	721	715	695	691	650	675	726	751	661	642	678	(42)
(43)		Edh at Noon	126	169	208	242	248	262	225	179	151	161	133	116	(43)
(44)	All-Sky Solar Radiation	RadAvg	2.53	3.37	4.35	4.88	5.50	5.10	4.26	4.42	4.33	3.36	2.23	2.06	(44)
(45)		RadStd	0.13	0.23	0.33	0.39	0.47	0.52	0.55	0.51	0.39	0.24	0.26	0.14	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page