

ANJU, Korea, Democratic People's Republic ofWMO: **470500**Lat: **39.617N**Lon: **125.650E**Elev: **27**StdP: **101.00**Time Zone: **9.00 (E09)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.2	-14.1	-23.5	0.5	-12.9	-21.2	0.6	-11.1	9.1	-7.0	8.5	-7.2	1.1	320	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.9	30.8	25.0	29.6	24.3	28.5	23.7	26.5	29.5	25.6	28.2	24.9	27.3	2.4	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.6	20.9	28.6	24.9	20.0	27.5	24.1	19.1	26.7	83.2	29.6	79.4	28.3	76.4	27.4	31.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.6	7.6	6.4	-19.2	32.7	2.8	1.1	-21.2	33.5	-22.9	34.2	-24.5	34.8	-26.5	35.6		
(5)			-19.3	28.2	2.8	1.5	-21.4	29.3	-23.0	30.2	-24.6	31.0	-26.6	32.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.5	-6.4	-2.9	3.4	10.1	16.5	21.4	24.5	24.9	19.9	12.9	4.3	-4.1
	DBStd	11.40	4.12	4.01	3.50	3.55	2.76	2.15	1.95	2.13	2.69	3.71	4.79	4.40
	HDD10.0	1743	507	361	205	41	1	0	0	0	0	16	177	436
	HDD18.3	3438	766	594	462	246	69	3	0	0	16	169	419	694
	CDD10.0	1917	0	0	2	45	203	343	451	461	297	107	7	0
	CDD18.3	569	0	0	0	0	13	96	193	203	63	2	0	0
	CDH23.3	3640	0	0	0	3	91	493	1291	1486	266	9	0	0
	CDH26.7	787	0	0	0	0	12	85	293	374	23	1	0	0
Wind	WSAvg	1.8	1.4	1.8	2.2	2.3	2.1	1.7	1.8	1.6	1.3	1.6	1.8	1.6
Precipitation	PrecAvg	1118	7	21	23	52	87	114	355	250	108	51	45	16
	PrecMax	1910	27	107	72	104	239	268	1010	788	345	106	157	48
	PrecMin	664	0	0	0	1	12	33	74	52	17	1	5	2
	PrecStd	314	7	27	15	30	52	57	186	162	92	30	38	13
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	4.9	9.2	16.9	23.4	28.1	30.6	32.7	32.7	28.9	24.6	17.2	7.2
		MCWB	2.0	5.1	10.5	14.9	18.5	21.3	27.0	27.0	22.2	17.9	13.5	4.9
	2%	DB	2.9	6.3	13.3	20.8	25.7	28.7	30.7	31.1	27.1	22.1	15.0	5.2
		MCWB	1.1	2.9	8.1	13.2	18.3	21.2	25.0	25.8	21.1	16.4	11.6	3.5
	5%	DB	1.4	4.5	11.0	18.6	23.9	27.5	29.4	29.9	26.1	20.2	13.0	3.7
		MCWB	-0.4	1.7	6.9	12.0	16.9	20.9	24.6	25.1	20.4	15.1	10.2	1.9
	10%	DB	-0.1	2.9	9.1	16.6	22.3	26.2	28.3	28.7	24.9	18.6	11.2	2.2
		MCWB	-1.8	0.5	5.4	10.7	16.0	20.3	24.2	24.4	19.5	14.3	8.5	0.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.1	6.8	11.4	16.6	21.2	24.1	28.2	27.9	24.2	19.4	14.2	5.6
		MCDB	4.2	9.0	14.8	21.0	25.2	27.9	32.0	31.4	26.6	23.1	16.3	6.7
	2%	WB	1.3	3.5	9.1	14.3	19.3	22.8	26.6	26.7	22.6	17.3	12.1	3.7
		MCDB	2.6	5.6	12.8	18.6	23.8	26.6	29.4	29.9	25.7	20.5	14.2	5.1
	5%	WB	-0.2	2.0	7.2	12.8	18.0	22.0	25.7	25.9	21.5	16.1	10.4	2.2
		MCDB	1.2	4.0	10.5	17.0	22.5	25.7	28.0	28.8	24.6	19.2	12.7	3.5
	10%	WB	-1.6	0.8	5.7	11.5	17.0	21.2	24.9	25.2	20.7	14.9	8.9	0.7
		MCDB	-0.2	2.7	8.7	15.8	21.1	24.6	27.2	27.8	23.8	17.9	11.0	1.9
Mean Daily Temperature Range	5% DB	MDBR	8.6	8.6	8.6	9.9	9.7	8.3	6.3	6.9	9.4	9.9	7.9	7.3
		MCDBR	8.7	9.5	11.5	12.8	12.3	10.6	8.4	8.1	10.0	11.1	9.7	7.1
		MCWBR	6.9	6.7	7.4	6.9	6.2	5.1	4.5	4.4	5.1	6.3	7.0	6.0
	5% WB	MCDBR	8.0	8.7	10.8	11.0	10.9	8.4	6.7	6.9	8.4	9.9	8.5	6.8
		MCWBR	6.8	6.5	7.4	6.8	6.4	4.7	4.3	4.2	5.1	6.4	6.8	6.2
Clear-Sky Solar Irradiance	taub		0.406	0.482	0.544	0.622	0.643	0.718	0.694	0.587	0.512	0.537	0.489	0.418
	taud		1.959	1.818	1.729	1.628	1.632	1.554	1.648	1.869	1.977	1.815	1.863	1.958
	Ebn at Noon		706	699	704	682	681	631	641	703	729	639	607	652
	Edh at Noon		131	175	212	249	253	274	248	194	163	173	145	123
All-Sky Solar Radiation	RadAvg		2.43	3.21	4.36	5.08	5.70	5.26	4.22	4.49	4.41	3.44	2.32	2.06
	RadStd		0.16	0.23	0.32	0.40	0.50	0.55	0.54	0.52	0.36	0.22	0.24	0.14