

SOKCHO, Korea, Republic of

WMO: 470900

Lat: 38.2508N

Lon: 128.5647E

Elev: 19

StdP: 101.09

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.4	-6.5	-25.6	0.4	-5.9	-23.3	0.5	-4.3	9.5	-1.0	8.5	-0.6	3.2	290	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.1	31.5	24.3	30.1	23.7	28.7	23.1	25.9	29.1	25.1	28.4	24.3	27.5	3.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.0	20.1	27.9	24.2	19.1	27.1	23.3	18.2	26.4	80.4	29.1	77.1	28.4	73.9	27.6	28.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	6.9	5.9	-11.6	34.0	2.3	1.4	-13.3	35.0	-14.6	35.8	-15.9	36.6	-17.6	37.6		
(5)			-13.5	26.5	2.1	1.1	-15.0	27.2	-16.2	27.9	-17.4	28.5	-18.9	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.6	0.1	1.9	6.2	11.9	16.4	19.8	23.6	24.4	20.1	15.3	8.9	2.5	(6)
(7)		DBStd	8.93	3.48	3.53	3.99	3.95	3.74	2.81	3.27	2.65	2.36	2.90	3.93	3.90	(7)
(8)		HDD10.0	991	306	228	131	23	1	0	0	0	0	3	67	232	(8)
(9)		HDD18.3	2581	564	462	376	198	84	15	1	0	8	99	284	490	(9)
(10)		CDD10.0	1956	0	1	14	79	200	293	422	446	302	166	33	1	(10)
(11)		CDD18.3	504	0	0	1	4	25	57	165	187	61	4	0	0	(11)
(12)		CDH23.3	3187	0	0	1	21	134	256	1218	1362	191	4	0	0	(12)
(13)		CDH26.7	850	0	0	0	3	18	45	395	364	25	0	0	0	(13)
(14)	Wind	WSAvg	2.4	2.7	2.6	2.7	2.9	2.6	2.1	2.0	1.9	2.1	2.2	2.5	2.6	(14)
(15)	Precipitation	PrecAvg	1327	54	60	57	74	78	103	218	278	206	90	63	45	(15)
(16)		PrecMax	2012	166	208	122	254	162	289	504	603	651	342	159	226	(16)
(17)		PrecMin	928	0	3	7	0	10	15	51	57	7	3	0	0	(17)
(18)		PrecStd	245	51	52	30	64	46	71	102	143	156	87	52	53	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	13.3	21.2	26.0	28.8	30.1	33.5	33.4	29.2	23.7	20.0	13.6	(19)
(20)			MCWB	5.2	6.7	11.4	14.8	16.3	19.4	24.8	25.5	22.4	16.0	12.8	7.8	(20)
(21)		2%	DB	8.1	10.9	17.2	22.9	26.5	27.9	31.8	31.4	27.0	22.2	18.0	11.5	(21)
(22)			MCWB	3.4	5.2	9.0	12.8	15.7	19.4	24.4	24.9	21.3	15.9	11.9	6.6	(22)
(23)		5%	DB	6.5	8.9	14.8	20.5	24.7	26.2	30.4	30.0	25.3	21.0	16.4	9.6	(23)
(24)			MCWB	2.3	4.1	8.0	11.5	15.0	19.0	24.0	24.4	20.8	15.9	11.1	5.2	(24)
(25)		10%	DB	5.1	7.2	12.7	18.4	22.9	24.6	29.0	28.7	24.1	20.0	14.9	8.1	(25)
(26)			MCWB	1.1	2.8	6.8	10.7	14.5	18.9	23.5	24.1	20.3	15.2	10.2	3.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.2	8.0	12.4	17.2	18.9	22.5	26.7	27.2	24.2	19.4	14.7	9.3	(27)
(28)			MCDWB	9.0	12.0	19.0	22.8	24.5	26.0	30.3	30.7	27.4	21.2	17.4	12.2	(28)
(29)		2%	WB	4.2	5.9	10.3	14.3	17.5	21.5	25.7	26.2	22.6	18.1	13.2	7.3	(29)
(30)			MCDWB	7.1	9.6	15.6	19.7	23.0	24.6	29.5	29.3	25.3	20.4	16.4	10.7	(30)
(31)		5%	WB	2.9	4.6	8.7	13.2	16.6	20.8	24.9	25.5	21.7	17.2	12.1	5.6	(31)
(32)			MCDWB	5.6	8.0	13.3	18.1	21.5	23.6	29.0	28.4	24.4	19.7	15.5	9.0	(32)
(33)		10%	WB	1.7	3.4	7.4	11.9	15.8	20.1	24.1	24.8	20.9	16.2	10.8	4.4	(33)
(34)			MCDWB	4.3	6.5	11.8	16.5	20.3	22.8	27.8	27.6	23.4	18.9	14.2	7.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.5	6.7	7.3	7.6	7.1	5.5	4.7	5.1	6.1	7.1	6.7	6.6	(35)
(36)			MCDBR	7.5	8.4	9.6	10.7	10.4	8.6	7.2	6.8	7.2	7.9	8.0	7.5	(36)
(37)			MCWBR	5.8	5.8	5.7	5.5	4.8	3.6	3.0	3.3	4.3	5.1	5.8	5.8	(37)
(38)		5% WB	MCDWB	6.5	7.8	9.0	9.0	8.4	6.1	6.3	5.6	5.9	6.5	7.2	7.1	(38)
(39)			MCWBR	5.4	5.9	6.1	5.6	4.6	3.2	3.2	3.3	4.0	4.9	5.9	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.410	0.471	0.559	0.611	0.616	0.664	0.631	0.555	0.486	0.484	0.448	0.403	(40)	
(41)		taud	1.994	1.870	1.730	1.675	1.713	1.678	1.809	2.003	2.119	1.989	2.007	2.041	(41)	
(42)		Ebn at Noon	720	723	699	695	704	670	688	733	761	705	673	694	(42)	
(43)		Edh at Noon	130	169	214	239	235	243	212	171	143	148	128	116	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.46	3.22	4.08	4.90	5.43	5.17	4.28	4.24	3.92	3.39	2.39	2.17	(44)	
(45)		RadStd	0.23	0.33	0.40	0.41	0.54	0.41	0.58	0.53	0.47	0.29	0.33	0.21	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (33 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	+102	+62
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	+99	+52

Nomenclature: See separate page