

BAENGYEONGDO, Korea, Republic of

WMO: 471020

Lat: 37.974N

Lon: 124.713E

Elev: 38

StdP: 100.87

Time Zone: 9.00 (E09)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.1	(c) -7.1	(d) -16.7	(e) 0.9	(f) -6.0	(g) -15.3	(h) 1.0	(i) -5.5	(j) 20.2	(k) -1.8	(l) 15.6	(m) -1.1	(n) 5.4	(o) 290	(p) 0.519

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 4.2	(c) 28.3	(d) 24.5	(e) 27.1	(f) 23.7	(g) 26.0	(h) 23.0	(i) 25.6	(j) 27.1	(k) 24.9	(l) 26.3	(m) 24.1	(n) 25.5	(o) 3.5	(p) 230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	26.6	24.4	19.5	25.8	23.6	18.5	25.2	79.4	27.2	76.2	26.4	73.1	25.5	29.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.6	(b) 11.8	(c) 10.1	(e) -11.1	(f) 30.4	(g) 2.9	(h) 1.2	(i) -13.2	(j) 31.3	(k) -14.8	(l) 32.0	(m) -16.4	(n) 32.7	(o) -18.5	(p) 33.6		
(a) 14.6	(b) 11.8	(c) 10.1	(e) -12.1	(f) 26.2	(g) 2.5	(h) 1.3	(i) -13.9	(j) 27.2	(k) -15.4	(l) 27.9	(m) -16.8	(n) 28.7	(o) -18.7	(p) 29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.4	-1.3	0.1	3.9	9.2	14.7	19.2	22.5	23.9	20.4	14.9	7.8	1.2
	DBStd	9.19	3.46	3.47	2.91	2.90	2.74	2.20	2.01	2.09	1.97	2.86	3.80	3.82
	HDD10.0	1230	351	278	190	48	1	0	0	0	0	4	86	273
	HDD18.3	2937	609	512	448	274	116	17	1	0	6	108	316	531
	CDD10.0	1754	0	0	1	24	147	276	387	432	311	157	21	0
	CDD18.3	418	0	0	0	0	4	42	129	173	67	3	0	0
	CDH23.3	1402	0	0	0	0	4	48	389	889	71	1	0	0
	CDH26.7	142	0	0	0	0	0	1	32	109	1	0	0	0
Wind	WSAvg	4.7	4.8	4.8	5.3	5.8	5.4	4.4	4.3	3.9	3.5	4.2	5.2	5.2
Precipitation	PrecAvg	818	13	18	19	50	72	76	219	166	86	35	40	22
	PrecMax	1265	28	66	72	99	137	202	400	327	362	94	154	44
	PrecMin	406	2	0	2	6	3	16	74	36	6	1	10	7
	PrecStd	201	7	16	18	28	44	45	93	87	105	27	37	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.8	9.2	12.9	18.9	23.8	26.1	29.3	30.2	26.4	22.2	16.8	10.7
		MCWB	4.9	6.0	6.4	10.7	14.1	18.5	25.0	25.8	20.9	17.5	13.9	8.9
	2%	DB	5.7	6.8	10.4	16.7	21.8	24.7	27.4	28.9	25.1	20.6	15.3	9.2
		MCWB	3.6	4.4	6.6	9.9	13.3	18.4	23.9	25.1	20.7	16.7	12.7	7.2
	5%	DB	4.5	5.5	8.9	15.0	20.4	23.5	26.2	27.9	24.1	19.4	14.1	7.7
		MCWB	2.2	3.3	5.6	9.1	13.5	18.3	23.4	24.4	20.0	15.9	11.8	5.2
	10%	DB	3.4	4.4	7.7	13.6	19.1	22.5	25.3	26.8	23.1	18.4	13.0	6.5
		MCWB	1.1	2.3	4.9	8.4	13.0	18.1	23.0	23.8	19.4	15.2	10.6	3.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.5	7.5	9.2	13.5	17.2	22.2	26.2	26.9	23.6	19.2	15.2	9.6
		MCDB	6.5	8.4	10.2	16.3	20.2	23.9	27.2	29.0	24.7	20.7	16.1	10.4
	2%	WB	4.0	5.0	7.7	11.7	16.1	20.9	25.1	26.1	22.1	18.0	13.7	7.5
		MCDB	5.4	6.2	9.3	14.2	19.0	22.4	26.3	27.7	23.4	19.7	14.6	9.0
	5%	WB	2.6	3.8	6.4	10.6	15.3	20.1	24.4	25.4	21.3	16.8	12.2	5.7
		MCDB	4.2	5.2	8.0	12.9	18.1	21.8	25.6	26.9	22.8	18.6	13.5	7.5
	10%	WB	1.2	2.6	5.4	9.6	14.4	19.5	23.7	24.7	20.5	15.9	11.0	4.2
		MCDB	3.2	4.1	7.1	12.1	17.3	21.2	24.8	26.2	22.4	17.8	13.0	6.3
Mean Daily Temperature Range	5% DB	MDBR	3.9	4.2	4.7	5.4	5.9	5.1	4.1	4.2	4.4	4.4	4.1	4.1
		MCDBR	4.8	5.3	6.5	7.4	7.7	6.5	5.4	5.1	5.3	5.2	4.3	4.9
		MCWBR	4.7	4.6	4.5	4.4	4.2	3.7	3.1	3.0	3.5	3.8	4.1	4.9
	5% WB	MCDBR	4.8	5.1	5.9	6.2	6.5	4.8	4.2	4.4	4.3	5.0	4.2	5.1
		MCWBR	4.8	5.0	5.1	4.7	4.2	3.2	3.0	3.0	3.7	4.4	4.7	5.4
Clear-Sky Solar Irradiance	taub	0.439	0.494	0.554	0.605	0.624	0.706	0.682	0.585	0.515	0.526	0.507	0.446	
	taud	1.944	1.841	1.740	1.682	1.696	1.607	1.706	1.920	2.017	1.866	1.862	1.932	
	Ebn at Noon	688	703	705	700	698	642	653	709	736	664	610	642	
	Edh at Noon	138	174	212	238	239	261	235	185	159	168	150	131	
All-Sky Solar Radiation	RadAvg	2.21	3.15	4.38	5.05	5.55	5.11	4.37	4.70	4.46	3.57	2.36	1.92	
	RadStd	0.17	0.23	0.36	0.35	0.51	0.62	0.59	0.57	0.38	0.25	0.27	0.13	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+1.44	N/A	N/A	N/A	N/A	
(47) Regional (16 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+84	+48	

Nomenclature: See separate page