

YEONGWOL, Korea, Republic of

WMO: 471210

Lat: 37.1814N

Lon: 128.4575E

Elev: 242

StdP: 98.45

Time Zone: 9.00 (E09)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-14.3	-12.2	-22.7	0.5	-8.9	-20.6	0.6	-8.0	6.5	-3.4	5.5	-2.5	1.0	270	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.2	32.2	23.3	30.8	22.7	29.5	22.0	25.1	29.3	24.5	28.4	23.9	27.5	2.2	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.1	19.5	26.4	23.5	18.8	26.0	22.8	18.1	25.7	78.1	29.4	75.6	28.5	73.3	27.5	27.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.9	5.1	4.3	-17.6	34.5	2.7	1.4	-19.6	35.5	-21.1	36.4	-22.7	37.1	-24.6	38.1		
			-18.1	26.1	2.6	0.7	-20.0	26.6	-21.6	27.0	-23.0	27.4	-24.9	27.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-3.4	-0.7	4.9	11.3	17.0	21.5	24.4	19.8	13.5	5.8	-1.3	(6)	
(7)		DBStd	10.38	4.13	3.95	3.74	3.72	2.63	2.36	2.20	2.59	2.83	3.48	4.20	4.12	(7)
(8)		HDD10.0	1404	416	298	163	28	0	0	0	0	12	137	350	(8)	
(9)		HDD18.3	3048	674	532	417	211	58	4	0	16	152	376	608	(9)	
(10)		CDD10.0	1962	0	0	5	68	216	344	445	458	295	120	11	0	(10)
(11)		CDD18.3	564	0	0	0	1	16	98	187	199	61	2	0	0	(11)
(12)		CDH23.3	4193	0	0	0	37	258	753	1307	1517	311	11	0	0	(12)
(13)		CDH26.7	1239	0	0	0	4	46	206	402	532	51	0	0	0	(13)
(14)	Wind	WSAvg	1.4	1.3	1.4	1.7	1.8	1.6	1.4	1.3	1.2	1.2	1.2	1.2	(14)	
(15)	Precipitation	PrecAvg	1303	19	28	50	84	92	156	326	284	149	51	40	22	(15)
(16)		PrecMax	2049	50	71	144	192	208	433	855	667	375	150	127	56	(16)
(17)		PrecMin	741	3	2	11	18	18	47	95	61	24	2	4	3	(17)
(18)		PrecStd	312	14	20	32	47	46	89	159	167	106	37	29	15	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.2	13.2	20.0	26.9	30.1	32.0	33.6	34.5	30.2	24.7	19.2	10.9	(19)
(20)			MCWB	3.9	6.6	10.8	14.6	16.9	19.5	24.4	24.3	22.0	16.6	12.6	6.4	(20)
(21)		2%	DB	6.2	10.5	17.1	24.1	27.8	30.4	31.8	32.7	28.1	22.7	16.5	8.4	(21)
(22)			MCWB	2.5	4.8	8.4	13.2	15.5	19.4	23.7	24.1	20.4	15.4	10.9	4.7	(22)
(23)		5%	DB	4.6	8.2	14.7	21.9	26.2	29.1	30.4	31.2	26.6	21.1	14.6	6.5	(23)
(24)			MCWB	1.3	3.2	7.3	11.7	15.2	19.0	23.3	23.9	19.7	14.9	10.2	3.4	(24)
(25)		10%	DB	3.0	6.1	12.6	19.7	24.5	27.6	29.0	29.7	25.1	19.5	12.7	5.0	(25)
(26)			MCWB	0.1	1.7	6.2	10.8	14.7	18.7	22.8	23.4	19.1	14.2	9.0	2.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.0	8.7	12.2	17.3	19.8	22.9	25.6	26.2	23.7	19.3	14.5	7.7	(27)
(28)			MCDWB	6.9	10.4	16.6	22.8	23.4	27.0	29.6	30.4	27.9	21.0	16.8	9.7	(28)
(29)		2%	WB	3.1	5.4	10.2	14.7	18.2	21.9	25.0	25.3	22.6	17.4	12.5	5.4	(29)
(30)			MCDWB	5.4	9.5	14.9	21.0	23.3	26.1	28.8	29.8	25.8	20.4	15.1	7.6	(30)
(31)		5%	WB	1.7	3.7	8.3	13.4	17.0	21.0	24.5	24.7	21.5	16.1	10.9	3.8	(31)
(32)			MCDWB	3.9	7.3	13.4	19.1	22.4	25.5	28.1	29.0	24.2	19.4	13.7	6.1	(32)
(33)		10%	WB	0.4	2.2	6.6	12.0	16.1	20.2	23.9	24.2	20.4	14.8	9.5	2.5	(33)
(34)			MCDWB	2.6	5.7	11.8	17.7	21.7	24.6	27.3	28.1	23.4	18.5	12.2	4.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.1	11.0	11.5	13.1	13.0	11.0	7.7	8.2	9.5	11.4	10.6	9.8	(35)
(36)			MCDBR	10.8	13.7	15.7	17.3	16.9	14.1	10.4	10.5	11.6	12.8	13.0	11.0	(36)
(37)			MCWBR	7.3	8.5	8.3	7.5	5.9	4.4	3.2	3.3	4.4	5.6	7.4	7.5	(37)
(38)		5% WB	MCDBR	9.1	12.0	13.5	13.5	12.0	9.7	8.1	8.7	8.2	9.6	10.5	10.1	(38)
(39)			MCWBR	6.7	8.1	8.2	6.8	5.4	3.7	3.1	3.3	3.7	4.7	7.0	7.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.401	0.458	0.552	0.586	0.592	0.648	0.611	0.549	0.473	0.458	0.431	0.395	(40)	
(41)		taud	2.006	1.894	1.732	1.715	1.739	1.682	1.831	1.991	2.141	2.048	2.046	2.059	(41)	
(42)		Ebn at Noon	741	745	711	718	723	682	705	740	778	739	704	717	(42)	
(43)		Edh at Noon	131	166	215	231	229	243	208	173	141	141	126	117	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.54	3.30	4.20	4.91	5.54	5.13	4.16	4.21	3.88	3.51	2.51	2.26	(44)	
(45)		RadStd	0.19	0.31	0.44	0.39	0.49	0.40	0.59	0.58	0.48	0.27	0.32	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.65	N/A	N/A	N/A	N/A	N/A	-126	-191	+141	+58
(47)	Regional (46 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+90	+50

Nomenclature: See separate page