

TAEJON, Korea, Republic of

WMO: 471330

Lat: 36.3719N

Lon: 127.3722E

Elev: 229

StdP: 14.57

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.8	16.1	-1.1	5.2	23.4	2.5	6.3	24.4	18.2	28.8	15.2	29.8	1.9	320	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.4	91.6	78.5	89.2	76.8	86.7	75.3	80.4	88.0	79.1	86.0	77.9	84.2	4.7	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.6	149.7	84.6	77.2	142.8	83.0	76.0	137.0	82.0	44.3	88.4	42.9	86.2	41.6	84.1	86.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.9	12.2	10.4	6.5	94.4	4.4	3.1	3.4	96.7	0.8	98.5	-1.6	100.3	-4.8	102.6		
			5.4	81.7	4.1	2.2	2.4	83.3	0.1	84.5	-2.2	85.7	-5.2	87.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.6	29.8	34.2	43.5	54.9	64.7	72.6	78.2	79.2	70.3	58.6	45.9	33.7
	DBStd	18.12	6.82	7.03	6.91	6.67	4.98	3.87	4.21	4.55	5.01	6.07	7.16	7.10
	HDD50	1999	625	445	223	28	0	0	0	0	0	9	163	506
	HDD65	4767	1090	864	667	309	67	3	0	0	13	209	574	971
	CDD50	4035	0	1	22	174	456	677	876	905	608	277	39	0
	CDD65	1325	0	0	0	5	58	229	411	440	171	11	0	0
	CDH74	11027	0	0	0	79	544	1635	3589	4163	972	45	0	0
	CDH80	3412	0	0	0	6	85	423	1184	1536	178	0	0	0
	WSAvg	3.5	3.3	3.6	4.3	4.4	4.1	3.5	3.8	3.5	3.2	2.8	2.9	2.8
	PrecAvg	53.3	1.1	1.5	2.2	3.5	3.7	6.4	12.2	11.5	6.0	2.2	1.9	1.2
Precipitation	PrecMax	81.5	3.6	4.4	8.6	8.6	7.9	16.2	26.9	30.8	21.7	6.8	6.6	2.6
	PrecMin	32.2	0.0	0.0	0.2	0.6	0.4	0.3	4.1	2.0	0.2	0.1	0.4	0.1
	PrecStd	11.9	0.9	1.1	1.5	2.0	1.9	4.1	5.4	6.3	4.6	1.8	1.4	0.6
	PrecStd	11.9	0.9	1.1	1.5	2.0	1.9	4.1	5.4	6.3	4.6	1.8	1.4	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	59.3	69.6	80.5	85.6	89.7	94.9	95.6	87.4	77.9	69.4	56.3
		MCWB	45.6	50.4	54.4	61.1	64.2	69.8	80.6	79.4	73.4	65.5	58.2	47.8
	2%	DB	46.7	53.5	64.4	76.1	82.3	86.5	91.2	92.6	84.3	75.1	64.8	51.8
		MCWB	40.1	43.9	50.6	57.9	63.0	69.4	78.7	79.3	71.4	63.2	55.5	45.0
	5%	DB	43.3	49.8	60.3	72.5	79.8	84.5	88.7	90.0	81.9	72.4	61.6	48.4
		MCWB	37.8	41.6	48.1	56.1	62.3	68.8	77.6	77.9	70.5	61.9	53.7	42.7
	10%	DB	40.5	46.1	56.6	68.6	77.0	82.4	86.2	87.7	79.6	69.7	58.2	45.2
		MCWB	35.6	38.9	46.2	54.4	61.5	68.3	76.6	77.1	69.4	60.3	51.4	40.3
	0.4%	WB	46.7	52.9	57.7	66.4	70.9	75.8	82.2	82.4	77.2	70.5	61.1	49.8
		MCDB	51.0	56.6	64.7	73.3	77.7	81.8	90.3	90.5	82.7	74.5	66.1	53.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	41.7	46.0	54.0	62.1	67.7	74.1	80.5	80.8	75.3	66.8	57.7	46.3
		MCDB	45.4	51.3	61.3	71.3	76.0	80.3	87.7	88.8	80.7	71.1	62.3	50.3
	5%	WB	38.7	42.2	50.1	59.1	65.5	72.6	79.2	79.6	73.4	63.9	55.2	43.3
		MCDB	42.1	48.4	56.9	68.1	74.1	79.1	85.7	87.0	78.3	69.2	60.2	47.7
	10%	WB	36.1	39.6	47.3	56.4	63.7	71.2	78.1	78.4	71.6	61.7	52.4	40.6
		MCDB	39.8	45.1	54.8	65.0	72.4	78.4	84.0	85.1	77.1	67.8	57.4	44.9
Mean Daily Temperature Range	5% DB	MDBR	16.7	18.6	20.3	22.2	21.3	17.5	12.7	13.4	16.3	20.0	18.9	16.9
		MCDBR	19.3	22.5	25.8	28.2	26.1	22.1	16.7	17.1	18.8	22.1	23.4	20.9
		MCWBR	13.6	14.4	14.4	13.2	10.7	8.7	7.1	6.5	8.1	11.1	14.2	14.7
	5% WB	MCDBR	17.5	20.7	21.4	22.1	20.2	16.1	14.6	15.0	14.6	17.3	19.2	19.6
		MCWBR	13.6	14.8	14.2	13.0	10.8	8.0	7.0	6.6	8.1	10.4	13.6	15.1
Clear-Sky Solar Irradiance	taub		0.436	0.480	0.563	0.591	0.604	0.672	0.621	0.568	0.494	0.477	0.461	0.433
	taud		1.945	1.879	1.725	1.711	1.726	1.649	1.818	1.947	2.087	2.005	1.979	1.973
	Ebn at Noon		224	231	224	227	227	212	221	231	242	230	215	215
	Edh at Noon		45	54	69	74	74	80	67	58	48	47	43	41
	RadAvg		790	1030	1357	1571	1762	1603	1334	1380	1274	1136	800	701
All-Sky Solar Radiation	RadStd		45	84	135	127	160	139	183	198	140	92	93	50

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+1.04	N/A	N/A	N/A	N/A	N/A	N/A	-263	+317	+193
(47) Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+133	N/A

Nomenclature: See separate page