

TAEJON, Korea, Republic of

WMO: 471330

Lat: 36.3719N

Lon: 127.3722E

Elev: 70

StdP: 100.49

Time Zone: 9.00 (E09)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.7	-8.8	-18.4	0.7	-4.8	-16.4	0.9	-4.2	8.2	-1.8	6.8	-1.2	0.8	320	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.4	33.1	25.8	31.8	24.9	30.4	24.0	26.9	31.1	26.2	30.0	25.5	29.0	2.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.9	21.4	29.2	25.1	20.4	28.3	24.4	19.6	27.8	85.3	31.3	82.0	30.1	79.0	28.9	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
6.7	5.4	4.6	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-14.2	34.7	2.4	1.7	-15.9	35.9	-17.3	37.0	-18.7	37.9	-20.4	39.2
			-14.8	27.6	2.3	1.2	-16.4	28.5	-17.7	29.2	-19.0	29.8	-20.7	30.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.1	-1.2	1.2	6.4	12.7	18.2	22.5	25.7	26.2	21.3	14.8	7.7	0.9	(6)
(7)		DBStd	10.07	3.79	3.90	3.84	3.70	2.77	2.15	2.34	2.53	2.78	3.37	3.98	3.94	(7)
(8)		HDD10.0	1111	347	247	124	16	0	0	0	0	5	91	281		(8)
(9)		HDD18.3	2648	606	480	371	172	37	2	0	7	116	319	539		(9)
(10)		CDD10.0	2242	0	1	12	97	253	376	487	503	338	154	22	0	(10)
(11)		CDD18.3	736	0	0	0	3	32	127	228	244	95	6	0	0	(11)
(12)		CDH23.3	6126	0	0	0	44	302	908	1994	2313	540	25	0	0	(12)
(13)		CDH26.7	1896	0	0	0	3	47	235	658	853	99	0	0	0	(13)
(14)	Wind	WSAvg	1.6	1.5	1.6	1.9	2.0	1.8	1.6	1.7	1.6	1.4	1.2	1.3	1.3	(14)
(15)	Precipitation	PrecAvg	1355	28	38	55	88	95	163	309	293	153	57	47	31	(15)
(16)		PrecMax	2071	92	111	218	218	201	411	682	782	550	172	168	66	(16)
(17)		PrecMin	819	1	0	6	15	11	8	103	52	6	2	10	3	(17)
(18)		PrecStd	303	24	27	38	52	47	105	138	159	117	45	35	16	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	15.2	20.9	26.9	29.8	32.0	34.9	35.3	30.8	25.5	20.8	13.5	(19)
(20)			MCWB	7.5	10.2	12.4	16.2	17.9	21.0	27.0	26.4	23.0	18.6	14.6	8.8	(20)
(21)		2%	DB	8.2	11.9	18.0	24.5	27.9	30.3	32.9	33.7	29.0	23.9	18.2	11.0	(21)
(22)			MCWB	4.5	6.6	10.3	14.4	17.2	20.8	25.9	26.3	21.9	17.3	13.0	7.2	(22)
(23)		5%	DB	6.3	9.9	15.7	22.5	26.5	29.2	31.5	32.2	27.7	22.4	16.4	9.1	(23)
(24)			MCWB	3.2	5.4	8.9	13.4	16.8	20.5	25.3	25.5	21.4	16.6	12.1	5.9	(24)
(25)		10%	DB	4.7	7.9	13.7	20.3	25.0	28.0	30.1	30.9	26.5	20.9	14.6	7.4	(25)
(26)			MCWB	2.0	3.8	7.9	12.4	16.4	20.2	24.8	25.0	20.8	15.7	10.8	4.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.2	11.6	14.3	19.1	21.6	24.3	27.9	28.0	25.1	21.4	16.2	9.9	(27)
(28)			MCD B	10.6	13.7	18.2	22.9	25.4	27.7	32.4	32.5	28.2	23.6	18.9	11.9	(28)
(29)		2%	WB	5.4	7.8	12.2	16.7	19.8	23.4	26.9	27.1	24.1	19.3	14.3	8.0	(29)
(30)			MCD B	7.5	10.7	16.3	21.8	24.5	26.8	31.0	31.5	27.0	21.7	16.8	10.2	(30)
(31)		5%	WB	3.7	5.7	10.1	15.1	18.6	22.6	26.2	26.4	23.0	17.7	12.9	6.3	(31)
(32)			MCD B	5.6	9.1	13.8	20.1	23.4	26.2	29.8	30.5	25.7	20.7	15.7	8.7	(32)
(33)		10%	WB	2.3	4.2	8.5	13.6	17.6	21.8	25.6	25.8	22.0	16.5	11.3	4.8	(33)
(34)			MCD B	4.4	7.3	12.6	18.3	22.4	25.8	28.9	29.5	25.1	19.9	14.1	7.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.3	10.3	11.3	12.3	11.8	9.7	7.1	7.4	9.1	11.1	10.5	9.4	(35)
(36)			MCD BR	10.7	12.5	14.3	15.7	14.5	12.3	9.3	9.5	10.4	12.3	13.0	11.6	(36)
(37)			MCWBR	7.5	8.0	8.0	7.3	6.0	4.8	4.0	3.6	4.5	6.2	7.9	8.2	(37)
(38)		5% WB	MCD BR	9.7	11.5	11.9	12.3	11.2	8.9	8.1	8.3	8.1	9.6	10.7	10.9	(38)
(39)			MCWBR	7.5	8.2	7.9	7.2	6.0	4.4	3.9	3.7	4.5	5.8	7.6	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.436	0.480	0.563	0.591	0.604	0.672	0.621	0.568	0.494	0.477	0.461	0.433	(40)	
(41)		taud	1.945	1.879	1.725	1.711	1.726	1.649	1.818	1.947	2.087	2.005	1.979	1.973	(41)	
(42)		Ebn at Noon	707	728	705	716	716	667	698	727	762	726	678	678	(42)	
(43)		Edh at Noon	142	171	218	233	233	251	211	182	150	149	137	130	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.49	3.25	4.28	4.95	5.56	5.05	4.21	4.35	4.02	3.58	2.52	2.21	(44)	
(45)		RadStd	0.14	0.26	0.43	0.40	0.50	0.44	0.58	0.62	0.44	0.29	0.29	0.16	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.58	N/A	N/A	N/A	N/A	N/A	N/A	-146	+176	+107	(46)
(47)	Regional (54 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+74	N/A	(47)

Nomenclature: See separate page